

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Lane

Conventional or Direct Filtration

Month/Year:

Aug-25

System Name:		Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	off	0.02	0.02	0.02	0.02	0.02	0.03	
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
3	0.02	off	0.02	0.02	0.02	0.02	0.02	
4	off	0.02	0.02	0.02	0.02	0.02	0.02	
5	0.02	0.03	0.02	0.02	0.02	0.02	0.03	
6	off	0.02	0.02	0.02	0.02	off	0.02	
7	0.02	off	0.02	0.02	0.02	0.02	0.04	
8	off	0.02	0.02	0.02	0.03	0.02	0.03	
9	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.03	
11	0.02	off	0.02	0.02	0.03	0.02	0.04	
12	0.02	0.02	0.02	0.02	0.02	0.02	0.06	
13	0.02	off	0.03	0.03	off	0.03	0.04	
14	off	0.03	0.02	0.02	0.02	0.02	0.06	
15	off	off	0.02	0.02	0.02	0.02	0.03	
16	0.02	0.02	0.02	0.02	0.02	off	0.03	
17	0.02	off	0.02	0.02	0.02	0.02	0.03	
18	off	0.02	0.02	off	0.03	off	0.03	
19	0.03	0.02	0.02	0.02	0.02	off	0.04	
20	0.02	off	0.02	0.02	0.02	0.02	0.03	
21	off	off	0.02	0.02	0.02	0.02	0.03	
22	off	0.02	0.02	0.02	0.02	0.02	0.03	
23	0.02	0.02	0.02	0.02	0.02	off	0.03	
24	0.02	off	0.02	0.02	0.02	off	0.03	
25	off	0.03	0.02	0.03	off	0.03	0.03	
26	0.02	0.02	0.02	0.03	off	0.03	0.05	
27	off	0.02	0.03	off	0.02	off	0.03	
28	0.02	off	0.03	0.03	0.03	off	0.04	
29	0.03	0.04	0.03	0.03	0.03	0.03	0.04	
30	0.03	0.03	0.03	0.03	0.03	off	0.03	
31	0.03	off	0.03	0.03	0.03	0.03	0.03	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		

Notes:	Carl Neville	
	SIGNATURE:	DATE: 9-3-2025
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

					WTP - : 0301A	
System Name:	Heceta WPUd	ID#: 41	00301A	Month/Year:	Aug-25	Disinfection <i>Giardia</i> Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.9	78	70.2	22.1	6.30	6.4	Yes	693
2	0.9	78	70.2	22.3	6.30	6.3	Yes	694
3	0.89	78	69.4	22.1	6.30	6.4	Yes	689
4	0.87	78	67.9	22.1	6.30	6.4	Yes	690
5	0.97	78	75.7	22.1	6.30	6.4	Yes	697
6	0.95	78	74.1	22.2	6.30	6.4	Yes	677
7	0.93	78	72.5	22.0	6.30	6.5	Yes	699
8	0.96	78	74.9	22.1	6.30	6.4	Yes	692
9	0.94	78	73.3	22.2	6.20	6.1	Yes	685
10	0.94	78	73.3	22.2	6.20	6.1	Yes	695
11	0.95	78	74.1	22.4	6.30	6.3	Yes	686
12	0.95	78	74.1	22.6	6.20	6.0	Yes	693
13	0.93	78	72.5	22.8	6.40	6.3	Yes	597
14	0.88	78	68.6	22.8	6.40	6.3	Yes	621
15	0.96	78	74.9	22.9	6.30	6.1	Yes	684
16	0.98	78	76.4	22.5	6.40	6.5	Yes	638
17	0.99	78	77.2	22.5	6.30	6.3	Yes	634
18	1.02	78	79.6	22.6	6.40	6.5	Yes	669
19	1.02	78	79.6	22.7	6.40	6.5	Yes	687
20	1.02	78	79.6	22.7	6.30	6.2	Yes	685
21	0.97	78	75.7	22.6	6.30	6.2	Yes	658
22	0.93	78	72.5	22.6	6.30	6.2	Yes	697
23	0.95	78	74.1	22.7	6.30	6.2	Yes	657
24	0.93	78	72.5	22.6	6.30	6.2	Yes	632
25	0.92	78	71.8	22.7	6.30	6.1	Yes	622
26	0.95	78	74.1	22.8	6.30	6.1	Yes	608
27	0.92	78	71.8	22.6	6.30	6.2	Yes	628
28	0.93	78	72.5	22.4	6.30	6.3	Yes	658
29	1.01	78	78.8	22.1	6.30	6.5	Yes	696
30	1.06	78	82.7	21.9	6.40	6.9	Yes	650
31	1.04	78	81.1	21.7	6.40	6.9	Yes	669

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012