

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County:

Lane

Conventional or Direct Filtration

Month/Year:

Oct-25

System Name:		Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	off	off	0.04	0.04	off	0.04	0.05	
2	off	off	0.04	0.04	off	off	0.05	
3	0.04	off	off	0.04	off	0.04	0.05	
4	0.04	0.04	off	0.04	off	off	0.05	
5	0.04	off	off	0.04	off	off	0.07	
6	0.04	off	off	0.04	0.04	off	0.06	
7	off	0.03	off	0.04	off	off	0.05	
8	0.04	off	0.04	0.04	0.04	off	0.05	
9	0.05	off	off	0.03	off	off	0.05	
10	0.04	off	off	0.04	off	0.04	0.04	
11	0.04	0.04	off	0.04	off	off	0.05	
12	0.03	off	off	0.03	off	off	0.05	
13	0.03	off	off	0.04	0.04	0.04	0.05	
14	off	off	0.03	0.04	0.04	off	0.05	
15	off	off	0.03	0.03	off	0.03	0.06	
16	off	off	off	0.04	off	off	0.05	
17	off	0.05	0.03	off	0.03	0.04	0.05	
18	0.04	off	0.03	0.04	off	off	0.04	
19	0.04	off	off	0.03	off	off	0.04	
20	0.03	off	off	0.03	0.04	off	0.05	
21	off	off	0.04	0.03	0.04	off	0.05	
22	off	0.04	off	0.04	off	off	0.05	
23	0.03	off	off	0.03	0.03	off	0.05	
24	off	0.03	off	0.03	off	0.03	0.07	
25	0.03	off	0.04	0.03	off	0.04	0.06	
26	off	off	off	0.03	off	0.03	0.04	
27	off	off	off	0.03	0.03	off	0.05	
28	off	0.03	off	0.03	0.04	off	0.05	
29	off	0.03	off	0.03	off	off	0.05	
30	off	off	off	0.03	0.03	off	0.07	
31	off	0.03	off	0.03	0.03	off	0.04	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		

Notes:	Carl Neville	
	SIGNATURE:	DATE: 11-3-2025
	PHONE #: (541) 997-2446	CERT #: FE0103

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

					WTP - : 0301A	
System Name:	Heceta WPUd	ID#: 41	00301A	Month/Year:	Oct-25	Disinfection <i>Giardia</i> Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.9	78	70.2	20.6	6.90	8.9	Yes	603
2	0.86	78	67.1	20.5	6.80	8.6	Yes	634
3	0.89	78	69.4	20.3	6.80	8.7	Yes	646
4	0.93	78	72.5	20.5	7.00	9.3	Yes	639
5	0.87	78	67.9	20.3	6.80	8.7	Yes	624
6	0.85	78	66.3	20.4	6.80	8.6	Yes	640
7	0.9	78	70.2	20.7	6.90	8.8	Yes	669
8	0.91	78	71.0	20.3	6.60	8.1	Yes	694
9	0.86	78	67.1	19.8	6.80	9.0	Yes	644
10	0.87	78	67.9	19.7	6.80	9.1	Yes	530
11	0.91	78	71.0	19.5	6.60	8.6	Yes	662
12	0.84	78	65.5	19.2	6.80	9.3	Yes	624
13	0.93	78	72.5	18.8	6.40	8.3	Yes	626
14	0.83	78	64.7	18.6	6.50	8.7	Yes	628
15	0.89	78	69.4	18.6	6.40	8.4	Yes	616
16	0.88	78	68.6	18.1	6.60	9.4	Yes	623
17	1.01	78	78.8	18.2	6.40	8.8	Yes	654
18	0.99	78	77.2	18.1	6.60	9.5	Yes	640
19	0.92	78	71.8	18.1	6.40	8.7	Yes	627
20	0.91	78	71.0	18.0	6.40	8.8	Yes	618
21	0.91	78	71.0	18.1	6.50	9.1	Yes	623
22	0.94	78	73.3	18.0	6.50	9.2	Yes	601
23	0.9	78	70.2	17.9	6.40	8.8	Yes	606
24	0.95	78	74.1	17.9	6.60	9.6	Yes	630
25	0.96	78	74.9	17.6	6.70	10.2	Yes	641
26	0.9	78	70.2	17.0	6.50	9.8	Yes	603
27	0.95	78	74.1	16.7	6.40	9.6	Yes	513
28	0.94	78	73.3	16.8	6.60	10.3	Yes	650
29	0.92	78	71.8	16.9	6.50	9.9	Yes	598
30	0.89	78	69.4	16.6	6.50	10.0	Yes	686
31	0.96	78	74.9	16.7	6.70	10.8	Yes	663

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012