

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Lane**  
 Month/Year: **Nov-25**

Conventional or Direct Filtration

System Name:	Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.03	0.03	off	0.03	off	0.03	0.04
2	0.03	off	off	0.03	off	off	0.05
3	0.03	off	off	0.03	off	off	0.06
4	0.03	off	off	0.03	0.03	off	0.04
5	off	off	0.03	off	off	off	0.07
6	off	off	0.03	0.03	0.03	off	0.05
7	off	off	off	0.03	0.03	off	0.05
8	0.03	0.03	off	0.03	off	0.03	0.05
9	off	off	off	0.03	off	off	0.05
10	0.04	off	off	0.03	off	off	0.06
11	off	off	0.03	off	off	0.03	0.05
12	off	off	off	0.03	0.04	off	0.08
13	off	off	0.04	off	off	0.04	0.07
14	off	off	off	0.04	off	0.04	0.06
15	0.04	0.04	off	0.03	off	0.03	0.09
16	off	off	off	0.03	off	off	0.06
17	0.04	off	0.03	0.04	off	off	0.08
18	0.04	off	off	0.04	0.04	off	0.07
19	off	0.03	off	0.03	0.04	off	0.06
20	off	0.03	off	off	0.04	off	0.07
21	off	0.04	off	0.03	off	0.03	0.08
22	0.03	off	off	0.04	off	off	0.06
23	0.03	off	off	0.04	off	off	0.06
24	0.04	off	off	0.03	0.03	off	0.06
25	off	0.03	off	0.03	0.04	off	0.08
26	off	off	0.03	0.04	off	off	0.10
27	off	off	off	0.04	off	off	0.06
28	0.03	off	off	0.03	off	0.03	0.07
29	0.04	0.04	0.04	off	0.04	off	0.12
30	off	0.03	off	off	off	0.03	0.07
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / No		

<b>Notes:</b>	<b>Carl Neville</b>	
	<b>SIGNATURE:</b>	<b>DATE: 12-1-2025</b>
	<b>PHONE #: ( 541) 997-2446</b>	<b>CERT #: FE0103</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPU D	ID#: 41	00301A	Month/Year:	Nov-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------	---------	--------	-------------	--------	--	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1	78	78.0	16.8	6.40	9.6	Yes	634
2	0.9	78	70.2	16.5	6.50	10.1	Yes	634
3	0.89	78	69.4	16.5	6.50	10.1	Yes	622
4	0.9	78	70.2	16.3	6.50	10.2	Yes	663
5	0.94	78	73.3	16.3	6.40	9.9	Yes	608
6	0.95	78	74.1	16.3	6.40	9.9	Yes	638
7	0.88	78	68.6	16.0	6.50	10.4	Yes	690
8	0.9	78	70.2	15.9	6.40	10.1	Yes	606
9	0.9	78	70.2	15.8	6.50	10.6	Yes	609
10	0.9	78	70.2	15.8	6.50	10.6	Yes	619
11	0.9	78	70.2	15.9	6.50	10.5	Yes	603
12	0.9	78	70.2	16.0	6.50	10.4	Yes	608
13	0.9	78	70.2	15.9	6.40	10.1	Yes	607
14	0.9	78	70.2	15.8	6.60	11.0	Yes	658
15	0.9	78	70.2	15.8	6.70	11.4	Yes	614
16	0.83	78	64.7	15.6	6.50	10.6	Yes	600
17	0.88	78	68.6	15.5	6.40	10.4	Yes	674
18	0.9	78	70.2	15.1	6.60	11.5	Yes	669
19	0.94	78	73.3	14.9	6.90	13.1	Yes	606
20	0.95	78	74.1	14.9	6.80	12.7	Yes	603
21	0.94	78	73.3	14.6	6.80	12.9	Yes	662
22	0.97	78	75.7	14.5	7.00	14.0	Yes	661
23	0.91	78	71.0	14.4	6.80	13.0	Yes	604
24	0.91	78	71.0	14.3	6.80	13.1	Yes	678
25	0.93	78	72.5	14.1	6.60	12.4	Yes	664
26	0.94	78	73.3	14.2	6.40	11.4	Yes	597
27	0.91	78	71.0	14.2	6.50	11.8	Yes	612
28	0.91	78	71.0	14.3	6.40	11.3	Yes	609
29	0.95	78	74.1	14.1	6.50	11.9	Yes	627
30	0.92	78	71.8	14.0	6.60	12.4	Yes	615
31			0.0			4.2		

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012