

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Lane  
 Month/Year: Dec-25

Conventional or Direct Filtration

System Name:	Haceta WPUD		ID#: 41	00301A			WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	off	off	off	0.03	0.03	off	0.06	
2	off	0.04	0.04	0.04	off	off	0.05	
3	0.04	off	off	0.04	off	off	0.08	
4	0.03	off	off	0.03	0.04	off	0.04	
5	off	0.03	off	0.03	off	0.04	0.05	
6	0.04	0.03	off	0.03	off	off	0.04	
7	0.03	off	off	0.03	off	off	0.04	
8	0.03	off	off	0.03	0.04	off	0.05	
9	off	off	0.04	off	0.04	off	0.06	
10	off	0.03	off	0.04	0.03	0.03	0.05	
11	off	off	0.03	0.03	0.03	off	0.04	
12	off	off	0.03	off	off	0.03	0.04	
13	0.05	0.04	0.04	0.04	off	off	0.05	
14	0.03	off	off	0.03	off	off	0.04	
15	0.03	off	off	0.03	0.03	0.04	0.04	
16	off	off	0.03	0.03	0.04	off	0.05	
17	off	off	off	0.03	0.03	0.03	0.06	
18	off	off	0.03	0.03	0.04	off	0.05	
19	off	off	off	0.04	0.03	0.04	0.06	
20	0.04	0.04	off	0.03	0.03	off	0.04	
21	0.03	0.03	off	0.04	off	off	0.04	
22	0.03	off	off	0.03	0.04	0.04	0.05	
23	off	off	0.03	0.03	0.03	0.03	0.06	
24	off	off	off	0.03	0.03	0.03	0.06	
25	off	off	off	0.03	0.03	off	0.05	
26	off	0.03	off	0.04	off	0.03	0.05	
27	0.04	0.03	0.03	0.03	off	off	0.04	
28	0.03	off	off	0.03	off	off	0.05	
29	0.03	off	0.04	0.03	0.04	0.04	0.05	
30	off	off	off	0.05	0.03	0.03	0.05	
31	off	off	0.03	0.03	0.03	off	0.05	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / No		

Notes:	Carl Neville	
	SIGNATURE:	DATE: 1-3-2026
	PHONE #: ( 541) 997-2446	CERT #: FE0103

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**WTP - : 0301A**

<b>System Name:</b>	Heceta WPUD	<b>ID#:</b> 41	00301A	<b>Month/Year:</b>	Dec-25	<b>Disinfection <i>Giardia</i> Log Inactiv:</b>	0.5
---------------------	-------------	----------------	--------	--------------------	--------	---	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.9	78	70.2	13.7	6.40	11.7	Yes	597
2	0.93	78	72.5	13.7	6.70	13.2	Yes	639
3	0.92	78	71.8	13.6	6.50	12.3	Yes	643
4	1	78	78.0	13.5	6.40	12.0	Yes	599
5	1.1	78	85.8	13.7	6.50	12.5	Yes	650
6	1.1	78	85.8	13.7	6.50	12.5	Yes	608
7	1.06	78	82.7	13.8	6.50	12.3	Yes	606
8	1.05	78	81.9	13.8	6.40	11.9	yes	617
9	0.99	78	77.2	13.8	6.40	11.8	yes	580
10	1.02	78	79.6	14.0	6.60	12.6	yes	624
11	0.99	78	77.2	13.9	6.50	12.2	yes	602
12	0.93	78	72.5	13.8	6.60	12.6	yes	657
13	0.94	78	73.3	13.8	6.40	11.7	yes	593
14	0.94	78	73.3	13.8	6.50	12.2	yes	626
15	0.96	78	74.9	13.9	6.50	12.1	yes	656
16	0.95	78	74.1	14.0	6.50	12.0	yes	586
17	0.97	78	75.7	14.0	7.00	14.5	yes	457
18	0.91	78	71.0	13.8	6.70	13.1	yes	583
19	0.93	78	72.5	13.8	6.50	12.2	yes	589
20	0.94	78	73.3	13.5	7.00	15.0	yes	650
21	0.9	78	70.2	13.5	6.50	12.4	Yes	593
22	0.9	78	70.2	13.4	6.50	12.4	Yes	583
23	0.84	78	65.5	13.3	6.64	13.1	Yes	584
24	0.84	78	65.5	13.0	6.60	13.2	Yes	591
25	0.91	78	71.0	12.9	6.50	12.9	Yes	588
26	0.9	78	70.2	12.9	6.70	13.9	Yes	669
27	0.9	78	70.2	12.8	6.60	13.4	Yes	572
28	0.88	78	68.6	12.5	6.50	13.2	yes	606
29	0.88	78	68.6	12.5	7.00	15.9	Yes	573
30	0.84	78	65.5	12.3	6.50	13.8	Yes	582
31	0.84	78	65.5	12.2	6.70	14.9	Yes	584

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012