

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Lane**  
 Month/Year: **Feb-26**

Conventional or Direct Filtration

System Name:	Haceta WPUD		ID#: 41	00301A		WTP : TP -	00301A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.04	off	off	0.04	off	off	0.10
2	0.04	off	off	0.04	0.04	0.04	0.11
3	off	off	0.04	0.04	0.04	off	0.11
4	off	off	0.04	0.05	off	off	0.15
5	0.04	off	off	0.04	0.05	off	0.12
6	off	off	0.04	0.04	off	0.04	0.15
7	0.04	0.04	0.04	0.04	off	off	0.05
8	0.04	off	0.04	0.05	off	0.04	0.10
9	0.04	off	off	0.04	0.05	0.04	0.09
10	off	off	off	0.04	0.04	0.04	0.13
11	off	off	off	0.05	off	off	0.11
12	0.04	off	off	0.04	0.04	off	0.09
13	off	0.04	off	0.04	off	0.04	0.09
14	0.04	0.04	0.04	0.05	0.04	off	0.05
15	off	0.04	off	0.04	off	0.04	0.09
16	0.04	off	off	0.04	0.04	off	0.08
17	off	off	0.04	0.04	0.04	off	0.08
18	off	0.04	off	0.04	0.04	off	0.08
19	off	0.04	off	0.04	0.04	0.04	0.07
20	off	off	0.04	0.04	off	0.04	0.08
21	0.04	0.04	0.04	0.04	off	off	0.04
22	0.04	off	off	0.04	off	off	0.05
23	0.04	off	0.04	0.04	0.04	0.04	0.05
24	off	off	0.04	0.04	0.04	off	0.06
25	off	off	0.04	off	0.04	0.04	0.08
26	off	off	off	0.04	0.04	off	0.09
27	off	0.04	off	0.04	off	0.04	0.06
28	0.04	0.04	0.04	0.04	off	off	0.05
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / No		

<b>Notes:</b>	<b>Carl Neville</b>	
	<b>SIGNATURE:</b>	<b>DATE: 3-3-2026</b>
	<b>PHONE #: ( 541) 997-2446</b>	<b>CERT #: FE0103</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : 0301A

System Name:	Heceta WPUD	ID#: 41	00301A	Month/Year:	Feb-26	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-------------	---------	--------	-------------	--------	------------------------------------------	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.89	78	69.4	11.0	6.80	16.7	Yes	575
2	0.86	78	67.1	11.1	6.50	14.9	yes	594
3	0.81	78	63.2	11.2	6.70	15.8	Yes	602
4	0.75	78	58.5	11.4	7.00	17.2	Yes	588
5	0.86	78	67.1	11.6	6.60	15.0	Yes	665
6	0.9	78	70.2	11.6	6.60	15.0	Yes	650
7	0.88	78	68.6	11.5	6.60	15.1	Yes	601
8	0.86	78	67.1	11.6	6.60	15.0	Yes	578
9	0.86	78	67.1	11.4	6.60	15.2	Yes	592
10	0.93	78	72.5	11.3	6.60	15.4	Yes	574
11	0.95	78	74.1	11.2	6.50	15.0	Yes	608
12	0.94	78	73.3	11.3	6.70	15.9	Yes	587
13	0.99	78	77.2	11.4	6.90	17.0	Yes	650
14	1.04	78	81.1	11.4	6.50	15.0	Yes	473
15	0.93	78	72.5	11.4	6.80	16.3	Yes	581
16	0.9	78	70.2	11.4	6.60	15.2	Yes	656
17	0.9	78	70.2	11.1	6.60	15.5	Yes	575
18	0.92	78	71.8	10.8	7.10	18.8	Yes	581
19	0.88	78	68.6	10.5	6.90	17.8	Yes	647
20	0.93	78	72.5	10.6	7.00	18.4	Yes	668
21	0.93	78	72.5	10.8	6.70	16.4	Yes	600
22	1.05	78	81.9	11.1	6.70	16.3	Yes	605
23	1.05	78	81.9	11.1	6.70	16.3	Yes	572
24	1.03	78	80.3	11.1	6.70	16.3	Yes	574
25	1.03	78	80.3	11.0	6.80	16.9	Yes	640
26	1.01	78	78.8	11.1	6.50	15.2	Yes	591
27	1.04	78	81.1	11.2	6.80	16.8	Yes	651
28	1.05	78	81.9	11.3	6.60	15.6	Yes	589
29			0.0			4.2		
30			0.0			4.2		
31			0.0			4.2		

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012