


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Lane**
 Month/Year: **March-21**

System Name: South Coast W.D.		ID#: 41 00302		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				0.037			
2				0.037			
3				0.037			
4				0.037			
5				0.037			
6				0.037			
7				0.037			
8				0.037			
9				0.037			
10				0.037			
11				0.037			
12				0.037			
13				0.037			
14				0.037			
15				0.037			
16				0.037			
17				0.037			
18				0.037			
19				0.037			
20				0.037			
21				0.037			
22				0.037			
23				0.036			
24				0.036			
25				0.036			
26				0.036			
27				0.036			
28				0.036			
29				0.036			
30				0.036			
31				0.036			

Slow Sand/Membrane/DE Filtration/Unfiltered				Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU? ²		Yes		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?		Yes		Yes	Yes		
Notes:				PRINTED NAME: Daniel Reitz			
				SIGNATURE: 	DATE: 04/05/2021		
				PHONE #: (541) 342-1718	CERT #: 6528		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :
System Name: South Coast Water ID#: 41 00302 Month/Year: Mar-21
Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.58	104	60.3	13.6	7.4	16.6	yes	
2	0.62	104	64.5	11.2	7.4	19.6	yes	
3	0.61	104	63.4	11.5	7.4	19.3	yes	
4	0.60	104	62.4	11.7	7.4	19.0	yes	
5	0.60	104	62.4	11.7	7.3	18.4	yes	
6	0.61	104	63.4	11.6	7.4	19.2	yes	
7	0.61	104	63.4	11.7	7.3	18.3	yes	
8	0.62	104	64.5	10.8	7.3	19.5	yes	
9	0.67	104	69.7	8.9	7.3	22.1	yes	
10	0.64	104	66.6	11.1	7.5	20.5	yes	
11	0.62	104	64.5	13.3	7.9	20.4	yes	
12	0.69	104	71.8	11.2	8.1	25.3	yes	
13	0.76	104	79.0	12.3	8.7	29.4	yes	
14	0.71	104	73.8	12.1	8.4	26.7	yes	
15	0.67	104	69.7	12.6	8.2	24.0	yes	
16	0.74	104	77.0	10.7	8.3	28.3	yes	
17	0.73	104	75.9	11.6	8.4	27.7	yes	
18	0.88	104	91.5	11.6	9.1	36.2	yes	
19	0.84	104	87.4	11.3	8.9	34.1	yes	
20	0.87	104	90.5	11.5	9.0	35.1	yes	
21	0.76	104	79.0	11.7	8.6	29.6	yes	
22	0.65	104	67.6	12.2	8.0	22.7	yes	
23	0.69	104	71.8	9.7	7.8	25.1	yes	
24	0.66	104	68.6	10.9	7.7	22.4	yes	
25	0.60	104	62.4	12.7	7.6	19.0	yes	
26	0.64	104	66.6	10.8	7.5	20.9	yes	
27	0.59	104	61.4	12.9	7.4	17.4	yes	
28	0.60	104	62.4	12.1	7.4	18.5	yes	
29	0.60	104	62.4	12.2	7.3	17.8	yes	
30	0.64	104	66.6	10.0	7.3	20.6	yes	
31	0.56	104	58.2	13.9	7.3	15.6	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013