

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: 

Lane
------


  
 Month/Year: 

July-21
---------

System Name: **South Coast W.D.** ID#: **41 00302** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.03	0.03	0.03	0.031	0.03	0.03	0.034
2	0.04	0.03	0.03	0.034	0.03	0.03	0.042
3	0.03	0.03	0.03	0.029	0.03	0.04	0.035
4	0.04	0.03	0.03	0.028	0.03	0.03	0.034
5	0.03	0.03	0.03	0.034	0.03	0.03	0.034
6	0.03	0.03	0.03	0.033	0.03	0.03	0.034
7	0.03	0.03	0.03	0.032	0.03	0.03	0.034
8	0.03	0.03	0.03	0.034	0.03	0.03	0.034
9	0.04	0.03	0.03	0.031	0.03	0.03	0.035
10	0.03	0.03	0.03	0.032	0.03	0.03	0.034
11	0.03	0.03	0.03	0.032	0.03	0.03	0.034
12	0.03	0.03	0.03	0.033	0.03	0.03	0.034
13	0.03	0.03	0.04	0.035	0.05	0.03	0.035
14	0.04	0.05	0.03	0.032	0.03	0.03	0.052
15	0.03	0.04	0.03	0.033	0.03	0.03	0.039
16	0.03	0.03	0.03	0.035	0.034	0.033	0.035
17	0.032	0.030	0.031	0.031	0.030	0.041	0.041
18	0.030	0.033	0.031	0.033	0.034	0.036	0.036
19	0.029	0.035	0.034	0.033	0.034	0.034	0.035
20	0.028	0.034	0.032	0.034	0.032	0.033	0.034
21	0.032	0.031	0.028	0.036	0.035	0.031	0.036
22	0.029	0.034	0.033	0.033	0.042	0.034	0.034
23	0.034	0.031	0.032	0.033	0.031	0.034	0.034
24	0.032	0.031	0.044	0.031	0.031	0.034	0.044
25	0.031	0.030	0.031	0.031	0.034	0.032	0.034
26	0.032	0.028	0.030	0.031	0.031	0.032	0.032
27	0.034	0.034	0.030	0.033	0.032	0.034	0.034
28	0.031	0.030	0.032	0.031	0.031	0.032	0.034
29	0.031	0.031	0.047	0.031	0.033	0.032	0.047
30	0.030	0.032	0.031	0.031	0.030	0.030	0.032
31	0.030	0.032	0.031	0.031	0.030	0.030	0.032

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<b>Notes:</b>	<b>PRINTED NAME: Daniel Reitz</b>	
	<b>SIGNATURE:</b> 	<b>DATE:08/06/2021</b>
	<b>PHONE #: ( 541 ) 342-1718</b>	<b>CERT #: 6528</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

WTP- :

System Name: **South Coast Water**

ID#: **41**

**00302**

Month/Year: **Jul-21**

Disinfection *Giardia* Log Inactiv: **0.5**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.50	104	52.0	22.9	7.3	8.4	yes	
2	0.54	104	56.2	21.3	7.3	9.5	yes	
3	0.52	104	54.1	22.3	7.4	9.2	yes	
4	0.51	104	53.0	22.8	7.3	8.5	yes	
5	0.51	104	53.0	22.4	7.3	8.7	yes	
6	0.52	104	54.1	22.3	7.3	8.8	yes	
7	0.52	104	54.1	21.9	7.3	9.1	yes	
8	0.51	104	53.0	22.4	7.3	8.7	yes	
9	0.56	104	58.2	19.9	7.3	10.4	yes	
10	0.53	104	55.1	21.8	7.3	9.1	yes	
11	0.54	104	56.2	20.9	7.3	9.7	yes	
12	0.52	104	54.1	21.8	7.3	9.1	yes	
13	0.57	104	59.3	19.5	7.3	10.7	yes	
14	0.54	104	56.2	20.8	7.3	9.8	yes	
15	0.51	104	53.0	22.7	7.3	8.6	yes	
16	0.56	104	58.2	19.9	7.3	10.4	yes	
17	0.50	104	52.0	22.9	7.3	8.4	yes	
18	0.52	104	54.1	22.0	7.3	9.0	yes	
19	0.49	104	51.0	23.8	7.3	7.9	yes	
20	0.51	104	53.0	22.1	7.3	9.0	yes	
21	0.52	104	54.1	22.0	7.3	9.0	yes	
22	0.51	104	53.0	22.4	7.3	8.7	yes	
23	0.55	104	57.2	20.2	7.3	10.2	yes	
24	0.51	104	53.0	22.1	7.3	8.9	yes	
25	0.52	104	54.1	21.8	7.3	9.1	yes	
26	0.51	104	53.0	22.3	7.3	8.8	yes	
27	0.53	104	55.1	21.1	7.3	9.6	yes	
28	0.50	104	52.0	22.7	7.3	8.5	yes	
29	0.49	104	51.0	23.3	7.3	8.2	yes	
30	0.52	104	54.1	21.4	7.3	9.3	yes	
31	0.50	105	52.5	22.7	7.3	8.6	yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013