

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:

Lane

 Month/Year:

October-21

System Name:	South Coast W.D.			ID#: 41	00302	WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.03	0.031	0.03	0.03	0.034
2	0.03	0.03	0.03	0.052	0.03	0.03	0.052
3	0.03	0.03	0.03	0.033	0.03	0.05	0.052
4	0.03	0.03	0.03	0.034	0.04	0.03	0.036
5	0.03	0.03	0.03	0.034	0.03	0.03	0.034
6	0.03	0.03	0.03	0.034	0.03	0.03	0.034
7	0.03	0.03	0.03	0.031	0.03	0.03	0.034
8	0.03	0.03	0.03	0.034	0.03	0.03	0.034
9	0.03	0.03	0.03	0.032	0.03	0.03	0.034
10	0.03	0.03	0.03	0.033	0.03	0.03	0.033
11	0.03	0.03	0.03	0.048	0.03	0.03	0.048
12	0.03	0.03	0.03	0.034	0.03	0.03	0.034
13	0.03	0.03	0.03	0.034	0.03	0.03	0.034
14	0.03	0.03	0.03	0.030	0.03	0.03	0.034
15	0.03	0.03	0.03	0.033	0.03	0.03	0.034
16	0.03	0.03	0.03	0.034	0.032	0.032	0.034
17	0.031	0.034	0.032	0.034	0.030	0.027	0.034
18	0.031	0.030	0.034	0.029	0.030	0.031	0.034
19	0.029	0.029	0.034	0.031	0.034	0.034	0.034
20	0.031	0.030	0.031	0.034	0.029	0.053	0.053
21	0.027	0.030	0.031	0.031	0.031	0.034	0.034
22	0.034	0.051	0.030	0.031	0.034	0.031	0.051
23	0.031	0.033	0.034	0.030	0.031	0.031	0.034
24	0.033	0.032	0.029	0.031	0.031	0.031	0.033
25	0.031	0.034	0.030	0.031	0.032	0.056	0.056
26	0.034	0.033	0.031	0.033	0.030	0.029	0.034
27	0.050	0.031	0.032	0.030	0.034	0.031	0.050
28	0.050	0.031	0.033	0.031	0.034	0.050	0.050
29	0.029	0.034	0.031	0.031	0.031	0.033	0.034
30	0.033	0.031	0.031	0.031	0.029	0.027	0.033
31	0.029	0.030	0.030	0.032	0.030	0.034	0.034

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Daniel Reitz	
	SIGNATURE:	DATE: 11/04/2021
	PHONE #: (541) 342-1718	CERT #: 6528

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: **South Coast Water**

ID#: **41**

00302

Month/Year: **Oct-21**

Disinfection *Giardia* Log Inactiv: **0.5**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.85	104	88.4	18.7	7.5	12.6	yes	
2	0.74	104	77.0	19.1	7.5	12.1	yes	
3	0.82	104	85.3	18.9	7.5	12.4	yes	
4	0.81	104	84.2	18.9	7.5	12.3	yes	
5	0.83	104	86.3	19.0	7.5	12.3	yes	
6	0.83	104	86.3	17.8	7.5	13.3	yes	
7	0.92	104	95.7	17.8	7.5	13.5	yes	
8	0.85	104	88.4	16.9	7.5	14.2	yes	
9	0.83	104	86.3	17.8	7.5	13.4	yes	
10	0.80	104	83.2	18.9	7.5	12.4	yes	
11	0.84	104	87.4	17.2	7.5	13.9	yes	
12	0.90	104	93.6	16.3	7.5	14.9	yes	
13	0.91	104	94.6	15.6	7.5	15.6	yes	
14	0.89	104	92.6	16.9	7.5	14.2	yes	
15	0.97	104	100.9	17.5	7.5	13.8	yes	
16	0.84	104	87.4	18.1	7.5	13.1	yes	
17	0.75	104	78.0	18.8	7.5	12.4	yes	
18	0.90	104	93.6	16.1	7.5	15.0	yes	
19	0.90	104	93.6	16.7	7.5	14.5	yes	
20	0.84	104	87.4	16.8	7.5	14.3	yes	
21	0.84	104	87.4	17.8	7.5	13.4	yes	
22	0.92	104	95.7	16.7	7.6	15.1	yes	
23	0.70	104	72.8	16.3	7.6	15.0	yes	
24	0.87	104	90.5	15.9	7.6	15.8	yes	
25	0.62	104	64.5	15.8	7.6	15.5	yes	
26	0.88	104	91.5	15.9	7.5	15.2	yes	
27	0.84	104	87.4	15.7	7.5	15.3	yes	
28	0.74	104	77.0	16.9	7.5	14.0	yes	
29	0.76	104	79.0	18.6	7.5	12.6	yes	
30	0.91	104	94.6	15.8	7.5	15.4	yes	
31	0.90	104	93.6	16.4	7.5	14.8	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013