

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:

Lane

 Month/Year:

March-23


System Name: **South Coast W.D.** ID#: **41 00302** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.033	0.030	0.032	0.029	0.028	0.029	0.033
2	0.027	0.032	0.027	0.030	0.031	0.035	0.035
3	0.034	0.034	0.032	0.031	0.028	0.027	0.034
4	0.033	0.034	0.029	0.030	0.031	0.030	0.034
5	0.028	0.028	0.030	0.029	0.032	0.031	0.032
6	0.028	0.030	0.029	0.031	0.030	0.033	0.033
7	0.031	0.030	0.028	0.034	0.029	0.032	0.034
8	0.033	0.032	0.029	0.031	0.032	0.032	0.033
9	0.028	0.031	0.032	0.031	0.033	0.033	0.033
10	0.031	0.029	0.032	0.031	0.031	0.033	0.033
11	0.027	0.033	0.027	0.034	0.030	0.034	0.034
12	0.034	0.030	0.031	0.031	0.026	0.031	0.034
13	0.031	0.034	0.029	0.025	0.031	0.029	0.034
14	0.028	0.030	0.028	0.029	0.033	0.026	0.033
15	0.031	0.026	0.030	0.031	0.030	0.030	0.031
16	0.034	0.033	0.032	0.028	0.030	0.028	0.034
17	0.031	0.031	0.034	0.031	0.031	0.032	0.034
18	0.033	0.027	0.031	0.030	0.035	0.030	0.035
19	0.030	0.032	0.030	0.030	0.031	0.030	0.032
20	0.031	0.034	0.031	0.030	0.031	0.032	0.034
21	0.031	0.025	0.025	0.027	0.033	0.028	0.033
22	0.030	0.033	0.028	0.028	0.034	0.030	0.034
23	0.030	0.031	0.028	0.032	0.032	0.034	0.034
24	0.031	0.034	0.032	0.031	0.032	0.031	0.034
25	0.029	0.027	0.029	0.031	0.029	0.031	0.031
26	0.031	0.034	0.025	0.031	0.028	0.032	0.034
27	0.030	0.031	0.026	0.033	0.033	0.031	0.033
28	0.028	0.034	0.034	0.031	0.030	0.031	0.034
29	0.034	0.033	0.033	0.026	0.029	0.030	0.034
30	0.028	0.030	0.033	0.034	0.028	0.032	0.034
31	0.033	0.034	0.031	0.027	0.031	0.033	0.034

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:

PRINTED NAME: Daniel Reitz

SIGNATURE: 

DATE: 04/03/2023

PHONE #: (541) 342-1718

CERT #: 6528

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: **South Coast Water**

ID#: **41**

00302

Month/Year: **Mar-23**

Disinfection *Giardia* Log Inactiv: **0.5**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.37	104	38.5	7.9	7.7	26.4	yes	
2	0.38	104	39.5	8.7	7.3	21.8	yes	
3	0.36	104	37.4	8.0	7.3	22.7	yes	
4	0.35	104	36.4	7.8	7.5	24.7	yes	
5	0.31	104	32.2	7.8	7.4	23.7	yes	
6	0.29	104	30.2	8.3	7.5	23.7	yes	
7	0.27	104	28.1	7.9	7.5	24.3	yes	
8	0.28	104	29.1	7.7	7.6	25.6	yes	
9	0.24	104	25.0	8.1	7.6	24.8	yes	
10	0.25	104	26.0	7.4	7.6	26.0	yes	
11	0.27	104	28.1	9.6	7.7	23.3	yes	
12	0.30	104	31.2	9.7	7.7	23.2	yes	
13	0.29	104	30.2	10.1	7.7	22.6	yes	
14	0.28	104	29.1	8.0	7.7	26.0	yes	
15	0.29	104	30.2	9.7	7.7	23.2	yes	
16	0.32	104	33.3	10.7	7.6	21.1	yes	
17	0.31	104	32.2	9.1	7.5	22.6	yes	
18	0.35	104	36.4	11.4	7.6	20.2	yes	
19	0.34	104	35.4	11.1	7.6	20.6	yes	
20	0.30	104	31.2	11.1	7.6	20.5	yes	
21	0.28	104	29.1	9.2	7.6	23.1	yes	
22	0.32	104	33.3	10.9	7.6	20.8	yes	
23	0.25	104	26.0	10.4	7.6	21.3	yes	
24	0.27	104	28.1	8.8	7.6	23.7	yes	
25	0.23	104	23.9	9.6	7.6	22.4	yes	
26	0.25	104	26.0	10.0	7.6	21.9	yes	
27	0.30	104	31.2	9.3	7.5	22.2	yes	
28	0.39	104	40.6	9.2	7.5	22.6	yes	
29	0.37	104	38.5	11.4	7.6	20.2	yes	
30	0.42	104	43.7	12.2	7.6	19.3	yes	
31	0.47	104	48.9	11.2	7.7	21.5	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013