

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:

Lane


 Month/Year:

June-23

System Name: **South Coast W.D.** ID#: **41 00302** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.033	0.030	0.031	0.034	0.031	0.040	0.040
2	0.030	0.033	0.033	0.033	0.031	0.031	0.033
3	0.030	0.027	0.030	0.027	0.028	0.027	0.030
4	0.027	0.033	0.034	0.028	0.027	0.033	0.034
5	0.031	0.033	0.028	0.027	0.030	0.033	0.033
6	0.032	0.033	0.031	0.031	0.030	0.032	0.033
7	0.029	0.031	0.033	0.031	0.032	0.030	0.033
8	0.028	0.030	0.034	0.034	0.031	0.027	0.034
9	0.033	0.028	0.029	0.029	0.028	0.031	0.033
10	0.031	0.033	0.032	0.027	0.034	0.033	0.034
11	0.033	0.034	0.030	0.032	0.028	0.034	0.034
12	0.031	0.033	0.029	0.033	0.031	0.031	0.033
13	0.031	0.032	0.031	0.033	0.031	0.034	0.034
14	0.034	0.032	0.033	0.033	0.033	0.034	0.034
15	0.028	0.032	0.028	0.031	0.033	0.034	0.034
16	0.033	0.033	0.033	0.030	0.034	0.032	0.034
17	0.033	0.027	0.034	0.031	0.033	0.030	0.034
18	0.030	0.031	0.033	0.029	0.034	0.033	0.034
19	0.031	0.027	0.028	0.030	0.028	0.031	0.031
20	0.034	0.031	0.030	0.031	0.030	0.031	0.034
21	0.034	0.032	0.034	0.027	0.031	0.031	0.034
22	0.031	0.034	0.033	0.032	0.031	0.030	0.034
23	0.034	0.029	0.033	0.032	0.033	0.031	0.034
24	0.031	0.034	0.033	0.031	0.028	0.031	0.034
25	0.031	0.031	0.027	0.031	0.034	0.030	0.034
26	0.030	0.033	0.027	0.032	0.030	0.027	0.033
27	0.035	0.026	0.031	0.031	0.032	0.034	0.035
28	0.033	0.031	0.032	0.033	0.031	0.030	0.033
29	0.030	0.029	0.027	0.028	0.031	0.031	0.031
30	0.034	0.031	0.031	0.029	0.031	0.033	0.034

		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: Daniel Reitz	
	SIGNATURE: 	DATE: 7/3/2023
	PHONE #: (541) 342-1718	CERT #: 6528

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: **South Coast Water**

ID#: **41**

00302

Month/Year: **Jun-23**

Disinfection *Giardia* Log

Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.50	104	52.0	18.7	7.9	14.0	yes	
2	0.54	104	56.2	16.7	7.9	16.1	yes	
3	0.62	104	64.5	19.1	7.9	13.8	yes	
4	0.63	104	65.5	18.1	7.9	14.8	yes	
5	0.79	104	82.2	19.0	7.9	14.2	yes	
6	0.59	104	61.4	17.0	7.9	15.9	yes	
7	1.01	104	105.0	19.9	7.9	13.7	yes	
8	1.11	104	115.4	21.1	7.9	12.8	yes	
9	1.13	104	117.5	19.7	7.8	13.6	yes	
10	1.20	104	124.8	20.8	7.9	13.2	yes	
11	1.20	104	124.8	19.4	7.9	14.5	yes	
12	1.30	104	135.2	21.1	7.9	13.1	yes	
13	1.20	104	124.8	19.4	7.9	14.5	yes	
14	0.55	104	57.2	19.6	7.9	13.3	yes	
15	0.57	104	59.3	19.6	7.9	13.3	yes	
16	0.56	104	58.2	18.2	7.9	14.6	yes	
17	0.65	104	67.6	20.9	7.9	12.3	yes	
18	0.64	104	66.6	20.4	7.9	12.7	yes	
19	0.65	104	67.6	20.4	7.9	12.7	yes	
20	0.58	104	60.3	18.4	7.9	14.4	yes	
21	0.65	104	67.6	20.8	7.9	12.4	yes	
22	0.69	104	71.8	22.6	7.9	11.0	yes	
23	0.65	104	67.6	19.9	7.9	13.2	yes	
24	0.66	104	68.6	21.1	7.9	12.2	yes	
25	0.66	104	68.6	20.6	7.9	12.6	yes	
26	0.70	104	72.8	22.1	7.9	11.4	yes	
27	0.67	104	69.7	20.4	7.9	12.8	yes	
28	0.72	104	74.9	22.6	7.9	11.1	yes	
29	0.72	104	74.9	23.1	7.9	10.7	yes	
30	0.72	104	74.9	21.0	7.9	12.3	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013