

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
Conventional or Direct Filtration**

System Name: FOREST GROVE, CITY OF		ID #: 4100305 WTP-:WTP-A			Month/Year:		Jan-25
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the day ¹ (NTU)
1	0.02	0.02	0.02	0.02	0.01	0.01	0.02
2	0.01	0.01	0.01	0.01	0.01	0.01	0.02
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.01	off	off	0.02	0.01	0.02	0.02
5	Off	Off	Off	0.01	0.01	0.02	0.02
6	0.02	0.02	0.01	0.01	0.02	0.01	0.02
7	0.02	0.01	0.02	0.01	0.01	0.01	0.03
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.01	0.02	0.02	0.02	0.02	0.01	0.02
10	0.01	0.01	0.01	0.02	0.02	0.05	0.05
11	0.02	0.02	0.02	0.02	0.02	0.02	0.03
12	0.02	0.02	0.02	0.01	0.01	0.01	0.02
13	0.01	0.01	0.02	0.02	0.01	0.03	0.05
14	0.01	0.02	0.01	0.01	0.01	0.01	0.02
15	0.01	0.02	0.02	0.01	0.03	0.01	0.04
16	0.01	0.01	0.01	0.01	0.01	0.01	0.02
17	0.01	0.01	0.01	0.01	0.01	0.01	0.02
18	0.01	0.01	0.01	0.01	0.01	0.01	0.06
19	0.01	0.01	0.01	0.02	0.01	0.01	0.04
20	0.01	0.01	0.01	0.01	0.01	0.01	0.02
21	0.01	0.01	0.01	0.01	0.01	0.01	0.02
22	0.01	0.01	0.01	0.01	0.01	0.01	0.03
23	0.01	0.01	0.02	0.01	0.01	0.01	0.02
24	0.01	0.01	0.01	0.01	0.01	0.01	0.02
25	0.01	0.01	0.01	0.01	0.01	0.01	0.02
26	0.02	0.01	0.01	0.01	0.01	0.01	0.02
27	0.02	0.01	0.01	0.02	0.01	0.01	0.02
28	0.01	0.01	0.01	0.01	0.01	0.01	0.02
29	0.01	0.01	0.01	0.01	0.01	0.01	0.03
30	0.01	0.01	0.02	0.01	0.01	0.01	0.03
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of turbidity readings \leq 0.3 NTU? Yes/No				CT's met everyday? All CL ₂ residuals at entry point \geq			
All turbidity readings < 1 NTU? Yes/No				(see back)			
All turbidity readings < IFE triggers? Yes/No				Yes/No 0.2mg/l?			
Notes:				Printed Name: <i>ANDY SEWELL</i>			
				Signature: <i>[Signature]</i>			Date: <i>2/4/25</i>
				Phone #: (503) 992-3259			CERT #: <i>9171</i>

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8PM" may not correspond to continuous readings' maximum.

² IFE - Individ. Filter Effl. (OAR 333-061-0040(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FOREST GROVE, CITY OF ID #: OR4100305 WTP-: WTP-A							Month / Year	Jan-25	Required Log Inactivation: 0.5
Date / Time	Minimum Cl ₂ Residual at 1st User(C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met ? ³	Maximum Reservoir Outflow	
	[ppm or mg/l]	minutes	C x T	[C]		Use tables	Yes / No	[GPM]	
1 / 8 am	0.73	272	198.4	9.90	6.54	24	YES	1906.00	
2 / 8 am	0.74	215	159.1	9.80	6.59	24	YES	2230.00	
3 / 8 am	0.74	231	170.9	9.20	6.53	24	YES	2061.00	
4 / 8 am	0.70	207	145.1	9.10	6.56	24	YES	2144.00	
5 / 8 am	0.72	201	145.0	9.90	6.69	24	YES	2451.00	
6 / 8 am	0.75	208	155.9	10.00	6.62	18	YES	2358.00	
7 / 8 am	0.75	182	136.5	9.90	6.63	24	YES	2634.00	
8 / 8 am	0.76	193	146.7	9.90	6.61	24	YES	2520.00	
9 / 8 am	0.77	198	152.1	9.80	6.64	24	YES	2657.00	
10 / 8 am	0.77	173	133.0	9.20	6.66	24	YES	2816.00	
11 / 8 am	0.77	227	174.9	9.10	6.73	24	YES	2265.00	
12 / 8 am	0.77	169	130.0	9.10	6.74	24	YES	2944.00	
13 / 8 am	0.82	195	160.1	9.00	6.77	25	YES	2527.00	
14 / 8 am	0.82	190	155.8	8.90	6.73	25	YES	2579.00	
15 / 8 am	0.82	187	153.7	8.20	6.70	25	YES	2465.00	
16 / 8 am	0.81	184	149.2	8.00	6.74	25	YES	2394.00	
17 / 8 am	0.82	164	134.5	8.00	6.73	25	YES	2987.00	
18 / 8 am	0.81	180	145.4	7.80	6.75	25	YES	2651.00	
19 / 8 am	0.81	237	192.3	7.50	6.76	25	YES	2123.00	
20 / 8 am	0.84	186	156.4	7.20	6.78	25	YES	2631.00	
21 / 8 am	0.80	171	137.1	7.00	6.80	25	YES	2777.00	
22 / 8 am	0.77	169	130.4	6.90	6.79	25	YES	2852.00	
23 / 8 am	0.76	179	135.9	6.90	6.76	24	YES	2702.00	
24 / 8 am	0.74	220	162.5	6.80	6.75	24	YES	2295.00	
25 / 8 am	0.73	178	129.9	7.00	6.80	24	YES	2655.00	
26 / 8 am	0.73	210	153.3	6.60	6.90	24	YES	2350.00	
27 / 8 am	0.72	173	124.3	6.10	6.83	24	YES	2880.00	
28 / 8 am	0.72	182	131.4	6.10	6.84	24	YES	2743.00	
29 / 8 am	0.73	179	130.6	6.00	6.87	24	YES	2934.00	
30 / 8 am	0.74	184	136.1	6.00	6.74	24	YES	2740.00	
31 / 8 am	0.74	320	236.8	6.00	6.76	24	YES	1619.00	

³ If Cl₂ at entry point <0.2 mg/l, OR CT not met, notify DWP by end of next business day.