

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
Conventional or Direct Filtration

System Name: FOREST GROVE, CITY OF			ID #: 4100305 WTP--WTP-A			Month/Year: Mar-25	
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the day ¹ (NTU)
1	0.01	0.02	0.01	0.01	0.01	0.01	0.02
2	0.01	0.01	0.01	0.01	0.01	0.01	0.02
3	0.01	0.01	0.01	0.01	0.01	0.01	0.02
4	0.01	0.01	0.01	0.01	0.01	0.01	0.06
5	0.01	0.01	0.01	0.01	0.01	0.01	0.02
6	0.01	0.01	0.01	0.01	0.01	0.01	0.02
7	0.02	0.01	0.01	0.02	0.01	0.01	0.05
8	0.01	0.01	0.01	0.01	0.01	0.02	0.05
9	0.01	0.01	0.01	0.01	0.01	0.01	0.02
10	0.01	0.01	0.01	0.01	0.01	0.01	0.03
11	0.01	0.01	0.01	0.01	0.01	0.01	0.02
12	0.02	0.01	0.01	0.01	0.01	0.01	0.02
13	0.01	0.01	0.01	0.01	0.01	0.01	0.02
14	0.01	0.01	0.02	0.02	0.01	0.01	0.02
15	0.01	0.01	0.01	0.05	0.02	0.02	0.05
16	0.02	0.02	0.02	0.01	0.02	0.01	0.03
17	0.01	0.01	0.02	0.02	0.02	0.02	0.03
18	0.01	0.02	0.02	0.01	0.02	0.01	0.02
19	0.02	0.01	0.02	0.01	0.01	0.02	0.04
20	0.02	0.02	0.01	0.02	0.02	0.02	0.02
21	0.01	0.02	0.01	0.02	0.02	0.02	0.03
22	0.02	0.02	0.02	0.01	0.02	0.02	0.03
23	0.02	0.02	0.02	0.02	0.01	0.01	0.02
24	0.02	0.01	0.02	0.01	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	0.01	0.01	0.02
26	0.01	0.01	0.01	0.01	0.01	0.02	0.02
27	0.01	0.02	0.02	0.02	0.02	0.02	0.02
28	0.01	0.01	0.01	0.02	0.03	0.02	0.03
29	0.01	0.02	0.01	0.02	0.02	0.02	0.02
30	0.02	0.01	0.02	0.02	0.02	0.02	0.02
31	0.01	0.01	0.02	0.02	0.02	0.02	0.03
Conventional or Direct Filtration 95% of turbidity readings $\leq$ 0.3 NTU? Yes / No All turbidity readings < 1 NTU? Yes / No All turbidity readings < IFE triggers? Yes / No ²				Monthly Summary (Answer Yes or No) CT's met everyday? Yes / No All CL ₂ residuals at entry point $\geq$ 0.2mg/l? Yes / No			
Notes:				Printed Name: ANDY SEWELL			
				Signature: <i>[Signature]</i>		Date:	
				Phone #: (503) 992-3269		CERT #: 9171	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8PM" may not correspond to continuous readings' maximum.

² IFE - Individ. Filter Effl. (OAR 333-061-0040(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FOREST GROVE, CITY OF ID #: OR4100305 WTP:- WTP-A								Month / Year	Mar-25	Required Log Inactivation: 0.5
Date / Time	Minimum Cl ₂ Residual at 1st User(C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met ? ³	Maximum Reservoir Outflow		
	[ppm or mg/l]	minutes	C x T	[C]		Use tables	Yes / No	[GPM]		
1 / 8 am	0.70	216	151.5	9.00	6.56	24	YES	2426.00		
2 / 8 am	0.69	188	129.9	9.00	6.60	24	YES	2639.00		
3 / 8 am	0.69	200	137.9	9.00	6.71	24	YES	2540.00		
4 / 8 am	0.69	182	125.3	9.00	6.49	20	YES	2678.00		
5 / 8 am	0.68	211	143.6	9.00	6.55	24	YES	2419.00		
6 / 8 am	0.68	165	112.4	9.00	6.71	24	YES	3008.00		
7 / 8 am	0.68	177	120.4	9.00	6.74	24	YES	2729.00		
8 / 8 am	0.67	220	147.5	8.90	6.64	24	YES	2241.00		
9 / 8 am	0.68	189	128.6	8.90	6.52	24	YES	2627.00		
10 / 8 am	0.68	212	144.1	9.00	6.81	24	YES	2379.00		
11 / 8 am	0.68	185	126.0	9.00	6.54	24	YES	2645.00		
12 / 8 am	0.68	205	139.4	9.00	6.51	24	YES	2407.00		
13 / 8 am	0.67	201	134.6	9.00	6.65	24	YES	2596.00		
14 / 8 am	0.65	187	121.3	8.90	6.62	24	YES	2719.00		
15 / 8 am	0.64	223	143.0	8.50	6.62	24	YES	2303.00		
16 / 8 am	0.63	211	133.1	8.30	6.53	24	YES	2336.00		
17 / 8 am	0.66	214	141.3	8.40	6.49	24	YES	2337.00		
18 / 8 am	0.68	198	134.8	8.20	6.57	24	YES	2595.00		
19 / 8 am	0.70	192	134.4	8.30	6.53	24	YES	2643.00		
20 / 8 am	0.70	232	162.3	8.80	6.68	24	YES	2174.00		
21 / 8 am	0.68	172	117.0	8.80	6.60	24	YES	2706.00		
22 / 8 am	0.69	224	154.2	8.90	6.71	24	YES	2255.00		
23 / 8 am	0.69	209	144.3	9.00	6.56	24	YES	2426.00		
24 / 8 am	0.70	189	132.6	9.10	6.64	24	YES	2660.00		
25 / 8 am	0.70	195	136.6	9.90	6.63	24	YES	2619.00		
26 / 8 am	0.71	175	124.4	10.10	6.52	18	YES	2797.00		
27 / 8 am	0.71	132	93.8	10.80	6.53	18	YES	3655.00		
28 / 8 am	0.71	214	151.9	10.60	6.82	18	YES	2340.00		
29 / 8 am	0.79	222	175.6	10.60	6.65	18	YES	2204.00		
30 / 8 am	0.76	159	120.8	10.50	6.82	18	YES	3258.00		
31 / 8 am	0.76	138	104.7	10.00	6.55	18	YES	3582.00		

³ If Cl₂ at entry point <0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf