

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington

Conventional or Direct Filtration

System Name: FOREST GROVE, CITY OF			ID #: 4100305 WTP:-WTP-A			Month/Year: Jun-25	
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the day ¹ (NTU)
1	0.02	0.01	0.02	0.01	0.01	0.01	0.02
2	0.01	0.01	0.01	0.01	0.01	0.01	0.02
3	0.01	0.01	0.02	0.01	0.02	0.02	0.02
4	0.01	0.01	0.01	0.03	0.02	off	0.06
5	off	off	off	off	off	off	0.06
6	off	off	off	off	off	off	off
7	off	off	off	0.03	0.02	0.02	0.03
8	0.01	0.01	0.01	0.02	0.01	0.01	0.02
9	0.01	0.01	0.01	0.01	0.01	0.01	0.02
10	0.01	0.01	0.02	0.01	0.01	0.01	0.02
11	0.01	0.01	0.01	0.01	0.01	0.01	0.02
12	0.01	0.02	0.01	0.01	0.01	0.01	0.02
13	0.01	0.01	0.01	0.02	0.01	0.01	0.03
14	0.01	0.01	0.01	0.01	0.01	0.01	0.02
15	0.01	0.01	0.02	0.01	0.01	0.01	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.02
17	0.01	0.01	0.01	0.01	0.01	0.01	0.02
18	0.01	0.01	0.01	0.01	0.02	0.01	0.02
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.03	0.02	0.02	0.03
21	0.01	0.01	0.01	0.01	0.01	0.01	0.02
22	0.01	0.01	0.02	0.01	0.01	0.01	0.02
23	0.01	0.01	0.01	0.01	0.01	0.02	0.03
24	0.02	0.02	0.01	0.01	0.01	0.01	0.03
25	0.01	0.01	0.01	0.01	0.01	0.02	0.02
26	0.02	0.02	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.02	0.02	0.01	0.02
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.02
30	0.02	0.02	0.01	0.01	0.01	0.01	0.02
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of turbidity readings $\leq$ 0.3 NTU? Yes / No				CT's met everyday? All CL ₂ residuals at entry point $\geq$ 0.2mg/l?			
All turbidity readings < 1 NTU? Yes / No				(see back) Yes / No			
All turbidity readings < IFE triggers? Yes / No²				Yes / No			
Notes:				Printed Name: ANDREW SEWALL			
				Signature: [Signature]		Date: 7/7/25	
				Phone #: (503) 992-3259		CERT #: 9, 71	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8PM" may not correspond to continuous readings' maximum.

² IFE - Individ. Filter Effl. (OAR 333-061-0040(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FOREST GROVE, CITY OF ID #: OR4100305 WTP:- WTP-A								Month / Year	Jun-25	Required Log Inactivation: 0.5
Date / Time	Minimum Cl ₂ Residual at 1st User(C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met ? ³	Maximum Reservoir Outflow		
	[ppm or mg/l]	minutes	C x T	[C]		Use tables	Yes / No	[GPM]		
1 / 8 am	0.73	149	108.7	13.80	7.28	22	YES	3173.00		
2 / 8 am	0.73	133	97.2	13.80	7.30	22	YES	3523.00		
3 / 8 am	0.73	140	102.0	12.90	7.21	22	YES	3307.00		
4 / 8 am	0.65	142	92.2	14.00	7.16	22	YES	3206.00		
5 / 8 am	0.64	256	164.0	14.00	7.19	22	YES	1789.00		
6 / 8 am	0.61	286	174.6	14.00	7.27	off	YES	1614.00		
7 / 8 am	0.66	172	113.7	14.10	7.21	22	YES	2743.00		
8 / 8 am	0.73	137	100.1	14.90	7.27	22	YES	3420.00		
9 / 8 am	0.73	135	98.6	15.00	7.22	15	YES	3575.00		
10 / 8 am	0.74	138	102.3	15.50	7.27	15	YES	3493.00		
11 / 8 am	0.75	124	92.8	15.80	7.31	15	YES	3705.00		
12 / 8 am	0.74	145	107.0	15.80	7.34	15	YES	3340.00		
13 / 8 am	0.74	134	99.2	15.20	7.35	15	YES	3447.00		
14 / 8 am	0.74	158	117.1	15.00	7.25	15	YES	2963.00		
15 / 8 am	0.79	148	116.7	14.80	7.34	22	YES	3292.00		
16 / 8 am	0.79	95	75.2	14.20	7.28	22	YES	5034.00		
17 / 8 am	0.79	140	110.5	14.40	7.27	22	YES	3378.00		
18 / 8 am	0.81	200	161.8	14.50	7.37	22	YES	2401.00		
19 / 8 am	0.84	180	150.8	14.90	7.34	22	YES	2749.00		
20 / 8 am	0.86	197	169.3	13.90	7.23	22	YES	2525.00		
21 / 8 am	0.87	249	216.4	14.50	7.31	22	YES	2012.00		
22 / 8 am	0.87	197	171.7	14.10	7.30	22	YES	2536.00		
23 / 8 am	0.87	199	173.4	14.00	7.27	22	YES	2476.00		
24 / 8 am	0.87	185	160.8	14.20	7.24	22	YES	2651.00		
25 / 8 am	0.87	177	153.7	14.90	7.28	22	YES	2753.00		
26 / 8 am	0.88	173	151.9	15.00	7.33	15	YES	2819.00		
27 / 8 am	0.88	187	164.5	15.00	7.27	15	YES	2622.00		
28 / 8 am	0.88	189	166.4	15.00	7.29	15	YES	2610.00		
29 / 8 am	0.87	195	170.0	15.00	7.22	15	YES	2544.00		
30 / 8 am	0.88	233	204.7	15.20	7.24	15	YES	2152.00		

³ If Cl₂ at entry point <0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf