

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington

Conventional or Direct Filtration

System Name: FOREST GROVE, CITY OF			ID #: 4100305 WTP:-WTP-A			Month/Year: Oct-25	
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the day ¹ (NTU)
1	0.02	0.02	0.02	0.02	0.02	0.01	0.02
2	0.01	0.01	0.01	0.01	0.02	0.02	0.03
3	0.01	0.01	0.01	0.01	0.01	0.02	0.02
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.03
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.02	0.02	0.02
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.02	0.02	0.02
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.02	0.02	0.02
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.02	0.02	0.02	0.03
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.02	0.01	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.02	0.02	0.02
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.02	0.02	0.03
20	0.02	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.03
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	off	off	0.01
25	off	off	off	off	Off	Off	Off
26	Off	Off	Off	Off	Off	Off	Off
27	Off	Off	Off	0.02	Off	Off	0.03
28	Off	Off	0.02	0.02	0.04	0.02	0.05
29	0.01	0.01	0.01	0.02	0.02	0.01	0.02
30	0.01	0.08	0.02	0.04	0.01	0.02	0.16
31	0.02	0.02	0.01	0.02	0.01	0.01	0.02

<u>Conventional or Direct Filtration</u> 95% of turbidity readings $\leq$ 0.3 NTU? Yes / No Yes All turbidity readings < 1 NTU? Yes / No Yes All turbidity readings < IFE triggers? Yes / No Yes Notes:	Monthly Summary (Answer Yes or No) CT's met everyday? Yes / No (see back) All CL₂ residuals at entry point $\geq$ 0.2mg/l? Yes / No Yes Printed Name: Andrew Sena Signature: [Signature] Date: 11/5/25 Phone #: (503) 992-3259 CERT #: 9171
--	---

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8PM" may not correspond to continuous readings' maximum.

² IFE - Individ. Filter Effl. (OAR 333-061-0040(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FOREST GROVE, CITY OF ID #: OR4100305 WTP-: WTP-A							Month / Year	Oct-25	Required Log Inactivation: 0.5
Date / Time	Minimum Cl ₂ Residual at 1st User(C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met ? ³	Maximum Reservoir Outflow	
	[ppm or mg/l]	minutes	C x T	[C]		Use tables	Yes / No	[GPM]	
1 / 8 am	0.79	171	135.3	16.00	7.41	15	YES	2758.00	
2 / 8 am	0.67	159	106.5	15.90	7.26	15	YES	2907.00	
3 / 8 am	0.76	156	118.7	16.00	7.20	15	YES	3069.00	
4 / 8 am	0.76	184	139.7	15.80	7.23	15	YES	2589.00	
5 / 8 am	0.76	229	174.4	15.20	7.17	15	YES	2166.00	
6 / 8 am	0.77	172	132.2	15.10	7.13	15	YES	2855.00	
7 / 8 am	0.83	179	148.6	15.00	7.20	15	YES	2717.00	
8 / 8 am	0.85	189	160.4	15.00	7.39	15	YES	2596.00	
9 / 8 am	0.86	156	134.6	15.00	7.19	15	YES	2975.00	
10 / 8 am	0.88	172	151.4	14.50	7.24	22	YES	2848.00	
11 / 8 am	0.88	194	170.9	14.20	7.27	22	YES	2523.00	
12 / 8 am	0.98	233	228.8	14.10	7.27	22	YES	2144.00	
13 / 8 am	0.97	178	173.1	14.00	7.28	22	YES	2746.00	
14 / 8 am	0.92	221	203.3	13.80	7.35	22	YES	2233.00	
15 / 8 am	0.91	168	152.9	13.50	7.23	22	YES	2853.00	
16 / 8 am	0.90	201	180.5	13.20	7.33	22	YES	2460.00	
17 / 8 am	0.90	179	161.2	13.10	7.35	22	YES	2717.00	
18 / 8 am	0.89	223	198.6	13.00	7.28	22	YES	2212.00	
19 / 8 am	0.87	207	180.0	13.00	7.37	22	YES	2368.00	
20 / 8 am	0.80	213	170.5	13.00	7.33	22	YES	2315.00	
21 / 8 am	0.79	167	131.9	12.90	7.26	22	YES	2808.00	
22 / 8 am	0.81	204	165.2	12.80	7.22	22	YES	2403.00	
23 / 8 am	0.76	183	139.0	12.80	7.20	22	YES	2584.00	
24 / 8 am	0.79	204	161.4	12.90	7.21	22	YES	2295.00	
25 / 8 am	0.71	191	135.5	14.00	7.08	off	YES	2495.00	
26 / 8 am	0.70	193	135.0	13.00	7.23	off	YES	2414.00	
27 / 8 am	0.73	177	129.0	13.10	7.31	22	YES	2635.00	
28 / 8 am	0.72	203	146.5	13.00	7.30	22	YES	2477.00	
29 / 8 am	0.77	180	138.6	13.00	7.19	22	YES	2742.00	
30 / 8 am	0.77	155	119.4	12.40	7.82	26	YES	3115.00	
31 / 8 am	0.78	199	155.4	12.00	7.10	22	YES	2494.00	

³ If Cl₂ at entry point <0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf