

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington  
Conventional or Direct Filtration**

System Name: FOREST GROVE, CITY OF			ID #: 4100305 WTP.:WTP-A			Month/Year: Dec-25	
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the day <sup>1</sup> (NTU)
1	0.02	0.02	0.02	0.01	0.02	0.02	0.02
2	0.02	0.02	0.02	0.02	0.02	0.01	0.02
3	0.01	0.02	0.02	0.02	0.02	0.01	0.02
4	0.02	0.01	0.02	0.02	0.02	0.01	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.03
6	0.02	0.02	0.02	0.02	0.03	0.02	0.07
7	0.03	0.02	0.02	0.02	0.02	0.02	0.05
8	0.02	0.01	0.04	Off	Off	Off	0.04
9	Off	Off	Off	Off	Off	Off	Off
10	Off	Off	Off	Off	Off	Off	Off
11	Off	Off	Off	Off	Off	Off	Off
12	Off	Off	Off	0.03	0.02	0.01	0.04
13	0.02	0.02	0.02	0.02	0.01	0.01	0.02
14	0.01	0.01	0.01	0.01	0.02	0.01	0.02
15	0.01	0.02	0.01	0.02	0.02	0.02	0.04
16	0.02	0.01	0.02	0.02	Off	Off	0.04
17	Off	Off	Off	Off	Off	Off	Off
18	Off	Off	Off	Off	Off	Off	Off
19	Off	Off	Off	Off	Off	Off	Off
20	Off	Off	Off	Off	Off	Off	Off
21	Off	Off	Off	0.01	0.01	0.01	0.02
22	Off	Off	Off	0.01	0.01	0.01	0.02
23	0.01	0.01	0.02	0.01	0.01	0.01	0.02
24	0.01	0.01	0.01	0.01	0.01	0.01	0.02
25	0.01	0.01	0.01	0.01	0.01	0.01	0.02
26	0.01	0.01	0.01	0.01	0.01	0.01	0.02
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.02	0.02
29	0.01	0.01	0.01	0.01	0.01	0.01	0.02
30	0.01	0.01	0.01	0.02	0.01	0.01	0.02
31	0.01	0.01	0.01	0.01	0.01	0.01	0.02
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of turbidity readings $\leq$ 0.3 NTU? <b>Yes</b> / No				CT's met everyday? All CL <sub>2</sub> residuals at entry point $\geq$ 0.2mg/l? <b>Yes</b> / No			
All turbidity readings < 1 NTU? <b>Yes</b> / No				(see back) <b>Yes</b> / No			
All turbidity readings < IFE triggers? <b>Yes</b> / No <sup>2</sup>							
Notes:				Printed Name: <b>Andrew Sewall</b>			
				Signature: <b>[Signature]</b>			Date: <b>1/6/26</b>
				Phone #: (503) 992-3259			CERT #: <b>9171</b>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE - Individ. Filter Eff. (OAR 333-061-0040(e)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

FOREST GROVE, CITY OF ID #: OR4100305 WTP:- WTP-A							Month / Year	Dec-25	Required Log Inactivation: 0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met ? <sup>3</sup>	Maximum Reservoir Outflow	
	[ppm or mg/l]	minutes	C x T	[ C ]		Use tables	Yes / No	[GPM]	
1 / 8 am	0.89	203	180.4	10.10	6.90	19	YES	2486.00	
2 / 8 am	0.88	192	169.0	10.00	6.81	19	YES	2643.00	
3 / 8 am	0.87	180	156.7	9.90	6.96	25	YES	2642.00	
4 / 8 am	0.93	179	166.3	9.90	6.88	25	YES	2818.00	
5 / 8 am	0.87	183	159.1	9.80	6.80	25	YES	2641.00	
6 / 8 am	0.85	224	190.6	10.00	6.76	19	YES	2372.00	
7 / 8 am	0.83	168	139.7	10.00	6.80	19	YES	2829.00	
8 / 8 am	0.77	188	144.6	10.20	6.79	18	YES	2591.00	
9 / 8 am	0.74	598	442.8	10.50	6.64	off	YES	854.00	
10 / 8 am	0.70	197	138.2	10.70	6.69	off	YES	2447.00	
11 / 8 am	0.68	231	157.2	10.80	6.73	off	YES	2119.00	
12 / 8 am	0.68	181	123.4	11.00	6.69	18	YES	2662.00	
13 / 8 am	0.77	216	166.2	11.10	6.71	18	YES	2287.00	
14 / 8 am	0.77	183	141.2	11.00	6.72	18	YES	2595.00	
15 / 8 am	0.77	170	130.8	10.80	6.72	18	YES	2864.00	
16 / 8 am	0.71	183	130.2	11.20	6.69	18	YES	2672.00	
17 / 8 am	0.71	247	175.7	11.30	6.76	off	YES	1952.00	
18 / 8 am	0.75	222	166.8	11.30	6.65	off	YES	2109.00	
19 / 8 am	0.77	178	136.8	11.30	6.70	off	YES	2680.00	
20 / 8 am	0.79	218	171.9	11.20	6.78	off	YES	2204.00	
21 / 8 am	0.79	191	151.1	11.80	7.39	22	YES	2562.00	
22 / 8 am	0.83	233	193.5	11.80	7.40	22	YES	2207.00	
23 / 8 am	0.85	216	183.9	11.00	6.94	19	YES	2362.00	
24 / 8 am	0.87	164	143.1	10.90	6.83	19	YES	3128.00	
25 / 8 am	0.89	264	234.8	10.90	6.82	19	YES	1937.00	
26 / 8 am	0.90	219	197.2	10.80	6.74	19	YES	2332.00	
27 / 8 am	0.86	256	219.8	10.20	6.90	19	YES	2013.00	
28 / 8 am	0.85	213	180.9	10.00	6.90	19	YES	2319.00	
29 / 8 am	0.78	238	185.9	9.90	6.92	24	YES	2129.00	
30 / 8 am	0.72	180	129.6	9.50	6.94	24	YES	2605.00	
31 / 8 am	0.68	228	155.1	9.00	6.84	24	YES	2195.00	

<sup>3</sup> If Cl<sub>2</sub> at entry point <0.2 mg/l, OR CT not met, notify DWP by end of next business day.