

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
Conventional or Direct Filtration**

System Name: FOREST GROVE, CITY OF		ID #: 4100305 WTP--WTP-A			Month/Year:		Jan-26
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the day ¹ (NTU)
1	0.01	0.01	0.01	0.01	0.01	0.01	0.02
2	0.01	0.01	0.01	0.01	0.01	0.01	0.02
3	0.01	0.01	0.01	0.01	0.01	0.01	0.02
4	0.01	0.01	0.01	0.01	0.01	0.02	0.02
5	0.01	0.01	0.01	0.01	0.01	0.05	0.09
6	0.01	0.01	0.01	0.01	0.01	Off	0.02
7	Off	Off	0.02	0.01	0.01	0.01	0.03
8	0.02	0.01	0.02	0.01	0.01	0.01	0.02
9	0.01	0.01	0.01	0.02	0.01	0.01	0.02
10	0.01	0.01	0.01	0.01	0.01	0.01	0.02
11	0.02	0.01	0.01	0.01	0.01	0.01	0.02
12	0.01	0.01	0.01	0.01	0.01	0.01	0.02
13	0.01	0.01	0.01	0.01	0.01	0.01	0.02
14	0.01	0.01	0.01	0.01	0.01	0.01	0.02
15	0.01	0.01	0.01	0.01	0.01	0.01	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.02
17	0.01	0.01	0.01	0.01	0.01	0.04	0.06
18	0.01	0.01	0.01	0.01	0.01	0.01	0.02
19	0.02	0.01	0.01	0.01	0.06	0.01	0.11
20	0.01	0.01	0.01	0.01	0.01	0.01	0.04
21	0.01	0.01	0.01	0.01	0.01	0.01	0.06
22	0.05	0.03	0.01	0.01	0.01	0.01	0.09
23	0.01	0.01	0.01	0.03	0.01	0.01	0.04
24	0.01	0.01	0.02	0.02	0.01	0.01	0.11
25	0.01	0.01	0.01	0.01	0.01	0.01	0.02
26	0.02	0.01	0.01	0.01	0.01	0.01	0.04
27	0.01	0.01	0.01	0.01	0.01	0.01	0.03
28	0.01	0.01	0.02	0.02	0.02	0.02	0.03
29	0.01	0.02	0.01	0.01	0.01	0.02	0.02
30	0.01	0.01	0.02	0.01	0.01	0.01	0.02
31	0.01	0.01	0.01	0.01	0.02	0.02	0.05
<input checked="" type="radio"/> Conventional or <input type="radio"/> Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No				CT's met everyday? <input type="radio"/> Yes <input type="radio"/> No			
All turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No				All CL ₂ residuals at entry point \geq 0.2mg/l? <input type="radio"/> Yes <input type="radio"/> No			
All turbidity readings < IFE triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No ²				(see back) <input checked="" type="radio"/> Yes <input type="radio"/> No			
Notes:				Printed Name: <i>ANDREW SEWALL</i>			
				Signature: <i>[Signature]</i>			Date: 2/6/26
				Phone #: (503) 992-3259			CERT #: 9171

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8PM" may not correspond to continuous readings' maximum.

² IFE - Individ. Filter Effl. (OAR 333-061-0040(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FOREST GROVE, CITY OF ID #: OR4100305 WTP:- WTP-A							Month / Year	Jan-26	Required Log Inactivation: 0.5
Date / Time	Minimum Cl ₂ Residual at 1st User(C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met ? ³	Maximum Reservoir Outflow	
	[ppm or mg/l]	minutes	C x T	[C]		Use tables	Yes / No	[GPM]	
1 / 8 am	0.66	221	145.8	9.00	6.87	24	YES	2187.00	
2 / 8 am	0.66	225	148.8	8.90	6.92	24	YES	2158.00	
3 / 8 am	0.64	224	143.3	9.00	6.90	24	YES	2157.00	
4 / 8 am	0.61	211	128.8	9.10	6.96	24	YES	2304.00	
5 / 8 am	0.61	193	117.5	9.10	6.87	24	YES	2580.00	
6 / 8 am	0.62	188	116.6	9.10	6.84	24	YES	2586.00	
7 / 8 am	0.65	196	127.3	9.10	6.80	24	YES	2501.00	
8 / 8 am	0.69	173	119.6	9.00	6.79	24	YES	2746.00	
9 / 8 am	0.69	231	159.1	9.00	6.75	24	YES	2201.00	
10 / 8 am	0.70	200	140.2	9.10	6.91	24	YES	2499.00	
11 / 8 am	0.71	219	155.6	9.00	6.86	24	YES	2331.00	
12 / 8 am	0.71	194	137.7	9.10	6.80	24	YES	2490.00	
13 / 8 am	0.72	194	139.7	9.20	6.85	24	YES	2399.00	
14 / 8 am	0.74	214	158.2	9.10	6.94	24	YES	2325.00	
15 / 8 am	0.73	175	127.9	9.10	6.91	24	YES	2757.00	
16 / 8 am	0.72	210	151.5	9.10	6.88	24	YES	2378.00	
17 / 8 am	0.72	225	161.8	9.10	6.86	24	YES	2211.00	
18 / 8 am	0.72	230	165.9	9.00	6.95	24	YES	2172.00	
19 / 8 am	0.74	179	132.7	8.80	6.94	24	YES	2752.00	
20 / 8 am	0.74	201	148.8	8.10	6.89	24	YES	2385.00	
21 / 8 am	0.72	164	117.9	8.00	6.89	24	YES	3057.00	
22 / 8 am	0.70	163	114.2	7.40	6.94	24	YES	2960.00	
23 / 8 am	0.69	205	141.2	7.20	6.95	24	YES	2463.00	
24 / 8 am	0.68	182	123.6	7.10	6.99	24	YES	2793.00	
25 / 8 am	0.68	222	150.9	7.00	6.88	24	YES	2335.00	
26 / 8 am	0.72	171	122.9	6.80	6.93	24	YES	2892.00	
27 / 8 am	0.72	199	143.6	6.80	7.03	29	YES	2510.00	
28 / 8 am	0.70	160	111.8	7.10	7.14	29	YES	3067.00	
29 / 8 am	0.67	173	116.1	7.20	6.92	24	YES	2746.00	
30 / 8 am	0.65	187	121.7	7.90	6.81	24	YES	2579.00	
31 / 8 am	0.64	165	105.4	8.10	6.88	24	YES	2891.00	

³ If Cl₂ at entry point <0.2 mg/l, OR CT not met, notify DWP by end of next business day.