

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington

Conventional or Direct Filtration

| System Name: FOREST GROVE, CITY OF | | ID #: 4100305 WTP--WTP-A | | | Month/Year: | | Mar-26 |
|---|-------------|--------------------------|------------|---|-------------|------------|---|
| Day | 12 AM (NTU) | 4 AM (NTU) | 8 AM (NTU) | NOON (NTU) | 4 PM (NTU) | 8 PM (NTU) | Highest Reading of the day ¹ (NTU) |
| 1 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 | 0.04 |
| 2 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 3 | 0.01 | 0.01 | 0.01 | 0.02 | 0.01 | 0.01 | 0.02 |
| 4 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 5 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 |
| 6 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 7 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 |
| 8 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 |
| 9 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 10 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 11 | 0.01 | 0.02 | 0.01 | 0.02 | Off | Off | 0.02 |
| 12 | Off | Off | Off | Off | Off | Off | off |
| 13 | Off | Off | Off | 0.02 | Off | Off | 0.02 |
| 14 | Off | Off | 0.02 | Off | Off | Off | 0.05 |
| 15 | Off | Off | Off | Off | Off | Off | Off |
| 16 | Off | Off | Off | Off | Off | Off | Off |
| 17 | Off | Off | Off | Off | 0.03 | 0.02 | 0.03 |
| 18 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 19 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 20 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 21 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.04 | 0.04 |
| 22 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 23 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 24 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 25 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.08 |
| 26 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 | 0.04 |
| 27 | 0.01 | 0.01 | 0.02 | 0.01 | 0.01 | 0.01 | 0.02 |
| 28 | 0.01 | 0.01 | 0.01 | 0.01 | 0.03 | 0.02 | 0.10 |
| 29 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 30 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| 31 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 |
| Conventional or <input checked="" type="radio"/> Direct Filtration | | | | Monthly Summary (Answer Yes or No) | | | |
| 95% of turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No | | | | CT's met everyday? All CL ₂ residuals at entry point \geq 0.2mg/l? | | | |
| All turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes / No | | | | (see back) <input checked="" type="radio"/> Yes / No | | | |
| All turbidity readings < IFE triggers? <input checked="" type="radio"/> Yes / No ² | | | | <input checked="" type="radio"/> Yes / No | | | |
| Notes: | | | | Printed Name: Andrew Small | | | |
| | | | | Signature: <i>Andrew Small</i> | | | Date: 4/3/26 |
| | | | | Phone #: (503) 992-3259 | | | CERT #: 9171 |

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8PM" may not correspond to continuous readings' maximum.

² IFE - Individ. Filter Effl. (OAR 333-061-0040(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

| FOREST GROVE, CITY OF ID #: OR4100305 WTP:- WTP-A | | | | | | | Month / Year | Mar-26 | Required Log Inactivation: 0.5 |
|---|---|--------------------|-----------|-------|------|-------------|-----------------------|---------------------------|-----------------------------------|
| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met ? ³ | Maximum Reservoir Outflow | |
| | [ppm or mg/l] | minutes | C x T | [C] | | Use tables | Yes / No | [GPM] | |
| 1 / 8 am | 0.73 | 236 | 172.4 | 8.50 | 6.83 | 24 | YES | 2223.00 | |
| 2 / 8 am | 0.67 | 176 | 117.7 | 8.90 | 6.79 | 24 | YES | 2969.00 | |
| 3 / 8 am | 0.71 | 170 | 120.8 | 9.00 | 6.73 | 24 | YES | 3023.00 | |
| 4 / 8 am | 0.72 | 186 | 134.2 | 9.20 | 6.89 | 24 | YES | 2779.00 | |
| 5 / 8 am | 0.72 | 193 | 139.0 | 9.70 | 6.84 | 24 | YES | 2702.00 | |
| 6 / 8 am | 0.72 | 167 | 120.0 | 9.40 | 6.86 | 24 | YES | 2962.00 | |
| 7 / 8 am | 0.72 | 218 | 156.8 | 9.50 | 6.79 | 24 | YES | 2427.00 | |
| 8 / 8 am | 0.71 | 194 | 137.6 | 9.80 | 6.96 | 24 | YES | 2583.00 | |
| 9 / 8 am | 0.69 | 210 | 144.9 | 9.90 | 6.92 | 24 | YES | 2450.00 | |
| 10 / 8 am | 0.71 | 186 | 131.8 | 9.20 | 6.87 | 24 | YES | 2752.00 | |
| 11 / 8 am | 0.66 | 173 | 114.3 | 9.00 | 6.89 | 24 | YES | 2909.00 | |
| 12 / 8 am | 0.64 | 203 | 129.6 | 9.10 | 6.94 | Off | YES | 2385.00 | |
| 13 / 8 am | 0.63 | 244 | 154.0 | 9.10 | 6.88 | 24 | YES | 2048.00 | |
| 14 / 8 am | 0.63 | 220 | 138.6 | 9.20 | 6.93 | 24 | YES | 2227.00 | |
| 15 / 8 am | 0.69 | 185 | 127.9 | 9.80 | 7.12 | Off | YES | 2512.00 | |
| 16 / 8 am | 0.71 | 209 | 148.3 | 10.30 | 7.52 | Off | YES | 2429.00 | |
| 17 / 8 am | 0.71 | 187 | 132.6 | 10.00 | 7.01 | 22 | YES | 2717.00 | |
| 18 / 8 am | 0.72 | 202 | 145.6 | 10.00 | 6.91 | 18 | YES | 2579.00 | |
| 19 / 8 am | 0.72 | 180 | 129.9 | 10.20 | 7.43 | 22 | YES | 2794.00 | |
| 20 / 8 am | 0.72 | 210 | 150.9 | 10.80 | 6.76 | 18 | YES | 2471.00 | |
| 21 / 8 am | 0.72 | 200 | 144.1 | 10.90 | 6.83 | 18 | YES | 2571.00 | |
| 22 / 8 am | 0.74 | 243 | 179.5 | 10.40 | 6.81 | 18 | YES | 2136.00 | |
| 23 / 8 am | 0.74 | 116 | 85.7 | 10.10 | 6.93 | 18 | YES | 4169.00 | |
| 24 / 8 am | 0.72 | 123 | 88.7 | 10.10 | 6.93 | 18 | YES | 3779.00 | |
| 25 / 8 am | 0.72 | 143 | 103.0 | 10.10 | 6.95 | 18 | YES | 3498.00 | |
| 26 / 8 am | 0.70 | 142 | 99.5 | 10.00 | 6.97 | 18 | YES | 3618.00 | |
| 27 / 8 am | 0.69 | 187 | 128.7 | 9.90 | 6.95 | 24 | YES | 2702.00 | |
| 28 / 8 am | 0.69 | 207 | 143.2 | 9.90 | 6.96 | 24 | YES | 2446.00 | |
| 29 / 8 am | 0.69 | 143 | 98.6 | 10.00 | 6.89 | 18 | YES | 3601.00 | |
| 30 / 8 am | 0.69 | 126 | 86.7 | 10.00 | 6.84 | 18 | YES | 3846.00 | |
| 31 / 8 am | 0.73 | 126 | 92.3 | 9.90 | 6.90 | 24 | YES | 3709.00 | |

³ If Cl₂ at entry point <0.2 mg/l, OR CT not met, notify DWP by end of next business day.