

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Marion**  
 Month/Year: **November 2021**

System Name: **Gates, City of** ID#: **41 00317** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1							Plant Off
2							Plant Off
3				0.04			0.04
4							Plant Off
5							Plant Off
6				0.03			0.03
7							Plant Off
8							Plant Off
9					0.03		0.03
10							Plant Off
11							Plant Off
12					0.03		0.03
13							Plant Off
14							Plant Off
15				0.03			0.03
16							Plant Off
17							Plant Off
18				0.03			0.03
19							Plant Off
20							Plant Off
21				0.03			0.03
22							Plant Off
23							Plant Off
24			0.03				0.03
25							Plant Off
26							Plant Off
27							Plant Off
28							Plant Off
29				0.03			0.03
30				0.03			0.03
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: <b>Gregory R Benthin</b>	
	SIGNATURE: <i>Gregory R Benthin</i>	DATE: <b>12/3/21</b>
	PHONE #: <b>(503) 897-2669</b>	CERT #: <b>5244</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Gates, City of ID#: 41 00317 Month/Year: 21-Nov Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1								Plant Off
2								Plant Off
3	0.77	120	92.4	14.2	7.93	19.7	Yes	210
4								Plant Off
5								Plant Off
6/12:30 pm	0.53	120	63.6	13.6	8.10	21.3	Yes	210
7								Plant Off
8								Plant Off
9/4:15 pm	0.86	120	103.2	13.9	7.89	20.0	Yes	210
10								Plant Off
11								Plant Off
12	0.89	120	106.8	11.0	7.73	23.0	Yes	210
13								Plant Off
14								Plant Off
15	0.93	120	111.6	13.9	7.68	18.7	Yes	210
16								Plant Off
17								Plant Off
18	1.42	120	170.4	13.6	7.82	21.2	Yes	210
19								Plant Off
20								Plant Off
21	0.89	120	106.8	13.0	7.91	21.5	Yes	210
22								Plant Off
23								Plant Off
24	0.92	120	110.4	13.4	7.96	21.4	Yes	210
25								Plant Off
26								Plant Off
27								Plant Off
28								Plant Off
29/9:55 pm	1.63	120	195.6	13.4	7.75	21.5	Yes	210
30/10:45 am	1.24	120	148.8	13.4	7.75	20.5	Yes	210
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.