


OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Douglas**
 Month/Year: **Jun-22**

Conventional or Direct Filtration

System Name:	City of Glendale		ID#4100323				WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.03	0.03	0.04	0.02	off	0.03	0.04	
2	0.03	off	0.03	0.04	0.05	off	0.05	
3	off	off	0.03	0.03	0.03	0.03	0.03	
4	0.03	off	0.04	0.03	off	off	0.04	
5	off	off	0.03	0.03	0.03	0.03	0.03	
6	0.04	off	0.03	0.04	off	off	0.04	
7	0.03	off	0.04	0.03	off	off	0.04	
8	0.03	0.04	off	0.03	0.03	0.03	0.04	
9	off	off	0.04	0.02	0.03	0.03	0.04	
10	off	off	0.02	0.02	0.03	0.03	0.03	
11	off	off	0.03	0.03	0.03	off	0.03	
12	off	off	0.03	0.03	0.02	0.03	0.03	
13	0.03	off	0.03	0.03	off	0.03	0.03	
14	0.03	off	0.03	0.03	off	0.03	0.03	
15	off	off	0.03	0.04	0.03	0.03	0.04	
16	off	off	0.04	0.04	0.03	0.03	0.04	
17	off	off	0.04	0.03	0.03	0.03	0.04	
18	0.03	off	0.03	0.04	off	off	0.04	
19	off	off	0.03	0.04	0.03	0.03	0.04	
20	0.06	off	off	0.06	0.03	0.03	0.06	
21	0.03	off	0.04	0.03	0.03	0.03	0.04	
22	off	off	0.04	0.03	0.03	0.03	0.04	
23	off	off	0.04	0.04	0.03	0.03	0.04	
24	off	off	0.04	0.03	0.04	0.03	0.04	
25	off	off	0.04	0.03	0.03	0.04	0.04	
26	off	off	0.03	0.04	0.03	0.04	0.04	
27	0.04	off	0.03	0.03	0.03	off	0.04	
28	off	off	0.04	0.04	0.03	0.04	0.04	
29	0.04	off	0.03	0.04	0.03	off	0.04	
30	0.04	off	0.03	0.03	0.04	off	0.04	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: SEAN NECHERBOW	
	SIGNATURE: 	DATE: 7/4/22
	PHONE #: (541) 863-1453	CERT #: 6111

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	City of Glendale	ID#4100323	Month/Year:	Jun-22	WTP - : Disinfection Giardia Log Inactiv:	A 0.5
--------------	------------------	------------	-------------	--------	--	--------------

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	12:02	1.10	1100	1210.0	15.0	7.80	18.5	YES
2	9:23	0.86	1100	946.0	15.00	7.70	17.4	YES
3	11:56	1.06	1100	1166.0	15.00	7.90	19.1	YES
4	11:53	1.09	1100	1199.0	15.00	7.60	17.2	YES
5	8:59	0.97	1100	1067.0	14.0	7.80	19.5	YES
6	9:27	0.92	1100	1012.0	15.0	7.80	18.1	YES
7	11:42	0.92	1100	1012.0	15.0	7.70	17.5	YES
8	13:05	0.99	1100	1089.0	15.0	7.80	18.3	YES
9	15:55	0.82	1100	902.0	15.0	7.90	18.6	YES
10	9:25	0.87	1100	957.0	16.0	7.80	16.9	YES
11	8:55	0.93	1100	1023.0	17.0	7.70	15.3	YES
12	9:02	0.75	1100	825.0	17.0	7.60	14.5	YES
13	9:47	0.54	1100	594.0	15.0	7.70	16.8	YES
14	15:45	0.80	1100	880.0	14.0	7.80	19.1	YES
15	9:28	0.87	1100	957.0	15.0	7.70	17.4	YES
16	9:44	0.86	1100	946.0	15.0	7.80	18.0	YES
17	9:41	0.97	1100	1067.0	15.0	7.90	18.9	YES
18	12:04	0.60	1100	660.0	14.0	7.80	18.7	YES
19	12:15	0.75	1100	825.0	14.0	8.00	20.5	YES
20	12:17	0.73	1100	803.0	15.00	7.80	17.8	YES
21	10:05	0.59	1100	649.0	16.00	8.00	17.6	YES
22	9:30	0.73	1100	803.0	17.00	7.80	15.5	YES
23	11:48	0.42	1100	462.0	18.0	7.80	14.0	YES
24	9:22	0.95	1100	1045.0	17.0	7.70	15.4	YES
25	9:15	0.93	1100	1023.0	18.0	7.70	14.3	YES
26	9:38	1.06	1100	1166.0	19.0	7.70	13.6	YES
27	9:28	0.91	1100	1001.0	19.0	7.70	13.4	YES
28	9:24	0.83	1100	913.0	19.0	7.60	12.8	YES
29	9:46	0.71	1100	781.0	18.0	7.50	13.0	YES
30	9:37	0.73	1100	803.0	18.0	7.50	13.0	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.