

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: May-23

System Name:	City of Glendale		ID#4100323				WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	off	off	0.06	0.06	0.06	0.03	0.06	
2	0.03	0.03	0.04	0.03	off	off	0.04	
3	0.03	0.03	0.04	off	0.05	0.03	0.05	
4	0.03	off	0.05	0.05	0.04	0.03	0.05	
5	off	off	0.05	0.05	0.06	0.03	0.06	
6	0.03	off	off	off	off	off	0.03	
7	off	off	0.06	0.05	0.03	off	0.06	
8	off	off	0.04	0.04	0.05	0.04	0.05	
9	off	off	0.04	0.03	0.04	0.03	0.04	
10	0.05	0.04	0.03	0.05	0.04	0.03	0.05	
11	0.03	0.03	0.04	off	0.04	off	0.04	
12	off	off	0.04	0.04	0.03	0.03	0.04	
13	off	off	0.03	0.04	0.03	0.03	0.03	
14	0.03	off	0.04	0.03	0.05	0.03	0.03	
15	off	off	0.05	0.05	0.04	off	0.14	
16	off	off	0.05	0.08	0.04	0.03	0.05	
17	0.03	off	0.05	0.05	off	off	0.05	
18	0.03	0.03	off	0.05	0.06	off	0.06	
19	off	off	0.04	0.05	0.05	0.03	0.05	
20	0.03	off	0.04	0.04	off	off	0.04	
21	off	off	0.03	0.04	0.07	0.03	0.07	
22	0.03	off	0.05	0.05	off	off	0.05	
23	0.04	0.03	0.04	0.04	off	0.03	0.04	
24	0.03	off	off	0.04	0.04	0.03	0.06	
25	off	off	0.04	0.06	0.05	0.03	0.05	
26	off	off	0.04	0.05	0.04	off	0.05	
27	off	off	0.04	0.05	0.04	0.03	0.04	
28	0.03	off	0.05	0.04	0.05	off	0.05	
29	off	off	0.05	0.05	0.05	0.03	0.05	
30	0.03	off	0.05	0.05	0.05	off	0.05	
31	off	off	0.05	0.04	0.04	0.03	0.05	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE <sup>2</sup> triggers	Yes / No		

Notes:

PRINTED NAME: SEAN NEGERBAJ  
 SIGNATURE: *S. Negerbaj*  
 PHONE #: (541) 963 1453  
 DATE: 6/7/23  
 CERT #: 6111

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	City of Glendale	ID#4100323	Month/Year:	May-23	Disinfection Giardia Log Inactiv:	0.5
--------------	------------------	------------	-------------	--------	---	-----

Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	9:20	0.77	1100	847.0	13.0	7.90	21.1	YES
2	9:26	1.01	1100	1111.0	12.00	7.70	21.6	YES
3	15:50	1.11	1100	1221.0	12.00	7.70	21.9	YES
4	8:55	1.14	1100	1254.0	12.00	7.70	22.0	YES
5	15:53	0.96	1100	1056.0	12.0	7.80	22.3	YES
6	-	OFF	1100	#VALUE!	OFF	OFF	#VALUE!	#VALUE!
7	10:22	0.86	1100	946.0	12.0	7.80	22.0	YES
8	10:42	0.89	1100	979.0	12.0	7.90	22.9	YES
9	10:30	0.96	1100	1056.0	12.0	7.90	23.1	YES
10	15:53	0.69	1100	759.0	12.0	7.60	20.2	YES
11	15:55	0.60	1100	660.0	13.0	7.80	20.0	YES
12	11:27	0.91	1100	1001.0	14.0	8.10	21.6	YES
13	9:55	1.04	1100	1144.0	15.0	7.90	19.1	YES
14	12:17	0.72	1100	792.0	15.0	8.00	19.1	YES
15	15:40	0.73	1100	803.0	17.0	7.60	14.4	YES
16	12:17	0.63	1100	693.0	16.0	7.90	17.1	YES
17	9:07	1.07	1100	1177.0	17.0	7.70	15.6	YES
18	12:00	0.85	1100	935.0	17.0	7.70	15.2	YES
19	16:00	0.90	1100	990.0	16.0	7.70	16.3	YES
20	09:44	0.85	1100	935.0	17.00	7.70	15.2	YES
21	09:10	0.60	1100	660.0	17.00	7.80	15.3	YES
22	12:00	0.73	1100	803.0	17.00	7.70	15.0	YES
23	08:48	0.83	1100	913.0	15.0	7.60	16.7	YES
24	11:33	0.78	1100	858.0	16.0	7.60	15.5	YES
25	09:115	0.62	1100	682.0	16.0	8.10	18.3	YES
26	11:45	0.64	1100	704.0	16.0	8.10	18.4	YES
27	9:45	1.02	1100	1122.0	16.0	8.00	18.5	YES
28	8:58	0.78	1100	858.0	17.0	7.90	16.2	YES
29	12:09	0.74	1100	814.0	17.0	8.00	16.8	YES
30	15:45	0.72	1100	792.0	17.0	7.80	15.5	YES
31	15:45	0.66	1100	726.0	17.0	7.90	16.0	YES

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012