


OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Douglas**
 Month/Year: **Jul-23**

Conventional or Direct Filtration

WTP : TP - **A**

System Name:	City of Glendale			id# 4100323			Highest Reading of the Day ¹ [NTU]
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	
1	0.03	0.03	off	0.04	0.04	0.04	0.04
2	off	off	0.05	0.04	0.04	0.06	0.06
3	off	off	0.04	0.04	0.04	0.03	0.04
4	off	off	0.05	0.05	0.06	0.04	0.06
5	off	off	0.05	0.06	0.05	0.04	0.06
6	0.03	off	0.05	0.05	0.05	0.04	0.05
7	0.03	off	0.05	0.07	0.05	0.04	0.07
8	off	off	0.05	0.05	0.04	0.04	0.05
9	0.03	off	0.04	0.05	0.05	0.03	0.05
10	off	off	0.06	0.05	0.06	0.05	0.06
11	0.04	off	0.05	0.05	0.06	off	0.06
12	0.04	off	off	0.05	0.06	0.04	0.06
13	0.04	off	0.04	0.06	0.05	0.04	0.06
14	off	off	0.05	0.05	0.05	0.05	0.05
15	0.04	0.04	0.04	0.04	0.05	off	0.05
16	off	off	0.05	0.06	0.06	0.05	0.06
17	0.04	0.03	0.05	0.04	off	0.05	0.05
18	0.05	0.04	0.05	0.05	0.06	0.03	0.06
19	off	off	0.04	0.06	0.04	0.06	0.06
20	0.04	off	0.05	0.06	0.04	off	0.06
21	off	off	0.06	0.05	0.05	0.04	0.06
22	0.04	0.04	0.06	0.05	off	0.05	0.06
23	0.04	off	0.04	0.05	0.04	0.04	0.05
24	off	off	0.04	0.04	0.05	0.04	0.05
25	0.03	0.03	0.05	0.04	0.07	off	0.07
26	off	off	0.05	0.05	0.05	0.04	0.05
27	0.05	0.04	0.05	0.03	0	0.04	0.05
28	0.04	off	0.05	0.06	0.04	off	0.06
29	0.05	off	0.04	0.04	0.05	off	0.05
30	0.04	off	0.05	0.04	0.05	0.04	0.05
31	off	off	off	0.06	0.07	0.04	0.07

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: SEAN NEGERBON		
	SIGNATURE: 		DATE: 8/7/23
	PHONE #: (541) 863-1453		CERT #: 611

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	City of Glendale	id# 4100323	Month/Year:	Jul-23	WTP - : Disinfection Giardia Log Inactiv:	A 0.5
--------------	------------------	-------------	-------------	--------	--	----------

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³
		[ppm or mg/L]	[minutes]	C X T	[° C]	formula	Yes / No	
1	12:30	0.99	1100	1089.0	20.0	7.40	11.3	YES
2	15:39	0.81	1100	891.0	20.00	7.80	12.8	YES
3	9:33	0.76	1100	836.0	20.00	7.70	12.3	YES
4	8:45	0.75	1100	825.0	20.00	7.60	11.8	YES
5	12:12	0.77	1100	847.0	20.0	7.70	12.3	YES
6	10:00	0.77	1100	847.0	20.0	7.60	11.9	YES
7	9:07	0.64	1100	704.0	20.0	7.70	12.1	YES
8	12:26	0.52	1100	572.0	20.0	7.70	12.0	YES
9	9:45	0.78	1100	858.0	20.0	7.70	12.3	YES
10	9:10	0.46	1100	506.0	20.0	7.70	11.9	YES
11	12:20	0.71	1100	781.0	19.0	7.60	12.6	YES
12	15:25	0.82	1100	902.0	20.0	7.60	11.9	YES
13	8:40	0.51	1100	561.0	20.0	7.80	12.4	YES
14	9:40	0.69	1100	759.0	21.0	8.00	12.8	YES
15	9:57	0.89	1100	979.0	20.0	7.80	13.0	YES
16	12:15	0.80	1100	880.0	20.0	8.00	13.8	YES
17	12:08	0.80	1100	880.0	20.0	7.90	13.3	YES
18	10:00	1.00	1100	1100.0	19.0	7.80	14.0	YES
19	12:30	1.00	1100	1100.0	19.0	8.00	15.1	YES
20	9:34	1.07	1100	1177.0	19.00	7.80	14.1	YES
21	8:59	0.73	1100	803.0	19.00	7.90	14.1	YES
22	9:53	1.17	1100	1287.0	19.00	7.80	14.3	YES
23	11:00	0.93	1100	1023.0	19.0	7.70	13.4	YES
24	9:50	0.86	1100	946.0	19.0	7.80	13.8	YES
25	9:20	0.94	1100	1034.0	19.0	7.70	13.4	YES
26	8:27	0.58	1100	638.0	19.0	7.80	13.4	YES
27	9:03	1.09	1100	1199.0	18.0	7.80	15.2	YES
28	15:50	0.81	1100	891.0	19.0	7.60	12.7	YES
29	9:35	0.86	1100	946.0	19.0	7.80	13.8	YES
30	9:45	0.61	1100	671.0	18.0	7.80	14.3	YES
31	15:40	0.68	1100	748.0	19.0	8.10	15.1	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.