

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Dec-24**

System Name: **City of Glendale** ID# **4100323** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	off	0.06	0.06	0.05	off	0.06
2	off	off	0.05	0.05	0.06	0.04	0.06
3	0.03	off	0.07	0.06	0.14	off	0.14
4	off	off	0.10	0.12	0.12	0.06	0.12
5	0.09	off	0.07	0.06	0.06	0.04	0.07
6	0.04	off	0.07	0.06	off	off	0.07
7	0.03	off	0.06	0.07	off	0.05	0.07
8	off	off	0.07	0.07	off	off	0.07
9	0.04	off	0.06	0.06	off	off	0.06
10	0.03	off	0.06	0.07	off	off	0.07
11	off	off	0.06	0.06	off	off	0.06
12	off	off	0.05	0.06	off	off	0.06
13	0.03	off	off	0.07	0.07	0.03	0.07
14	off	off	0.06	0.04	off	off	0.06
15	0.03	off	0.03	0.04	off	0.03	0.04
16	off	off	0.03	0.03	off	off	0.03
17	0.03	off	0.04	0.06	off	off	0.06
18	off	off	0.06	0.05	0.06	off	0.06
19	off	off	0.05	0.04	0.04	off	0.05
20	off	off	0.06	0.04	0.03	off	0.06
21	off	off	0.06	0.05	0.06	off	0.06
22	off	off	0.05	0.03	0.03	off	0.05
23	off	off	0.03	0.03	off	off	0.03
24	off	off	0.04	0.05	0.04	off	0.05
25	off	off	0.03	0.04	0.03	off	0.04
26	off	off	0.03	0.05	0.04	off	0.05
27	off	off	0.03	0.04	off	off	0.04
28	off	off	0.06	0.04	0.05	0.04	0.06
29	off	off	0.04	0.04	0.06	off	0.06
30	off	off	0.05	0.04	0.04	0.03	0.05
31	off	off	0.04	0.04	off	off	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: **SEAN NEGERBOIN**

SIGNATURE: *[Signature]* DATE: **1/5/24**

PHONE #: **(541) 863 1453** CERT #: **611**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: City of Glendale ID# 4100323 Month/Year: Dec-24 Disinfection Giardia Log Inactiv: 0.5

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH ph	Required CT formula	CT Met? ³ Yes / No
1	9:45	1.11	1100	1221.0	9.0	7.40	24.0	YES
2	9:54	0.81	1100	891.0	9.00	8.00	28.7	YES
3	10:05	0.81	1100	891.0	10.00	7.70	24.1	YES
4	12:24	0.76	1100	836.0	12.00	7.50	19.6	YES
5	9:57	0.71	1100	781.0	12.0	7.60	20.2	YES
6	8:55	0.79	1100	869.0	13.0	7.60	19.0	YES
7	9:45	1.17	1100	1287.0	12.0	7.70	22.0	YES
8	9:07	1.36	1100	1496.0	10.0	7.60	24.8	YES
9	10:02	1.14	1100	1254.0	10.0	7.60	24.2	YES
10	9:35	1.13	1100	1243.0	10.0	7.70	25.0	YES
11	10:25	1.00	1100	1100.0	11.0	7.60	22.3	YES
12	9:16	1.25	1100	1375.0	11.0	7.70	23.7	YES
13	13:03	1.16	1100	1276.0	10.0	7.60	24.2	YES
14	9:45	1.00	1100	1100.0	11.0	7.60	22.3	YES
15	12:21	0.90	1100	990.0	10.0	7.80	25.3	YES
16	9:51	1.01	1100	1111.0	9.0	7.60	25.5	YES
17	9:39	1.15	1100	1265.0	10.0	7.70	25.1	YES
18	9:53	0.69	1100	759.0	10.0	7.70	23.8	YES
19	15:40	1.07	1100	1177.0	11.0	7.40	20.9	YES
20	13:10	0.49	1100	539.0	11.00	7.90	23.4	YES
21	10:00	0.72	1100	792.0	11.00	7.90	24.0	YES
22	9:37	1.26	1100	1386.0	10.00	8.00	28.3	YES
23	9:24	1.11	1100	1221.0	10.0	7.90	26.8	YES
24	9:38	1.02	1100	1122.0	10.0	8.00	27.5	YES
25	9:45	1.02	1100	1122.0	9.0	7.80	27.4	YES
26	9:22	1.06	1100	1166.0	10.0	7.70	24.8	YES
27	9:14	1.04	1100	1144.0	11.0	7.90	24.9	YES
28	15:41	0.92	1100	1012.0	10.0	7.80	25.3	YES
29	15:40	0.82	1100	902.0	11.0	7.70	22.6	YES
30	15:35	0.97	1100	1067.0	10.0	7.90	26.4	YES
31	9:40	0.82	1100	902.0	11.0	7.80	23.4	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012