

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas
 Month/Year: Jun-24

Conventional or Direct Filtration

System Name:	City of Glendale			ID#: 4100323	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.03	0.03	0.03	0.03	0.03
2	0.03	off	0.03	0.04	0.04	off	0.04
3	off	off	0.03	0.03	0.03	0.03	0.03
4	0.03	off	0.04	0.04	0.03	off	0.04
5	0.03	off	off	0.04	0.03	0.03	0.04
6	0.03	0.03	0.03	0.04	off	off	0.04
7	0.03	0.03	0.03	0.03	0.04	off	0.04
8	off	off	0.04	0.04	0.03	0.03	0.04
9	off	off	0.04	0.03	0.04	off	0.04
10	off	off	0.04	0.04	0.04	0.03	0.04
11	0.03	0.03	0.04	0.04	off	off	0.04
12	0.03	0.03	0.04	0.04	0.04	off	0.04
13	0.03	0.03	0.03	0.04	0.03	off	0.04
14	0.03	off	off	0.04	0.04	0.03	0.04
15	0.03	off	0.04	0.03	0.03	0.03	0.04
16	0.03	off	0.04	off	off	0.03	0.04
17	0.03	0.03	0.04	0.04	0.05	off	0.05
18	0.03	0.03	0.04	0.04	off	off	0.04
19	0.03	0.03	off	0.04	0.05	off	0.05
20	0.03	0.03	0.04	off	off	0.03	0.04
21	0.03	0.03	0.04	0.05	off	off	0.04
22	0.03	0.03	0.04	0.04	off	off	0.04
23	0.03	0.03	0.04	0.05	0.04	off	0.05
24	0.03	off	0.05	0.04	0.05	0.03	0.05
25	0.03	off	0.04	0.05	0.04	0.03	0.05
26	off	off	off	0.04	0.04	0.03	0.04
27	0.03	off	0.04	0.05	0.05	0.03	0.05
28	0.03	0.03	0.04	0.03	0.04	off	0.04
29	0.03	0.03	0.05	0.04	0.04	off	0.05
30	0.03	0.03	0.04	0.04	0.05	off	0.05

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: SEAN NEGHERCON
 SIGNATURE: 
 DATE: 7/8/24
 PHONE #: (541) 863 1453
 CERT #: 611

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	City of Glendale	ID#: 4100323	Month/Year:	Jun-24	Disinfection Giardia Log Inactiv:	0.5
--------------	------------------	--------------	-------------	--------	---	-----

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No
1	9:52	0.56	1100	616.0	16.0	8.00	17.6	YES
2	10:35	0.56	1100	616.0	16.00	7.90	16.9	YES
3	9:50	0.52	1100	572.0	16.00	7.90	16.8	YES
4	16:20	0.55	1100	605.0	17.00	7.80	15.2	YES
5	14:05	0.67	1100	737.0	18.0	7.90	15.0	YES
6	9:21	0.52	1100	572.0	18.0	7.90	14.7	YES
7	15:54	0.88	1100	968.0	18.0	7.80	14.8	YES
8	11:41	0.56	1100	616.0	18.0	7.70	13.7	YES
9	15:42	0.71	1100	781.0	18.0	7.60	13.5	YES
10	9:15	0.58	1100	638.0	18.0	7.70	13.8	YES
11	9:25	0.55	1100	605.0	18.0	7.50	12.7	YES
12	16:10	0.73	1100	803.0	18.0	7.60	13.5	YES
13	15:43	0.88	1100	968.0	17.0	7.80	15.8	YES
14	12:30	0.79	1100	869.0	18.0	7.80	14.6	YES
15	9:54	0.51	1100	561.0	17.0	8.20	17.6	YES
16	9:13	0.64	1100	704.0	16.0	8.10	18.4	YES
17	9:20	0.88	1100	968.0	15.0	8.20	20.9	YES
18	12:04	0.84	1100	924.0	16.0	8.10	18.8	YES
19	11:54	0.72	1100	792.0	16.0	7.70	16.0	YES
20	10:01	0.82	1100	902.0	17.00	7.70	15.1	YES
21	9:24	0.56	1100	616.0	18.00	7.60	13.2	YES
22	9:22	0.68	1100	748.0	19.00	7.60	12.6	YES
23	12:18	0.63	1100	693.0	19.0	7.60	12.5	YES
24	9:21	0.72	1100	792.0	19.0	7.70	13.1	YES
25	9:22	0.73	1100	803.0	19.0	7.60	12.6	YES
26	15:51	1.04	1100	1144.0	19.0	7.90	14.6	YES
27	15:57	0.60	1100	660.0	18.0	7.90	14.9	YES
28	9:44	0.79	1100	869.0	18.0	7.90	15.2	YES
29	12:21	0.78	1100	858.0	18.0	7.80	14.6	YES
30	9:43	0.74	1100	814.0	19.0	7.70	13.1	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012