

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Mar-25

System Name:		City of Glendale		ID#:4100323		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.04	0.04	0.04	0.04	0.04
2	0.03	off	0.03	0.03	0.04	0.03	0.04
3	off	off	0.04	0.04	0.03	0.03	0.04
4	0.03	off	0.04	0.04	0.03	0.03	0.04
5	off	off	0.03	0.03	0.04	0.03	0.04
6	off	off	0.03	0.06	0.04	0.03	0.06
7	0.03	off	0.04	0.03	0.03	0.03	0.04
8	off	off	0.04	0.03	0.03	0.03	0.04
9	0.03	off	0.03	0.03	0.04	0.03	0.04
10	off	off	0.05	0.06	0.04	0.03	0.06
11	0.03	off	off	0.05	0.05	0.03	0.05
12	0.03	0.03	0.04	0.04	0.05	off	0.05
13	off	off	0.04	0.03	0.04	0.03	0.04
14	0.03	0.03	0.04	0.06	0.05	off	0.06
15	off	off	0.03	0.04	0.06	0.09	0.09
16	0.05	0.04	0.06	0.06	0.17	off	0.17
17	off	off	off	0.13	0.06	0.06	0.13
18	0.09	0.18	0.08	0.06	0.06	0.03	0.18
19	0.19	0.03	0.09	0.06	0.06	0.04	0.19
20	off	off	0.05	0.06	0.04	0.04	0.06
21	0.03	off	0.04	0.06	0.06	0.04	0.06
22	off	off	0.05	0.07	0.05	0.04	0.07
23	0.03	off	0.03	0.04	0.04	0.05	0.05
24	0.03	off	0.05	0.05	0.04	off	0.05
25	off	off	0.05	0.05	0.03	0.04	0.05
26	0.03	off	0.04	0.05	0.04	0.05	0.05
27	off	off	0.05	0.04	0.04	0.04	0.05
28	0.05	off	0.04	0.05	0.05	0.03	0.05
29	0.03	0.05	0.04	0.04	0.04	off	0.05
30	off	off	0.03	0.03	0.03	0.04	0.04
31	0.05	0.03	0.05	0.04	0.03	0.04	0.05

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Sean Negherbon	
	SIGNATURE: 	DATE: 4/7/25
	PHONE #: (541) 541-863-1453	CERT #: 6111

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:	City of Glendale	ID#:4100323	Month/Year:	Mar-25	Disinfection Giardia Log Inactiv:	0.5
--------------	------------------	-------------	-------------	--------	---	-----

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³
	:	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	15:50	0.83	1100	913.0	10.0	7.60	23.4	YES
2	8:59	0.83	1100	913.0	10.00	7.40	21.8	YES
3	15:48	0.95	1100	1045.0	10.00	7.80	25.4	YES
4	11:47	0.96	1100	1056.0	10.00	7.40	22.1	YES
5	9:02	0.82	1100	902.0	10.0	7.80	25.0	YES
6	1:30	0.72	1100	792.0	10.0	7.90	25.7	YES
7	12:20	0.80	1100	880.0	9.0	7.80	26.7	YES
8	9:41	0.79	1100	869.0	9.0	7.90	27.7	YES
9	15:25	0.81	1100	891.0	9.0	7.80	26.8	YES
10	2:35	0.61	1100	671.0	9.0	7.90	27.1	YES
11	13:25	0.79	1100	869.0	10.0	8.00	26.8	YES
12	11:50	0.96	1100	1056.0	9.0	7.80	27.2	YES
13	9:13	0.78	1100	858.0	9.0	8.00	28.6	YES
14	15:52	0.82	1100	902.0	8.0	7.90	29.7	YES
15	15:30	0.73	1100	803.0	8.0	8.10	31.6	YES
16	5:51	0.80	1100	880.0	9.0	7.80	26.7	YES
17	13:12	0.68	1100	748.0	9.0	7.60	24.5	YES
18	10:04	0.67	1100	737.0	9.0	7.60	24.5	YES
19	9:50	0.78	1100	858.0	9.0	7.60	24.8	YES
20	9:15	0.72	1100	792.0	9.00	7.70	25.5	YES
21	9:25	0.84	1100	924.0	9.00	7.90	27.8	YES
22	13:26	0.69	1100	759.0	9.00	7.70	25.5	YES
23	8:55	0.81	1100	891.0	10.0	7.40	21.7	YES
24	8:45	0.74	1100	814.0	11.0	8.00	24.9	YES
25	11:53	0.55	1100	605.0	11.0	7.50	20.5	YES
26	9:14	0.71	1100	781.0	11.0	7.60	21.6	YES
27	12:24	0.94	1100	1034.0	12.0	7.60	20.7	YES
28	9:27	0.76	1100	836.0	11.0	7.80	23.3	YES
29	16:48	0.73	1100	803.0	10.0	7.70	23.9	YES
30	12:36	0.74	1100	814.0	10.0	7.40	21.5	YES
31	15:46	0.76	1100	836.0	10.0	7.80	24.9	YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012