

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Douglas

Conventional or Direct Filtration

Month/Year:

Jun-25

System Name:	City of Glendale			ID#: 41 00323	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.05	0.05	0.04	0.03	0.05
2	OFF	OFF	OFF	0.06	0.06	0.04	0.06
3	0.04	OFF	0.04	0.05	0.05	OFF	0.05
4	OFF	OFF	0.05	0.05	0.04	0.04	0.05
5	OFF	OFF	0.03	0.03	0.04	OFF	0.04
6	0.04	OFF	0.03	0.04	0.04	OFF	0.04
7	OFF	OFF	0.05	0.04	0.04	0.04	0.05
8	OFF	OFF	0.04	0.04	0.05	0.03	0.05
9	OFF	OFF	0.06	0.04	0.05	0.04	0.06
10	OFF	OFF	0.05	0.05	0.04	OFF	0.05
11	OFF	OFF	0.04	0.05	0.04	0.04	0.05
12	0.04	OFF	0.03	0.05	0.04	OFF	0.05
13	OFF	OFF	OFF	0.04	0.05	0.03	0.05
14	0.04	OFF	0.03	0.03	0.04	0.04	0.04
15	OFF	OFF	0.04	0.04	0.04	0.04	0.04
16	OFF	OFF	0.06	0.07	0.04	OFF	0.07
17	OFF	OFF	0.03	0.04	0.04	0.04	0.04
18	OFF	OFF	0.03	0.03	0.03	OFF	0.03
19	OFF	OFF	0.03	0.04	0.03	OFF	0.04
20	OFF	OFF	0.03	0.04	0.03	OFF	0.04
21	OFF	OFF	0.03	0.03	0.03	0.03	0.03
22	OFF	OFF	0.03	0.05	0.04	OFF	0.05
23	OFF	OFF	0.05	0.05	0.05	0.04	0.05
24	OFF	OFF	0.04	0.06	0.05	OFF	0.06
25	OFF	OFF	0.05	0.04	0.04	0.04	0.05
26	0.04	OFF	0.04	0.05	0.04	OFF	0.05
27	OFF	OFF	0.05	0.05	0.04	0.04	0.05
28	OFF	OFF	0.04	0.04	0.04	OFF	0.04
29	OFF	OFF	0.03	0.05	0.04	0.04	0.05
30	0.04	OFF	0.03	0.03	0.06	OFF	0.06
31							

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: sean Negherbon

SIGNATURE:

DATE: 7/7/25

PHONE #: (541) 863-1453

CERT #: 6111

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

						WTP - : A	
System Name:	City of Glendale	ID#: 41 00323	Month/Year:	Jun-25	Disinfection <i>Giardia</i> Log Inactive:	0.5	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/0929	0.82	744.0	610.1	17.0	7.70	15.1	YES	126
2/1203	0.72	744.0	535.7	17.0	7.80	15.5	YES	126
3/1550	0.72	694.4	500.0	17.0	7.80	15.5	YES	135
4/1157	0.68	744.0	506.0	17.0	7.90	16.0	YES	126
5/0907	0.8	787.8	630.3	18.0	7.90	15.2	YES	119
6/0940	0.94	593.4	557.8	18.0	7.70	14.4	YES	158
7/0949	0.53	674.5	357.5	19.0	7.90	13.8	YES	139
8/1208	0.53	679.3	360.1	19.0	7.70	12.8	YES	138
9/0929	0.53	532.7	282.3	20.0	7.70	12.0	YES	176
10/0935	0.7	710.2	497.2	20.0	7.60	11.8	YES	132
11/1147	0.41	679.3	278.5	20.0	7.80	12.3	YES	138
12/0940	0.9	336.0	302.4	19.0	7.70	13.4	YES	279
13/1150	0.65	844.6	549.0	19.0	7.90	14.0	YES	111
14/1017	0.79	684.3	540.6	17.0	7.90	16.2	YES	137
15/0910	0.75	726.7	545.1	17.0	7.90	16.2	YES	129
16/0928	0.6	762.2	457.3	18.0	7.90	14.9	YES	123
17/0943	0.91	684.3	622.7	18.0	7.90	15.4	YES	137
18/1004	0.87	679.3	591.0	18.0	7.80	14.8	YES	138
19/0741	0.78	732.4	571.3	18.0	7.90	15.2	YES	128
20/1548	0.72	726.7	523.3	18.0	8.00	15.6	YES	129
21/1005	0.74	844.6	625.0	17.0	8.00	16.8	YES	111
22/1232	0.79	801.3	633.0	16.0	8.00	18.0	YES	117
23/1542	0.55	582.3	320.3	16.0	8.00	17.5	YES	161
24/0933	0.69	660.2	455.5	18.0	7.90	15.0	YES	142
25/0857	0.71	629.2	446.7	18.0	7.80	14.5	YES	149
26/1610	0.76	699.6	531.7	19.0	7.80	13.6	YES	134
27/0940	0.73	589.6	430.4	19.0	7.80	13.6	YES	159
28/1013	0.72	582.3	419.3	19.0	7.80	13.6	YES	161
29/1220	0.68	699.6	475.7	19.0	7.80	13.5	YES	134
30/0913	0.93	651.0	605.5	20.0	7.70	12.5	YES	144
		#DIV/0!						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350