

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Aug-25

System Name:	City of Glendale	ID#: 41 00323	WTP : TP -	A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.06	0.06	0.05	OFF	0.06
2	OFF	OFF	0.04	0.05	0.04	0.04	0.05
3	OFF	OFF	0.04	0.06	0.06	OFF	0.06
4	OFF	OFF	0.07	0.06	0.06	0.04	0.07
5	OFF	OFF	0.04	0.05	0.05	OFF	0.05
6	OFF	OFF	0.03	0.03	0.03	0.04	0.04
7	OFF	OFF	0.05	0.04	0.05	OFF	0.05
8	OFF	OFF	0.04	0.06	0.04	0.04	0.06
9	OFF	OFF	0.03	0.03	0.04	OFF	0.04
10	OFF	OFF	0.03	0.06	0.05	0.04	0.06
11	OFF	OFF	0.04	0.05	0.03	0.04	0.05
12	OFF	OFF	0.04	0.06	0.05	OFF	0.06
13	OFF	OFF	OFF	0.04	0.05	0.04	0.05
14	0.04	OFF	0.04	0.03	0.03	0.04	0.04
15	OFF	OFF	0.04	0.03	0.05	0.05	0.05
16	OFF	OFF	0.05	0.03	0.03	OFF	0.05
17	OFF	OFF	0.03	0.04	0.05	OFF	0.05
18	OFF	OFF	0.03	0.05	0.05	0.04	0.05
19	OFF	OFF	0.03	0.03	0.03	0.04	0.04
20	OFF	OFF	0.03	0.04	0.04	0.04	0.04
21	OFF	OFF	0.03	0.04	0.05	OFF	0.05
22	OFF	OFF	0.05	0.04	0.06	0.04	0.06
23	OFF	OFF	0.05	0.04	0.03	OFF	0.05
24	0.04	OFF	0.03	OFF	0.04	0.05	0.05
25	0.04	OFF	0.04	0.07	OFF	OFF	0.07
26	OFF	OFF	0.05	0.04	0.04	OFF	0.05
27	OFF	OFF	0.05	0.04	0.03	0.04	0.05
28	0.04	OFF	0.03	0.03	0.04	OFF	0.04
29	OFF	OFF	0.05	0.04	0.04	0.04	0.05
30	OFF	OFF	0.04	0.05	0.04	0.04	0.05
31	OFF	OFF	0.04	0.03	0.04	OFF	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Marcus Brenden	
	SIGNATURE: <i>Marcus Brenden</i>	DATE: 9/3/2025
	PHONE #: (541) 237-4322	CERT #: 39085

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	City of Glendale	ID#: 41 00323	Month/Year:	Aug-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	------------------	---------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1158	0.95	52.0	49.4	21.0	7.90	12.7	YES	149
2/0952	0.93	52.0	48.4	21.0	7.90	12.6	YES	139
3/0919	1.04	52.0	54.1	20.0	7.80	13.2	YES	141
4/0918	0.86	52.0	44.7	19.0	7.90	14.3	YES	127
5/0906	0.93	52.0	48.4	20.0	7.90	13.5	YES	126
6/0918	0.88	52.0	45.8	20.0	7.80	12.9	YES	147
7/0910	0.94	52.0	48.9	20.0	7.80	13.0	YES	144
8/1014	0.83	52.0	43.2	20.0	7.90	13.4	YES	149
9/0955	1.05	52.0	54.6	20.0	7.80	13.2	YES	145
10/0915	0.87	52.0	45.2	19.0	7.80	13.8	YES	130
11/0921	0.93	52.0	48.4	20.0	7.70	12.5	YES	192
12/1552	0.82	52.0	42.6	21.0	7.80	12.0	YES	195
13/1230	0.86	52.0	44.7	22.0	7.80	11.3	YES	167
14/1202	0.96	52.0	49.9	21.0	7.80	12.2	YES	201
15/1148	0.87	52.0	45.2	20.0	7.90	13.4	YES	206
16/0956	0.75	52.0	39.0	20.0	7.90	13.2	YES	142
17/0913	0.9	52.0	46.8	20.0	7.90	13.5	YES	115
18/1501	0.81	52.0	42.1	20.0	7.90	13.3	YES	179
19/0941	0.87	52.0	45.2	20.0	7.90	13.4	YES	179
20/0910	0.93	52.0	48.4	19.0	7.90	14.4	YES	186
21/0928	0.97	52.0	50.4	20.0	7.80	13.1	YES	162
22/0940	0.9	52.0	46.8	20.0	7.90	13.5	YES	141
23/0954	1.08	52.0	56.2	21.0	7.80	12.4	YES	153
24/1522	1.12	52.0	58.2	20.0	7.80	13.3	YES	150
25/0841	1.04	52.0	54.1	21.0	7.80	12.3	YES	143
26/1524	1.25	52.0	65.0	21.0	7.80	12.6	YES	131
27/0958	0.78	52.0	40.6	21.0	7.80	12.0	YES	154
28/1005	1.05	52.0	54.6	21.0	7.80	12.3	YES	160
29/0927	0.8	52.0	41.6	20.0	7.90	13.3	YES	139
30/1020	1.11	52.0	57.7	20.0	7.90	13.8	YES	144
31/0910	0.96	52.0	49.9	19.0	7.90	14.5	YES	148

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350