

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Mar-26**

System Name: **City of Glendale** ID#: **41 00323** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.04	0.04	0.04	0.04	0.04	0.04
2	OFF	OFF	0.04	0.03	0.04	0.04	0.04
3	OFF	OFF	0.04	0.04	0.03	0.03	0.04
4	OFF	OFF	0.05	0.04	0.06	OFF	0.06
5	OFF	OFF	0.04	0.05	0.04	0.03	0.05
6	OFF	OFF	0.03	0.04	0.03	OFF	0.04
7	OFF	OFF	0.05	0.04	0.04	0.04	0.05
8	OFF	OFF	0.04	0.04	0.05	OFF	0.05
9	0.51	OFF	OFF	OFF	0.04	OFF	0.51
10	OFF	OFF	0.03	0.03	0.04	0.04	0.04
11	OFF	OFF	0.05	0.04	0.05	OFF	0.05
12	OFF	OFF	0.03	0.06	0.03	0.03	0.06
13	OFF	OFF	0.03	0.03	0.04	OFF	0.04
14	OFF	OFF	0.04	0.03	0.03	0.04	0.04
15	OFF	OFF	0.02	0.03	0.03	OFF	0.03
16	OFF	OFF	0.04	0.06	0.03	0.04	0.06
17	OFF	OFF	0.04	0.04	0.07	OFF	0.07
18	OFF	OFF	0.05	0.06	0.06	0.03	0.06
19	0.03	OFF	0.06	0.04	0.04	0.04	0.06
20	OFF	OFF	0.06	0.05	OFF	OFF	0.06
21	0.05	0.04	0.05	0.06	OFF	OFF	0.06
22	OFF	OFF	0.06	0.05	0.04	0.03	0.06
23	OFF	OFF	OFF	0.03	0.04	0.05	0.05
24	OFF	OFF	0.06	0.03	OFF	OFF	0.06
25	OFF	OFF	0.04	0.03	0.05	OFF	0.05
26	OFF	OFF	0.02	0.03	0.03	OFF	0.03
27	OFF	OFF	0.03	0.03	0.04	OFF	0.04
28	OFF	OFF	0.03	0.03	0.04	0.03	0.04
29	OFF	OFF	0.03	0.04	0.03	OFF	0.04
30	OFF	OFF	0.04	0.03	0.04	OFF	0.04
31	OFF	OFF	0.03	0.03	0.03	OFF	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)
--	---

95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE ² triggers	Yes/No Yes/No Yes/No	CT's met everyday? (see back)	Yes/No Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l?	Yes/No Yes/No
---	----------------------------	----------------------------------	------------------	--	------------------

Notes:	PRINTED NAME: Marcus Brenden SIGNATURE: <i>Marcus Brenden</i> DATE: 4/6/26 PHONE #: (541) 237-4322 CERT #: 39085
--------	--

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	A
Disinfection <i>Giardia</i> Log Inactive:	0.5

System Name: City of Glendale ID#: 41 00323 Month/Year: Mar-26

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/928	1.05	52.0	54.6	11.0	7.40	20.9	YES	98
2/1543	0.76	52.0	39.5	11.0	7.70	22.5	YES	94
3/1145	0.94	52.0	48.9	11.0	7.80	23.8	YES	91
4/1205	0.8	52.0	41.6	11.0	7.60	21.8	YES	101
5/1141	0.79	52.0	41.1	11.0	7.70	22.5	YES	93
6/1213	0.12	52.0	6.2	11.0	7.90	22.4	NO	100
7/0940	0.81	52.0	42.1	11.0	8.00	25.1	YES	100
8/0901	0.89	52.0	46.3	11.0	7.90	24.5	YES	99
9/1548	1.1	52.0	57.2	12.0	7.90	23.5	YES	90
10/0944	0.76	52.0	39.5	10.0	8.00	26.7	YES	118
11/0857	0.91	52.0	47.3	10.0	7.90	26.2	YES	98
12/0902	0.8	52.0	41.6	10.0	7.80	25.0	YES	107
13/1538	0.82	52.0	42.6	11.0	7.90	24.3	YES	113
14/0935	0.8	52.0	41.6	12.0	7.90	22.7	YES	101
15/1521	0.84	52.0	43.7	10.0	7.80	25.1	YES	104
16/1305	0.78	52.0	40.6	10.0	7.90	25.8	YES	124
17/0910	0.68	52.0	35.4	11.0	7.90	23.9	YES	116
18/1039	0.75	52.0	39.0	12.0	8.10	24.2	YES	119
19/0858	0.8	52.0	41.6	12.0	7.60	20.4	YES	104
20/0855	0.78	52.0	40.6	12.0	7.80	21.8	YES	119
21/1208	0.92	52.0	47.8	12.0	7.50	20.0	YES	119
22/0854	0.74	52.0	38.5	12.0	7.70	21.0	YES	119
23/1300	0.99	52.0	51.5	12.0	8.10	24.9	YES	123
24/0900	0.78	52.0	40.6	12.0	7.90	22.6	YES	86
25/0835	0.67	52.0	34.8	12.0	7.70	20.8	YES	111
26/1224	0.85	52.0	44.2	12.0	7.80	22.0	YES	96
27/0910	0.81	52.0	42.1	12.0	7.90	22.7	YES	111
28/0939	0.81	52.0	42.1	12.0	7.80	21.9	YES	111
29/0907	0.99	52.0	51.5	12.0	7.80	22.4	YES	111
30/0833	0.74	52.0	38.5	13.0	7.70	19.6	YES	113
31/1220	0.83	52.0	43.2	13.0	7.70	19.8	YES	91

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350