

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lincoln
 Month/Year: April 2021

System Name: Kernville Glenden Beach Lincoln Beach WD ID#: OR4100324 WTP: TP - Drift & Side Creek

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			.02				.03
2			.03				.03
3			.03				.04
4			.03				.03
5			.03				.03
6			.02				.03
7			.02				.03
8			.02				.03
9			.02				.03
10			.03				.04
11			.03				.03
12			.03				.03
13			.03				.03
14			.03				.11
15			.03				.04
16			.03				.05
17			.03				.06
18			.03				.10
19			.03				.10
20			.03				.04
21			.03				.04
22			.03				.04
23			.03				.03
24			.03				.03
25			.03				.03
26			.03				.03
27			.03				.03
28			.03				.03
29			.03				.03
30			.03				.03
31							

<p>Slow Sand/Membrane/DE Filtration/Unfiltered</p> <p>95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>	<p align="center">Monthly Summary (Answer Yes or No)</p>	
	<p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>	<p>All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>
<p>Notes:</p>	<p>PRINTED NAME: <u>Bill Neal</u></p>	
	<p>SIGNATURE: <u>Bill Neal</u></p>	<p>DATE: <u>5-3-2021</u></p>
	<p>PHONE #: <u>(541) 764-2475</u></p>	<p>CERT #: <u>5160</u></p>

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : Drift & Side Creek

System Name: K-GB-LB Water District ID#: 4100324

Month/Year: April 2021

Disinfection Giardia Log

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.2	74	89	7.9	6.8	51	Yes	400
2	1.4	74	104	8.1	6.8	52	Yes	400
3	1.4	74	104	8.1	6.8	52	Yes	400
4	1.4	74	104	8.2	6.8	52	Yes	400
5	1.3	74	96	8.2	6.8	52	Yes	400
6	1.4	74	104	8.0	6.9	52	Yes	400
7	1.4	74	104	8.0	6.9	52	Yes	400
8	1.3	74	96	8.1	7.0	52	Yes	400
9	1.3	74	96	8.1	7.0	52	Yes	400
10	1.2	74	89	8.1	7.0	51	Yes	400
11	1.2	74	89	8.0	7.0	51	Yes	400
12	1.3	74	96	7.9	7.1	62	Yes	400
13	1.3	74	96	8.0	7.0	52	Yes	400
14	1.4	74	104	8.2	7.0	52	Yes	400
15	1.3	74	96	8.3	7.0	52	Yes	400
16	1.4	74	104	8.4	7.0	52	Yes	400
17	1.4	74	104	8.8	7.0	52	Yes	400
18	1.4	74	104	9.0	7.0	52	Yes	400
19	1.3	74	96	9.0	7.0	52	Yes	400
20	1.3	74	96	8.9	7.0	52	Yes	400
21	1.3	74	96	9.0	7.1	62	Yes	400
22	1.3	74	96	9.0	7.0	52	Yes	400
23	1.3	74	96	9.0	7.1	62	Yes	400
24	1.3	74	96	8.9	7.1	62	Yes	400
25	1.4	74	104	8.6	7.1	62	Yes	400
26	1.3	74	96	8.6	7.1	62	Yes	400
27	1.2	74	89	8.6	7.2	61	Yes	400
28	1.3	74	96	8.6	7.2	62	Yes	400
29	1.4	74	104	8.8	7.1	62	Yes	400
30	1.3	74	96	9.0	7.0	52	Yes	400
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

RAW WATER - DRIFT CREEK

MONTH/YEAR: April 2021

DATE	METER READING	GALLONS	COMMENTS
PRIOR	2558925	676,000	
1	2559542	617,000	
2	2560165	623,000	
3	2560783	628,000	
4	2561402	609,000	
5	2561993	591,000	
6	2562611	618,000	
7	2563224	613,000	
8	2563830	606,000	
9	2564432	602,000	
10	2565101	669,000	
11	2565671	570,000	
12	2566209	538,000	
13	2566790	581,000	
14	2567442	652,000	
15	2568033	591,000	
16	2568600	567,000	
17	2569212	612,000	
18	2570313	1,101,000	
19	2571132	819,000	
20	2571641	509,000	
21	2572509	868,000	
22	2573496	987,000	
23	2574463	967,000	
24	2575226	763,000	
25	2575796	570,000	
26	2576325	529,000	
27	2576872	547,000	
28	2577420	548,000	
29	2578042	622,000	
30	2578668	626,000	
31			

SIDE CREEK

April 2021

DATE	P.H.	TURBIDITY	METER	GALLONS
			521459	559,000
1			521459	
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				

