

Turb

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lincoln
 Month/Year: September 2021

System Name: Kernville Gleneden Beach Lincoln Beach WD ID#: OR4100324 WTP: TP - Drift & Side Creek

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			.03				.03
2			.03				.03
3			.03				.03
4			.03				.03
5			.03				.03
6			.03				.03
7			.03				.03
8			.03				.03
9			.03				.03
10			.03				.03
11			.03				.05
12			.03				.03
13			.03				.03
14			.03				.03
15			.03				.03
16			.03				.03
17			.03				.21
18			.03				.06
19			.03				.03
20			.03				.03
21			.03				.03
22			.03				.03
23			.03				.03
24			.03				.03
25			.03				.03
26			.02				.03
27			.02				.03
28			.03				.03
29			.03				.03
30			.03				.03
31							

<input checked="" type="checkbox"/> Slow Sand/ <input type="checkbox"/> Membrane/DE Filtration/ <input type="checkbox"/> Unfiltered	Monthly Summary (Answer Yes or No)	
	95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Notes:	
PRINTED NAME: Bill Neal		DATE:
SIGNATURE: Bill Neal		CERT #: 5160
PHONE #: (541) 764-2475		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

SWQD

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : Drift & Side Creek

Disinfection Giardia Log

System Name: K-GB-LB Water District ID#: 4100324

Month/Year: September 2021 Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.2	74	89	10.4	7.2	46	Yes	800
2	1.2	74	89	10.0	7.2	46	Yes	800
3	1.1	74	81	9.9	7.2	61	Yes	800
4	1.1	74	81	9.9	7.2	61	Yes	800
5	1.5	74	111	10.1	7.2	48	Yes	800
6	1.5	74	111	10.3	7.2	48	Yes	800
7	1.2	74	89	10.3	7.2	46	Yes	400
8	1.2	74	89	10.3	7.2	46	Yes	800
9	1.4	74	104	10.4	7.2	47	Yes	800
10	1.5	74	111	10.4	7.2	48	Yes	400
11	1.3	74	96	10.4	7.2	47	Yes	800
12	1.5	74	111	10.1	7.2	48	Yes	800
13	1.5	74	111	10.1	7.2	48	Yes	800
14	1.5	74	111	10.0	7.2	48	Yes	400
15	1.5	74	111	9.9	7.2	64	Yes	400
16	1.5	74	111	9.9	7.2	64	Yes	800
17	1.5	74	111	9.7	7.2	64	Yes	400
18	1.4	74	104	9.6	7.2	64	Yes	400
19	1.0	74	74	9.7	7.2	60	Yes	400
20	1.0	74	74	9.7	7.2	60	Yes	400
21	1.0	74	74	9.7	7.2	60	Yes	400
22	1.3	74	96	9.7	7.2	62	Yes	400
23	1.3	74	96	9.7	7.2	62	Yes	400
24	1.4	74	104	9.6	7.2	62	Yes	400
25	1.2	74	89	9.6	7.2	61	Yes	400
26	1.4	74	104	9.6	7.2	62	Yes	400
27	1.3	74	96	9.7	7.2	62	Yes	400
28	1.3	74	96	9.8	7.2	62	Yes	400
29	1.3	74	96	9.6	7.2	62	Yes	400
30	1.0	74	74	9.5	7.2	60	Yes	400
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350
 PAGE 2 of 2