

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lincoln
 Month/Year: Jan. 2024

System Name: Kernville Gleneden Beach Lincoln Beach WD ID#: OR4100324 WTP: TP - Drift & Side Creek

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			.02				.02
2			.02				.02
3			.02				.02
4			.02				.02
5			.02				.02
6			.03				.06
7			.03				.03
8			.02				.02
9			.03				.09
10			.03				.04
11			.03				.04
12			.03				.04
13			.03				.03
14			.02				.03
15			.03				.03
16			.03				.03
17			.03				.03
18			.05				.05
19			.26				.9 Power out
20			.2				.21
21			.18				.2
22			.2				.3
23			.17				.2
24			.17				.3
25			.06				.9 Power out
26			.1				.15
27			.29				.31
28			.50				.57
29			.41				.52
30			.09				.94 Power out
31			.12				.13

<input checked="" type="checkbox"/> Slow Sand/ 95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes <input type="radio"/> No		Monthly Summary (Answer Yes or No)	
All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No

Notes:

PRINTED NAME: Bill Neal
 SIGNATURE: *Bill Neal* DATE: 2-1-2024
 PHONE #: (541) 764-2475 CERT #: 5160

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : Drift & Side Creek

Disinfection Giardia Log

System Name: K-GB-LB Water District ID#: 4100324

Month/Year: Jan. 2004

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
1	1.2	74	89	9.7	7.2	61	Yes	400
2	1.2	74	89	9.6	6.8	51	Yes	400
3	1.2	74	89	9.4	6.6	51	Yes	400
4	1.3	74	96	9.2	6.7	52	Yes	400
5	1.3	74	96	9.2	6.6	52	Yes	400
6	1.3	74	96	9.2	6.6	52	Yes	400
7	1.3	74	96	9.1	6.7	52	Yes	400
8	1.3	74	96	9.0	6.6	52	Yes	400
9	1.4	74	104	9.0	6.5	43	Yes	400
10	1.4	74	104	8.9	6.5	43	Yes	400
11	1.4	74	104	8.8	6.6	52	Yes	400
12	1.4	74	104	8.8	6.6	52	Yes	400
13	1.4	74	104	8.7	6.4	43	Yes	400
14	1.4	74	104	8.4	6.5	43	Yes	400
15	1.4	74	104	8.1	6.7	52	Yes	400
16	1.4	74	104	7.9	6.5	43	Yes	400
17	1.4	74	104	7.7	6.6	52	Yes	400
18	1.4	74	104	8.1	6.5	43	Yes	400
19	1.4	74	104	8.5	6.7	52	Yes	400
20	1.4	74	104	8.8	6.7	52	Yes	400
21	1.4	74	104	8.9	6.7	52	Yes	400
22	1.4	74	104	9.1	6.7	52	Yes	400
23	1.4	74	104	9.3	6.8	52	Yes	400
24	1.4	74	104	9.4	6.8	52	Yes	400
25	1.4	74	104	9.4	6.7	52	Yes	400
26	1.4	74	104	9.5	6.7	52	Yes	400
27	1.5	74	111	9.7	6.7	53	Yes	400
28	1.5	74	111	9.7	6.6	53	Yes	400
29	1.5	74	111	10.1	6.7	40	Yes	400
30	1.3	74	96	10.2	6.7	39	Yes	400
31	1.4	74	104	10.3	6.7	39	Yes	400

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350