

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lincoln  
 Month/Year: Sept 2024  
 WTP: TP - Drift & Side Creek

System Name: Kerrville Gleneden Beach Lincoln Beach WD ID#: OR4100324

| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1   |             |            | .03        |            |            |            | .03   |
| 2   |             |            | .03        |            |            |            | .03   |
| 3   |             |            | .02        |            |            |            | .02   |
| 4   |             |            | .02        |            |            |            | .02   |
| 5   |             |            | .02        |            |            |            | .02   |
| 6   |             |            | .02        |            |            |            | .99   |
| 7   |             |            | .02        |            |            |            | .03   |
| 8   |             |            | .02        |            |            |            | .03   |
| 9   |             |            | .02        |            |            |            | .04   |
| 10  |             |            | .02        |            |            |            | .03   |
| 11  |             |            | .02        |            |            |            | .04   |
| 12  |             |            | .02        |            |            |            | .03   |
| 13  |             |            | .02        |            |            |            | .04   |
| 14  |             |            | .02        |            |            |            | .04   |
| 15  |             |            | .02        |            |            |            | .03   |
| 16  |             |            | .02        |            |            |            | .04   |
| 17  |             |            | .02        |            |            |            | .13   |
| 18  |             |            | .03        |            |            |            | .13   |
| 19  |             |            | .03        |            |            |            | .04   |
| 20  |             |            | .03        |            |            |            | .03   |
| 21  |             |            | .03        |            |            |            | .03   |
| 22  |             |            | .03        |            |            |            | .04   |
| 23  |             |            | .02        |            |            |            | .03   |
| 24  |             |            | .02        |            |            |            | .03   |
| 25  |             |            | .02        |            |            |            | .03   |
| 26  |             |            | .02        |            |            |            | .05   |
| 27  |             |            | .03        |            |            |            | .03   |
| 28  |             |            | .03        |            |            |            | .12   |
| 29  |             |            | .03        |            |            |            | .03   |
| 30  |             |            | .02        |            |            |            | .02   |
| 31  |             |            |            |            |            |            |   |

|   |                                   |   |   |
|---|-----------------------------------|---|---|
| <b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>    |                                   | <b>Monthly Summary (Answer Yes or No)</b> |   |
| 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> | <u>Yes</u> /No                    | CT's met everyday? (see back)             | All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU?                 | <u>Yes</u> /No                    | <u>Yes</u> /No                            | <u>Yes</u> /No  |
| Notes:  | PRINTED NAME: <u>Jeremy Price</u> |   | DATE: <u>10-1-24</u>                                    |
|   | SIGNATURE: <u>[Signature]</u>     |   | CERT #:   |
|   | PHONE #: <u>(541) 764-2475</u>    |   |   |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : Drift & Side Creek

System Name: K-GB-LB Water District ID#: 4100324

9 Month/Year: 2024

Disinfection *Giardia* Log

Inactiv:

1.0

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> | Contact Time (T) | Actual CT | Temp | pH  | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|------|-----|-------------|----------------------|-------------------------|
|             | [ppm or mg/l]   | [minutes]        | C X T     | [°C] |     | formula     | Yes / No             | [GPM]                   |
| 1           | 1.3   | 74               | 96        | 16   | 7.0 | 25          | yes                  | 400                     |
| 2           | 1.2   | 74               | 89        | 16   | 7.0 | 25          | yes                  | 400                     |
| 3           | 1.2   | 74               | 89        | 15.8 | 6.8 | 25          | yes                  | 400                     |
| 4           | 1.2   | 74               | 89        | 15.8 | 7.1 | 31          | yes                  | 400                     |
| 5           | 1.3   | 74               | 96        | 16.0 | 7.1 | 31          | yes                  | 400                     |
| 6           | 1.3   | 74               | 96        | 16.3 | 7.0 | 25          | yes                  | 400                     |
| 7           | 1.3   | 74               | 96        | 16.5 | 7.1 | 31          | yes                  | 400                     |
| 8           | 1.2   | 74               | 89        | 16.5 | 7.1 | 31          | yes                  | 400                     |
| 9           | 1.1   | 74               | 81        | 16.5 | 7.3 | 31          | yes                  | 400                     |
| 10          | 1.1   | 74               | 81        | 16.7 | 7.3 | 31          | yes                  | 400                     |
| 11          | 1.1   | 74               | 81        | 16.5 | 7.2 | 31          | yes                  | 400                     |
| 12          | 1.2   | 74               | 89        | 16.4 | 7.0 | 25          | yes                  | 400                     |
| 13          | 1.2   | 74               | 89        | 16.2 | 7.2 | 31          | yes                  | 400                     |
| 14          | 1.2   | 74               | 89        | 15.9 | 7.1 | 31          | yes                  | 400                     |
| 15          | 1.2   | 74               | 89        | 15.7 | 7.1 | 31          | yes                  | 400                     |
| 16          | 1.2   | 74               | 89        | 15.6 | 7.1 | 31          | yes                  | 400                     |
| 17          | 1.2   | 74               | 89        | 15.1 | 7.1 | 31          | yes                  | 400                     |
| 18          | 1.0   | 74               | 74        | 14.6 | 7.1 | 45          | yes                  | 400                     |
| 19          | 1.2   | 74               | 89        | 14.6 | 7.1 | 46          | yes                  | 400                     |
| 20          | 1.0   | 74               | 74        | 14.5 | 7.0 | 37          | yes                  | 400                     |
| 21          | 1.0   | 74               | 74        | 14.3 | 7.0 | 37          | yes                  | 400                     |
| 22          | 1.2   | 74               | 89        | 14.0 | 7.2 | 46          | yes                  | 400                     |
| 23          | 1.4   | 74               | 104       | 13.9 | 7.0 | 39          | yes                  | 400                     |
| 24          | 1.3   | 74               | 96        | 13.8 | 7.0 | 38          | yes                  | 400                     |
| 25          | 1.2   | 74               | 89        | 14.2 | 7.0 | 38          | yes                  | 400                     |
| 26          | 1.2   | 74               | 89        | 14.2 | 7.0 | 38          | yes                  | 400                     |
| 27          | 1.2   | 74               | 89        | 14.4 | 7.0 | 38          | yes                  | 400                     |
| 28          | 1.0   | 74               | 74        | 14.4 | 7.0 | 37          | yes                  | 400                     |
| 29          | 1.0   | 74               | 74        | 14.4 | 7.0 | 37          | yes                  | 400                     |
| 30          | 1.0   | 74               | 74        | 13.6 | 7.0 | 37          | yes                  | 400                     |
| 31          |   |                  |           |      |     |             |                      |                         |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp\_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350