

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lincoln
 Month/Year: Aug 2025
 WTP: TP - Drift & Side Creek

System Name: Kernville Gleneden Beach Lincoln Beach WD ID#: OR4100324

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			.04				.07
2			.05				.07
3			.04				.06
4			.04				.04
5			.07				.09
6			.06				.08
7			.06				.10
8			.06				.09
9			.05				.17
10			.04				.06
11			.04				.05
12			.04				.04
13			.03				.04
14			.03				.03
15			.04				.29
16			.03				.04
17			.08				.10
18			.07				.09
19			.06				.09
20			.06				.08
21			.05				.06
22			.06				.07
23			.06				.09
24			.05				.11
25			.05				.09
26			.05				.08
27			.05				.08
28			.05				.07
29			.04				.08
30			.05				.08
31			.04				.05

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings $\leq$ 1 NTU? ² ☒ Yes / No All daily turbidity readings $\leq$ 5 NTU? ☒ Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / No All Cl2 residual at entry point $\geq$ 0.2 mg/l? ☒ Yes / No	
Notes: 		PRINTED NAME: <u>Jeremy Price</u>	
		SIGNATURE: <u>[Signature]</u>	
		DATE: <u>9-2-25</u>	
		PHONE #: <u>(541) 764-2475</u>	
		CERT #:	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : Drift & Side Creek

Disinfection Giardia Log

System Name: K-GB-LB Water District ID#: 4100324

Month/Year: Aug - 2025

Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes/ No	[GPM]
1	1.2	126	151	18.3	6.9	24	Yes	400
2	1.3	126	164	18.4	7.1	31	Yes	400
3	1.4	126	176	18.6	6.8	26	Yes	400
4	1.3	126	164	18.4	7.0	26	Yes	400
5	1.3	126	164	17.9	6.5	26	Yes	400
6	1.3	126	164	17.7	7.0	26	Yes	400
7	1.3	126	164	17.4	7.0	26	Yes	800
8	1.2	126	151	17.2	6.9	24	Yes	800
9	1.2	126	151	17.2	6.9	24	Yes	400
10	1.2	126	151	17.4	6.9	24	Yes	400
11	1.1	126	139	18.0	6.9	24	Yes	800
12	1.2	126	151	18.4	6.9	24	Yes	400
13	1.2	126	151	18.7	6.9	24	Yes	400
14	1.2	126	151	18.9	6.9	24	Yes	400
15	1.2	126	151	19.1	6.9	25	Yes	400
16	1.1	126	139	18.6	6.9	25	Yes	400
17	1.0	126	126	18.1	6.7	25	Yes	400
18	1.8	126	101	17.6	6.9	24	Yes	400
19	1.9	126	113	17.4	6.8	24	Yes	800
20	1.9	126	113	17.2	6.8	24	Yes	800
21	1.9	126	113	17.2	6.8	24	Yes	800
22	1.0	126	126	17.1	6.8	25	Yes	800
23	1.1	126	139	17.1	6.9	25	Yes	400
24	1.1	126	139	17.2	6.9	25	Yes	800
25	1.1	126	139	17.4	6.9	25	Yes	800
26	1.2	126	151	17.6	7.0	25	Yes	800
27	1.2	126	151	17.6	7.1	31	Yes	800
28	1.2	126	151	17.2	7.1	31	Yes	800
29	1.1	126	139	16.8	7.1	25	Yes	800
30	1.2	126	151	16.8	7.1	31	Yes	800
31	1.3	126	164	16.4	7.1	31	Yes	400

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2