

2/26

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Lincoln
 Month/Year: 2/26
 WTP: TP - Drift & Side Creek

| System Name: | Kernville Glendon Beach Lincoln Beach WD ID#: OR4100324 | | | | | | Highest Reading of the day ¹ [NTU] |
|--------------|---|------------|------------|------------|------------|------------|---|
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | |
| 1 | | | .07 | | | | .11 |
| 2 | | | .04 | | | | .06 |
| 3 | | | .09 | | | | .26 |
| 4 | | | .08 | | | | .09 |
| 5 | | | .07 | | | | .08 |
| 6 | | | .07 | | | | .08 |
| 7 | | | .05 | | | | .06 |
| 8 | | | .07 | | | | .07 |
| 9 | | | .05 | | | | .08 |
| 10 | | | .04 | | | | .05 |
| 11 | | | .06 | | | | .07 |
| 12 | | | .05 | | | | .06 |
| 13 | | | .05 | | | | .05 |
| 14 | | | .05 | | | | .06 |
| 15 | | | .05 | | | | .05 |
| 16 | | | .05 | | | | .05 |
| 17 | | | .04 | | | | .05 |
| 18 | | | .04 | | | | .04 |
| 19 | | | .04 | | | | .05 |
| 20 | | | .04 | | | | .04 |
| 21 | | | .05 | | | | .06 |
| 22 | | | .05 | | | | .05 |
| 23 | | | .05 | | | | .06 |
| 24 | | | .04 | | | | .06 |
| 25 | | | .05 | | | | .05 |
| 26 | | | .05 | | | | .05 |
| 27 | | | .05 | | | | .05 |
| 28 | | | .04 | | | | .04 |
| 29 | | | | | | | |
| 30 | | | | | | | |
| 31 | | | | | | | |

| | | | |
|---|--|---|--|
| Slow Sand/Membrane/DE Filtration/Unfiltered | | Monthly Summary (Answer Yes or No) | |
| 95% of daily turbidity readings ≤ 1 NTU? ² | Yes/No <input checked="" type="radio"/> Yes <input type="radio"/> No | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU? | Yes/No <input checked="" type="radio"/> Yes <input type="radio"/> No | <input checked="" type="radio"/> Yes <input type="radio"/> No | Yes/No <input checked="" type="radio"/> Yes <input type="radio"/> No |
| Notes: | | PRINTED NAME: <i>Jeremy Price</i> | |
| | | SIGNATURE: <i>Jeremy Price</i> | DATE: 3-2-26 |
| | | PHONE #: (541) 764-2425 | CERT #: 6578 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : Drift & Side Creek

Disinfection Giardia Log

System Name: K-GB-LB Water District ID#: 4100324

Month/Year: Feb 2026

Inactiv:

1.0

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|------|-----|-------------|----------------------|-------------------------|
| | [ppm or mg/L] | [minutes] | CXT | [°C] | | formula | Yes / No | [GPM] |
| 1 | .8 | 126 | 100 | 8.5 | 6.9 | 49 | yes | 400 |
| 2 | 1.1 | 126 | 139 | 8.6 | 7.0 | 51 | yes | 400 |
| 3 | 1.0 | 126 | 126 | 8.8 | 7.0 | 50 | yes | 400 |
| 4 | 1.0 | 126 | 126 | 8.9 | 7.0 | 50 | yes | 400 |
| 5 | 1.0 | 126 | 126 | 9.1 | 7.0 | 50 | yes | 400 |
| 6 | 1.0 | 126 | 126 | 9.1 | 7.0 | 50 | yes | 400 |
| 7 | .9 | 126 | 113 | 8.9 | 7.2 | 60 | yes | 400 |
| 8 | 1.0 | 126 | 126 | 8.9 | 7.2 | 60 | yes | 400 |
| 9 | 1.0 | 126 | 126 | 8.9 | 7.3 | 60 | yes | 400 |
| 10 | 1.0 | 126 | 126 | 8.9 | 7.3 | 60 | yes | 400 |
| 11 | 1.1 | 126 | 139 | 8.7 | 7.2 | 61 | yes | 400 |
| 12 | 1.1 | 126 | 139 | 8.5 | 7.2 | 61 | yes | 400 |
| 13 | 1.1 | 126 | 139 | 8.4 | 7.2 | 61 | yes | 400 |
| 14 | 1.1 | 126 | 139 | 8.3 | 6.9 | 51 | yes | 400 |
| 15 | 1.2 | 126 | 151 | 8.4 | 6.9 | 51 | yes | 400 |
| 16 | 1.2 | 126 | 151 | 8.3 | 7.0 | 51 | yes | 400 |
| 17 | 1.2 | 126 | 151 | 8.0 | 6.9 | 51 | yes | 400 |
| 18 | 1.1 | 126 | 139 | 7.7 | 6.9 | 51 | yes | 400 |
| 19 | 1.2 | 126 | 151 | 7.1 | 6.9 | 51 | yes | 400 |
| 20 | 1.1 | 126 | 139 | 7.2 | 6.9 | 51 | yes | 400 |
| 21 | 1.2 | 126 | 151 | 6.8 | 6.4 | 42 | yes | 400 |
| 22 | 1.1 | 126 | 139 | 7.1 | 6.7 | 50 | yes | 400 |
| 23 | 1.3 | 126 | 164 | 7.3 | 6.9 | 52 | yes | 400 |
| 24 | 1.2 | 126 | 151 | 7.5 | 6.9 | 51 | yes | 400 |
| 25 | 1.1 | 126 | 139 | 7.8 | 6.9 | 51 | yes | 400 |
| 26 | 1.2 | 126 | 151 | 7.9 | 6.8 | 51 | yes | 400 |
| 27 | 1.2 | 126 | 151 | 8.0 | 6.8 | 51 | yes | 400 |
| 28 | 1.2 | 126 | 151 | 8.1 | 6.7 | 51 | yes | 400 |
| 29 | | | | | | | | |
| 30 | | | | | | | | |
| 31 | | | | | | | | |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350