

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas  
Month/Year: Mar-24

System Name		ID#: 4100326					WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]	
1	0.045	P/O	P/O	0.056	0.053	0.052	0.109	
2	0.067	0.151	0.086	0.048	0.060	0.040	0.245	
3	0.040	P/O	0.052	0.054	0.029	0.032	0.083	
4	0.041	P/O	P/O	0.052	0.033	0.032	0.101	
5	P/O	P/O	0.045	0.050	0.029	0.038	0.103	
6	P/O	P/O	0.063	0.033	0.031	0.039	0.103	
7	P/O	P/O	0.061	0.037	0.027	0.028	0.092	
8	0.041	0.059	0.093	0.038	0.028	0.028	0.109	
9	0.031	0.040	0.056	0.059	0.031	0.028	0.107	
10	0.033	P/O	P/O	0.045	0.058	0.035	0.110	
11	0.053	0.035	P/O	0.032	0.057	0.033	0.086	
12	0.031	0.039	0.037	0.051	0.031	0.041	0.099	
13	0.050	0.036	P/O	0.041	0.041	0.043	0.116	
14	0.028	P/O	0.029	0.042	0.025	0.030	0.092	
15	0.052	P/O	P/O	0.032	0.022	0.031	0.092	
16	0.043	0.023	P/O	0.021	0.031	0.049	0.079	
17	0.024	0.023	0.023	0.039	0.028	0.025	0.079	
18	0.053	0.124	0.054	0.025	0.024	0.035	0.158	
19	0.033	0.023	0.021	0.031	0.040	0.023	0.070	
20	0.025	0.037	0.058	0.025	0.021	0.027	0.072	
21	0.040	0.077	P/O	0.026	0.021	0.023	0.112	
22	0.033	0.044	0.062	0.026	0.021	0.022	0.070	
23	0.027	P/O	0.051	0.055	0.023	0.021	0.105	
24	0.025	0.033	0.047	0.099	0.034	0.023	0.162	
25	0.026	0.029	0.037	0.043	0.021	0.020	0.059	
26	0.025	0.044	P/O	0.026	0.019	0.022	0.062	
27	0.032	0.062	0.044	0.023	0.020	0.027	0.121	
28	0.050	0.029	0.038	0.037	0.051	0.036	0.094	
29	P/O	P/O	0.057	0.031	0.044	0.026	0.073	
30	0.028	P/O	0.050	0.038	0.023	0.020	0.068	
31	0.022	0.026	0.031	0.043	0.028	0.020	0.059	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE* triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF      DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 4-8-24
		PHONE #: ( 541 ) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#: **4100326** Month/Year: \_\_\_\_\_

Disinfection  
Giardia Log Inactive: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
3/1/2024 10:45	0.8	150	113	7	8.2	70	Yes	175
3/2/2024 21:36	0.7	150	106	7	8.4	77	Yes	175
3/3/2024 7:44	0.7	150	103	7	8.4	78	Yes	175
3/4/2024 7:56	0.8	150	117	6	8.3	76	Yes	175
3/5/2024 7:24	0.8	150	119	6	8.3	79	Yes	175
3/6/2024 19:07	0.9	150	128	6	8.1	73	Yes	175
3/7/2024 7:27	0.8	150	117	7	8.2	74	Yes	175
3/8/2024 8:42	0.7	150	98	7	8.2	72	Yes	175
3/9/2024 8:48	0.8	150	122	7	7.6	57	Yes	175
3/10/2024 10:28	0.8	150	119	8	8.1	66	Yes	175
3/11/2024 0:31	0.9	150	128	8	8.1	67	Yes	175
3/12/2024 23:41	0.9	150	134	8	8.1	64	Yes	175
3/13/2024 9:44	0.9	150	129	8	8.0	63	Yes	175
3/14/2024 8:59	0.8	150	125	8	8.3	71	Yes	175
3/15/2024 23:42	0.8	150	121	8	8.2	67	Yes	175
3/16/2024 9:06	0.8	150	115	8	8.2	65	Yes	175
3/17/2024 9:26	0.8	150	113	8	8.2	64	Yes	175
3/18/2024 23:49	0.8	150	124	8	8.3	66	Yes	175
3/19/2024 8:59	0.7	150	100	9	8.1	60	Yes	175
3/20/2024 8:07	0.9	150	137	9	8.1	60	Yes	175
3/21/2024 23:25	0.8	150	125	9	8.2	61	Yes	175
3/22/2024 9:08	0.8	150	119	9	8.2	62	Yes	175
3/23/2024 6:46	0.9	150	132	8	7.6	53	Yes	175
3/24/2024 7:56	0.9	150	131	8	7.7	53	Yes	175
3/25/2024 8:18	0.7	150	107	9	7.7	52	Yes	175
3/26/2024 3:16	0.8	150	121	9	8.4	68	Yes	175
3/27/2024 10:12	0.8	150	119	9	8.1	60	Yes	175
3/28/2024 7:58	0.8	150	119	9	8.0	59	Yes	175
3/29/2024 7:20	0.8	150	113	8	8.1	64	Yes	175
3/30/2024 6:22	0.8	150	125	9	8.2	63	Yes	175
3/31/2024 4:10	0.9	150	131	9	8.2	64	Yes	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350