

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: Apr-24

System Name		ID#: 4100326					WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.020	0.020	0.025	0.021	0.025	0.037	0.053	
2	0.027	0.023	0.022	0.019	0.018	0.018	0.029	
3	0.018	0.018	P/O	0.022	0.041	0.049	0.109	
4	0.022	0.019	0.020	0.018	0.018	0.019	0.025	
5	0.022	0.033	0.041	0.026	0.020	0.018	0.055	
6	0.019	P/O	0.020	0.022	0.024	0.035	0.085	
7	0.063	0.069	0.046	0.032	0.021	0.018	0.107	
8	0.018	0.019	0.020	0.038	0.043	0.052	0.160	
9	0.059	0.032	0.059	0.034	0.021	0.022	0.161	
10	0.021	P/O	0.021	0.023	0.027	0.032	0.086	
11	0.059	P/O	0.065	0.027	0.024	0.023	0.109	
12	0.023	0.024	P/O	0.025	0.026	0.027	0.040	
13	0.029	0.035	P/O	0.034	0.029	0.029	0.053	
14	0.029	0.029	P/O	0.031	0.033	0.039	0.062	
15	0.039	P/O	0.036	0.040	0.060	0.018	0.144	
16	0.018	P/O	0.019	0.026	0.019	0.018	0.047	
17	0.018	P/O	0.018	0.019	0.025	0.031	0.055	
18	0.047	0.052	0.072	0.023	0.018	0.018	0.081	
19	0.018	0.018	0.018	0.018	0.020	0.025	0.053	
20	0.033	0.046	P/O	0.030	0.020	0.018	0.064	
21	0.018	0.018	0.020	0.018	0.018	0.019	0.027	
22	0.023	0.029	0.029	0.023	0.020	0.020	0.038	
23	0.020	P/O	0.020	0.020	0.020	0.020	0.023	
24	0.020	0.021	P/O	0.025	0.023	0.022	0.034	
25	0.021	0.023	P/O	0.023	0.023	0.023	0.025	
26	0.024	0.023	P/O	0.025	0.028	0.021	0.038	
27	0.021	P/O	0.021	0.020	0.021	0.030	0.049	
28	0.024	0.021	0.021	0.021	0.021	0.022	0.031	
29	0.026	0.031	0.038	0.025	0.018	0.017	0.044	
30	0.017	P/O	0.023	0.023	0.018	0.018	0.046	
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? ²	<input checked="" type="radio"/> Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 5-7-24
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

System Name: **Glide Water Association**

ID#: **4100326**

Month/Year: **April 2024**

Disinfection
Giardia Log
Inactive: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
4/1/2024 5:06	0.9	150	132	9	8.3	65	Yes	175
4/2/2024 6:37	0.9	150	130	10	8.3	62	Yes	175
4/3/2024 10:27	0.8	150	125	10	8.3	59	Yes	175
4/4/2024 10:01	0.7	150	107	9	8.3	62	Yes	175
4/5/2024 11:01	0.9	150	137	8	8.2	67	Yes	175
4/6/2024 12:32	0.9	150	134	8	8.3	68	Yes	175
4/7/2024 11:28	0.9	150	135	9	8.3	67	Yes	175
4/8/2024 9:34	0.9	150	137	9	8.3	64	Yes	175
4/9/2024 12:15	0.9	150	130	10	8.5	66	Yes	175
4/10/2024 22:55	0.9	150	133	10	7.7	50	Yes	175
4/11/2024 7:35	0.9	150	128	10	8.2	57	Yes	175
4/12/2024 21:32	0.9	150	137	11	7.6	46	Yes	175
4/13/2024 12:05	0.9	150	131	11	7.9	51	Yes	175
4/14/2024 11:17	0.9	150	128	10	7.9	52	Yes	175
4/15/2024 11:14	0.9	150	134	10	8.2	59	Yes	175
4/16/2024 22:55	0.8	150	124	10	8.1	57	Yes	175
4/17/2024 9:14	0.7	150	107	9	7.6	48	Yes	175
4/18/2024 8:14	0.8	150	126	9	7.6	49	Yes	175
4/19/2024 7:41	0.9	150	133	11	7.6	45	Yes	175
4/20/2024 8:12	0.9	150	131	10	7.6	46	Yes	175
4/21/2024 7:32	0.9	150	130	11	7.6	46	Yes	175
4/22/2024 23:45	0.7	150	110	11	7.6	43	Yes	175
4/23/2024 7:21	0.7	150	106	12	7.6	42	Yes	175
4/24/2024 8:06	0.7	150	101	12	7.6	41	Yes	175
4/25/2024 10:12	0.8	150	116	11	7.6	43	Yes	175
4/26/2024 12:59	0.8	150	118	10	7.8	48	Yes	175
4/27/2024 12:57	0.8	150	122	10	7.8	50	Yes	175
4/28/2024 12:18	0.8	150	121	10	7.9	53	Yes	175
4/29/2024 8:52	0.8	150	124	10	8.0	54	Yes	175
4/30/2024 7:51	0.7	150	112	9	8.0	57	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dimce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018