

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Jun-24
 WTP : TP - A

System Name		ID#: 4100326					WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.019	0.018	0.018	0.018	0.016	0.019	0.031	
2	0.018	0.018	P/O	0.018	0.019	0.020	0.029	
3	0.019	P/O	0.020	0.019	0.019	0.023	0.034	
4	0.021	P/O	0.024	0.024	0.020	0.021	0.047	
5	0.025	P/O	0.082	0.033	0.025	0.029	0.147	
6	0.023	0.021	0.024	0.024	0.025	0.023	0.033	
7	0.024	0.026	0.027	0.022	0.016	0.016	0.073	
8	0.017	0.017	P/O	0.016	0.018	0.016	0.025	
9	0.016	0.016	P/O	0.018	0.017	0.016	0.025	
10	0.018	0.018	0.018	0.017	0.016	0.018	0.025	
11	0.018	0.018	0.018	0.020	0.018	0.018	0.025	
12	0.018	0.022	0.021	0.019	0.018	0.020	0.027	
13	0.020	P/O	0.022	0.018	0.019	0.018	0.031	
14	0.018	0.000	0.023	0.018	0.019	0.018	0.052	
15	0.018	0.018	0.018	0.020	0.018	0.017	0.029	
16	0.016	0.018	0.018	0.020	0.018	0.016	0.029	
17	0.017	0.018	0.026	0.018	0.016	0.016	0.039	
18	0.016	0.017	0.018	0.022	0.017	0.016	0.044	
19	0.017	0.021	0.020	0.019	0.016	0.016	0.028	
20	0.019	0.018	0.019	0.020	0.019	0.018	0.030	
21	0.018	P/O	0.019	0.021	0.019	0.018	0.028	
22	0.018	0.018	0.023	0.020	0.020	0.021	0.030	
23	0.021	P/O	0.022	0.022	0.022	0.023	0.031	
24	0.022	0.022	0.023	0.022	0.020	0.019	0.028	
25	0.018	P/O	0.018	0.021	0.018	0.019	0.031	
26	0.018	0.022	0.021	0.020	0.018	0.019	0.028	
27	0.021	0.020	0.021	0.019	0.020	0.020	0.028	
28	0.020	0.020	0.020	0.023	0.020	0.019	0.028	
29	0.020	0.022	0.024	0.021	0.020	0.022	0.031	
30	0.021	P/O	0.023	0.026	0.022	0.022	0.031	
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 7-10-24
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#:4100326 Month/Year: *June 2024*

Disinfection
Giardia Log Inactive 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
6/1/2024 6:29	0.8	150	119	15	7.6	34	Yes	175
6/2/2024 10:19	0.8	150	121	15	7.6	34	Yes	175
6/3/2024 23:49	0.7	150	110	14	7.4	34	Yes	175
6/4/2024 8:14	0.7	150	104	13	7.7	38	Yes	175
6/5/2024 11:10	0.7	150	106	13	7.5	35	Yes	175
6/6/2024 7:59	0.8	150	113	15	7.5	32	Yes	175
6/7/2024 9:40	0.7	150	104	16	7.6	30	Yes	175
6/8/2024 3:28	0.7	150	110	17	7.5	29	Yes	175
6/9/2024 2:50	0.8	150	116	17	7.6	29	Yes	175
6/10/2024 8:04	0.7	150	112	17	7.6	29	Yes	175
6/11/2024 6:52	0.7	150	110	17	7.6	28	Yes	175
6/12/2024 7:40	0.8	150	116	17	7.6	29	Yes	175
6/13/2024 6:59	0.7	150	112	17	7.6	30	Yes	175
6/14/2024 22:33	0.7	150	109	17	7.7	30	Yes	175
6/15/2024 4:11	0.7	150	104	16	7.6	31	Yes	175
6/16/2024 7:07	0.7	150	104	15	7.6	33	Yes	175
6/17/2024 6:56	0.7	150	110	14	7.6	36	Yes	175
6/18/2024 7:10	0.8	150	113	13	7.6	38	Yes	175
6/19/2024 7:14	0.7	150	112	16	7.6	32	Yes	175
6/20/2024 6:32	0.7	150	110	17	7.7	31	Yes	175
6/21/2024 6:06	0.7	150	107	18	7.7	29	Yes	175
6/22/2024 7:22	0.7	150	106	18	7.7	28	Yes	175
6/23/2024 7:22	0.7	150	103	18	7.8	30	Yes	175
6/24/2024 5:46	0.7	150	103	18	7.8	29	Yes	175
6/25/2024 7:14	0.6	150	97	18	7.8	29	Yes	175
6/26/2024 7:27	0.7	150	104	18	7.7	28	Yes	175
6/27/2024 6:51	0.7	150	107	17	7.8	31	Yes	175
6/28/2024 3:37	0.7	150	109	18	7.8	30	Yes	175
6/29/2024 5:39	0.7	150	107	18	7.8	30	Yes	175
6/30/2024 7:37	0.7	150	106	18	7.8	30	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

² If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmc@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350