

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: Oct-24
WTP : TP - A

System Name		ID#: 4100326					WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.018	P/O	0.019	0.020	0.020	0.018	0.034	
2	0.018	0.019	0.018	0.019	0.019	0.019	0.032	
3	0.018	0.018	0.022	0.019	0.018	0.019	0.038	
4	0.020	P/O	0.019	0.019	0.018	0.019	0.033	
5	0.018	P/O	0.018	0.019	0.018	0.018	0.033	
6	0.018	P/O	0.020	0.020	0.018	0.018	0.036	
7	0.019	P/O	0.019	0.018	0.018	0.018	0.055	
8	0.018	0.018	0.018	0.020	0.018	0.018	0.034	
9	0.018	P/O	0.021	0.020	0.018	0.018	0.038	
10	0.019	P/O	0.019	0.018	0.019	0.018	0.031	
11	0.018	P/O	0.020	0.023	0.018	0.018	0.164	
12	0.021	0.023	0.024	0.025	0.021	0.018	0.141	
13	0.018	0.022	0.029	0.027	0.020	0.019	0.036	
14	0.019	0.020	0.020	0.021	0.020	0.021	0.037	
15	0.023	0.021	0.021	0.020	0.022	0.020	0.037	
16	0.020	P/O	0.024	0.022	0.021	0.023	0.051	
17	0.022	P/O	0.023	0.024	0.022	0.022	0.037	
18	0.023	0.027	0.024	0.020	0.020	0.019	0.079	
19	0.019	P/O	0.019	0.018	0.020	0.018	0.033	
20	0.018	0.018	P/O	0.021	0.018	0.018	0.034	
21	0.020	P/O	0.018	0.018	0.020	0.019	0.022	
22	0.018	0.018	0.018	0.022	0.019	0.018	0.034	
23	0.021	0.020	0.020	0.020	0.018	0.020	0.033	
24	0.020	0.019	0.020	0.018	0.020	0.018	0.034	
25	0.018	0.018	P/O	0.024	0.018	0.018	0.036	
26	0.020	0.020	0.020	0.020	0.020	0.020	0.033	
27	0.020	0.020	0.020	P/O	0.020	0.020	0.250	
28	P/O	0.020	0.020	0.020	P/O	0.020	0.080	
29	0.020	P/O	0.020	0.020	0.020	0.020	0.080	
30	0.020	P/O	0.020	0.020	0.020	0.020	0.070	
31	P/O	P/O	0.020	0.020	0.020	0.020	0.033	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 11-10-24
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

Disinfection
Giardia Log
Inactive. 1.0

System Name: **Glide Water Association** ID#:4100326 Month/Year: Oct-24

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
10/1/2024 8:57	0.7	150	100	13	8.4	51	Yes	175
10/2/2024 10:42	0.7	150	98	13	8.3	49	Yes	175
10/3/2024 2:44	0.7	150	107	12	8.3	52	Yes	175
10/4/2024 16:12	0.7	150	112	12	8.4	53	Yes	175
10/5/2024 11:20	0.7	150	106	12	8.3	50	Yes	175
10/6/2024 10:40	0.7	150	103	12	8.2	49	Yes	175
10/7/2024 8:24	0.7	150	103	12	8.3	50	Yes	175
10/8/2024 11:02	0.7	150	103	12	8.2	49	Yes	175
10/9/2024 13:22	0.7	150	104	13	8.3	49	Yes	175
10/10/2024 11:56	0.7	150	106	13	8.3	49	Yes	175
10/11/2024 12:07	0.7	150	107	13	8.3	50	Yes	175
10/12/2024 13:33	0.7	150	106	13	8.1	46	Yes	175
10/13/2024 10:53	0.7	150	104	13	8.3	50	Yes	175
10/14/2024 22:49	0.3	150	52	12	8.1	45	Yes	175
10/15/2024 22:54	0.5	150	80	13	7.9	43	Yes	175
10/16/2024 8:01	0.5	150	80	13	8.0	43	Yes	175
10/17/2024 6:21	0.7	150	104	12	7.9	44	Yes	175
10/18/2024 17:47	0.5	150	80	11	7.9	46	Yes	175
10/19/2024 7:12	0.7	150	110	11	7.9	48	Yes	175
10/20/2024 9:06	0.8	150	115	12	8.0	47	Yes	175
10/21/2024 22:23	0.7	150	104	12	7.9	46	Yes	175
10/22/2024 20:10	0.7	150	98	12	7.8	45	Yes	175
10/23/2024 9:17	0.7	150	98	10	7.9	50	Yes	175
10/24/2024 7:19	0.6	150	97	10	7.9	50	Yes	175
10/25/2024 8:11	0.7	150	103	9	7.9	54	Yes	175
10/26/2024 22:46	0.7	150	104	10	8.0	54	Yes	175
10/27/2024 12:21	0.7	150	100	11	7.9	49	Yes	175
10/28/2024 2:34	0.7	150	101	11	7.9	48	Yes	175
10/29/2024 8:26	0.7	150	99	11	8.1	52	Yes	175
10/30/2024 9:51	0.7	150	104	10	8.1	55	Yes	175
10/31/2024 20:50	0.7	150	98	9	8.1	56	Yes	175

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwo.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350