

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Douglas**  
Month/Year: **Dec-24**

System Name <b>Glide Water Association</b>		ID#: <b>4100326</b>		WTP : <b>TP - A</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.027	0.027	0.027	0.028	0.028	0.038	0.237
2	0.031	0.031	0.032	0.019	0.015	0.015	0.170
3	0.026	0.018	0.016	0.016	0.015	0.015	0.037
4	0.015	0.015	0.015	0.027	0.017	0.016	0.151
5	0.015	0.015	0.016	0.018	0.017	0.016	0.024
6	0.015	0.016	0.016	0.015	0.016	0.016	0.026
7	0.015	0.015	P/O	0.015	0.015	0.015	0.016
8	0.015	0.015	0.015	0.037	0.025	0.023	0.279
9	0.025	0.024	P/O	0.019	0.016	0.015	0.118
10	0.015	0.015	0.015	0.015	0.018	0.016	0.048
11	0.015	0.015	0.030	0.015	0.019	0.016	0.098
12	0.015	P/O	0.015	0.020	0.018	0.016	0.042
13	0.016	0.016	0.016	0.017	0.019	0.018	0.124
14	0.018	0.018	0.018	0.018	0.022	0.020	0.072
15	0.023	0.022	0.022	0.018	0.019	0.024	0.081
16	0.021	P/O	0.020	0.021	0.026	0.022	0.081
17	0.023	P/O	0.024	0.027	0.026	0.024	0.057
18	0.023	0.030	0.043	0.029	0.026	0.025	0.085
19	0.025	0.024	0.030	0.026	0.032	0.028	0.118
20	0.029	0.028	0.028	0.022	0.017	0.024	0.060
21	0.020	P/O	0.020	0.010	P/O	0.020	0.030
22	0.020	P/O	P/O	0.010	0.010	0.020	0.050
23	0.020	P/O	0.020	0.020	0.020	P/O	0.150
24	P/O	0.010	P/O	P/O	0.020	0.020	0.230
25	P/O	0.020	P/O	P/O	0.020	0.020	0.080
26	P/O	P/O	P/O	P/O	0.020	0.020	0.180
27	0.030	P/O	0.030	0.020	0.020	P/O	0.120
28	0.020	P/O	0.020	0.020	0.020	P/O	0.050
29	P/O	0.020	0.020	0.030	0.030	P/O	0.080
30	0.020	0.020	P/O	0.020	0.020	0.020	0.080
31	P/O	0.020	P/O	0.020	0.030	0.020	0.040

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: <b>Jonathan Woody</b>	
Notes: P/O = PLANT OFF      DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: <b>1-10-25</b>
		PHONE #: ( 541 ) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A  
 Disinfection  
 Giardia Log  
 Inactive 1.0

System Name: **Glide Water Association** ID#: **4100326** Month/Year:

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (m) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
12/1/24 9:06	1.3	150	194	6	8.3	83	Yes	175
12/2/24 17:52	1.0	150	147	5	8.2	81	Yes	175
12/3/24 5:41	0.9	150	128	6	8.3	80	Yes	175
12/4/24 1:11	0.9	150	138	6	8.3	80	Yes	175
12/5/2024 22:34	0.9	150	135	6	8.2	80	Yes	175
12/6/2024 17:11	0.8	150	125	6	8.2	76	Yes	175
12/7/2024 0:31	1.1	150	161	6	8.1	73	Yes	175
12/8/2024 22:58	1.0	150	147	7	8.1	71	Yes	175
12/9/2024 23:05	0.9	150	135	6	8.1	73	Yes	175
12/10/2024 8:07	0.9	150	132	5	8.2	78	Yes	175
12/11/2024 23:38	0.9	150	135	5	8.2	80	Yes	175
12/12/2024 6:40	0.8	150	127	6	8.1	75	Yes	175
12/13/2024 23:29	1.0	150	156	7	8.2	74	Yes	175
12/14/2024 23:30	0.9	150	141	7	8.0	67	Yes	175
12/15/2024 23:10	0.9	150	134	8	8.0	63	Yes	175
12/16/2024 13:38	0.8	150	119	8	8.0	62	Yes	175
12/17/2024 22:43	0.8	150	115	8	8.0	59	Yes	175
12/18/2024 9:54	0.7	150	112	9	8.1	58	Yes	175
12/19/2024 22:17	0.9	150	141	9	8.1	62	Yes	175
12/20/2024 19:48	0.7	150	110	9	8.1	61	Yes	175
12/21/2024 8:28	0.7	150	104	9	8.2	60	Yes	175
12/22/2024 7:40	0.8	150	113	9	8.1	60	Yes	175
12/23/2024 9:26	0.8	150	113	9	8.1	57	Yes	175
12/24/2024 5:37	0.8	150	118	9	8.0	56	Yes	175
12/25/2024 6:13	0.8	150	124	9	8.1	61	Yes	175
12/26/2024 17:00	0.8	150	127	9	8.1	61	Yes	175
12/27/2024 9:36	0.8	150	113	9	8.0	56	Yes	175
12/28/2024 8:44	0.9	150	141	10	8.0	55	Yes	175
12/29/2024 23:20	0.8	150	122	9	8.0	56	Yes	175
12/30/2024 1:35	1.0	150	143	9	8.0	61	Yes	175
12/31/2024 5:44	1.0	150	152	8	8.6	79	Yes	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dnce@state.or.us, 971-673-0694 or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350