

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jan-25**

System Name Glide Water Association		ID#: 4100326		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.022	0.034	0.028	0.023	0.022	0.022	0.048
2	0.022	0.030	P/O	0.029	0.025	0.023	0.048
3	0.022	0.022	P/O	0.031	0.026	0.025	0.103
4	0.031	0.026	0.026	0.024	0.024	0.042	0.322
5	0.035	0.029	P/O	0.036	0.029	0.028	0.052
6	0.037	0.033	0.031	0.029	0.036	0.032	0.072
7	0.031	0.030	0.044	0.035	0.042	0.037	0.052
8	0.037	P/O	0.042	0.020	0.024	0.018	0.068
9	0.024	0.018	0.017	0.022	0.020	0.022	0.037
10	0.018	0.031	0.026	0.060	0.026	0.020	0.118
11	0.020	0.016	P/O	0.021	0.016	0.020	0.042
12	0.016	0.016	0.024	0.020	0.017	0.022	0.031
13	0.018	0.016	0.021	0.020	0.017	0.025	0.033
14	0.018	P/O	0.016	0.022	0.018	0.016	0.039
15	0.022	0.018	0.018	0.017	0.027	0.021	0.042
16	0.030	0.022	0.033	0.023	0.022	0.026	0.042
17	0.022	0.035	P/O	0.023	0.024	0.020	0.050
18	0.020	0.024	P/O	0.021	0.024	0.021	0.033
19	0.018	0.026	0.023	0.021	0.020	0.025	0.033
20	0.021	0.020	P/O	0.027	0.022	0.026	0.035
21	0.024	P/O	0.000	0.037	0.061	0.053	0.120
22	0.031	0.039	0.079	0.024	0.024	0.029	0.115
23	0.025	0.025	P/O	0.028	0.026	0.031	0.045
24	0.027	0.026	P/O	0.037	0.028	P/O	0.048
25	0.030	P/O	P/O	0.028	0.031	P/O	0.046
26	0.035	P/O	P/O	0.031	0.039	0.033	0.046
27	0.037	P/O	0.037	0.035	0.017	0.024	0.089
28	0.017	P/O	0.022	0.017	0.019	0.017	0.155
29	0.027	0.026	P/O	0.037	P/O	0.022	0.300
30	0.022	P/O	0.029	0.020	P/O	0.022	0.031
31	0.022	P/O	P/O	0.023	P/O	0.027	0.042

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>John Woody</i>	DATE: 2-9-25
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-081-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#:4100326 Month/Year: Jan-25
 Disinfection Giardia Log Inactive: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1/1/2025 2:47	1.1	150	159	8	8.6	81	Yes	175
1/2/2025 20:24	0.8	150	118	8	8.6	76	Yes	175
1/3/2025 7:46	0.7	150	110	9	8.5	68	Yes	175
1/4/2025 0:38	0.8	150	119	9	8.6	71	Yes	175
1/5/2025 9:41	0.9	150	135	9	8.5	71	Yes	175
1/6/2025 21:48	0.9	150	141	10	8.5	69	Yes	175
1/7/2025 22:46	0.8	150	125	8	8.6	74	Yes	175
1/8/2025 7:29	0.8	150	115	8	8.6	76	Yes	175
1/9/2025 23:20	0.7	150	112	8	8.6	77	Yes	175
1/10/2025 9:50	0.7	150	103	7	8.1	65	Yes	175
1/11/2025 10:19	0.9	150	129	8	8.2	68	Yes	175
1/12/2025 2:48	0.9	150	141	7	8.3	73	Yes	175
1/13/2025 7:58	1.0	150	143	7	8.2	75	Yes	175
1/14/2025 6:54	0.9	150	140	6	8.2	77	Yes	175
1/15/2025 23:44	0.8	150	122	6	8.5	83	Yes	175
1/16/25 7:55	0.7	150	107	6	8.1	71	Yes	175
1/17/2025 21:58	0.9	150	135	7	8.1	71	Yes	175
1/18/2025 10:26	0.8	150	126	6	8.1	74	Yes	175
1/19/2025 0:47	0.8	150	125	5	8.1	78	Yes	175
1/20/2025 23:44	0.8	150	122	6	8.0	70	Yes	175
1/21/25 18:42	0.8	150	114	4	8.4	93	Yes	175
1/22/25 23:21	1.0	150	147	4	8.5	97	Yes	175
1/23/2025 21:58	0.9	150	135	7	8.1	71	Yes	175
1/24/2025 10:26	0.8	150	126	6	8.1	74	Yes	175
1/25/2025 0:47	0.8	150	125	5	8.1	78	Yes	175
1/26/2025 8:25	0.9	150	129	5	8.0	79	Yes	175
1/27/2025 20:19	0.7	150	103	4	8.4	94	Yes	175
1/28/2025 21:40	0.8	150	119	4	8.5	96	Yes	175
1/29/25 23:58	0.7	150	98	4	8.5	96	Yes	175
1/30/25 10:54	0.7	150	98	4	8.4	91	Yes	175
1/31/2025 18:28	1.0	150	146	5	8.3	89	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350