

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Feb-25**
 WTP : TP - **A**

System Name	ID#: 4100326						WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	P/O	P/O	0.040	P/O	P/O	0.038	0.068
2	P/O	P/O	0.040	P/O	P/O	0.038	0.068
3	0.046	P/O	P/O	0.020	0.033	0.018	0.077
4	0.022	P/O	0.018	0.022	0.020	0.016	0.073
5	0.018	P/O	0.016	0.036	0.018	P/O	0.038
6	0.020	P/O	0.016	0.027	P/O	0.014	0.040
7	0.022	P/O	0.018	0.029	0.018	P/O	0.040
8	0.020	P/O	P/O	0.016	0.022	0.018	0.040
9	P/O	0.023	P/O	0.018	P/O	0.020	0.037
10	P/O	P/O	0.025	0.022	0.018	0.016	0.038
11	P/O	P/O	0.020	0.018	0.018	0.023	0.038
12	P/O	P/O	0.020	P/O	0.020	0.018	0.037
13	P/O	0.036	P/O	0.018	0.025	P/O	0.040
14	0.018	P/O	0.038	0.022	0.018	0.023	0.083
15	0.022	0.029	P/O	0.022	0.023	0.022	0.055
16	0.025	P/O	P/O	0.029	P/O	P/O	0.059
17	P/O	P/O	P/O	P/O	0.022	0.024	0.057
18	0.025	0.033	P/O	0.027	0.044	P/O	0.086
19	0.047	P/O	0.029	0.037	0.037	0.037	0.079
20	P/O	P/O	P/O	0.111	0.016	0.022	0.124
21	0.018	P/O	P/O	P/O	0.020	0.040	0.055
22	P/O	P/O	0.044	0.020	P/O	0.020	0.046
23	0.018	0.031	P/O	0.022	0.027	P/O	0.087
24	0.059	0.038	0.094	0.022	0.033	0.022	0.179
25	0.031	0.018	0.022	0.031	0.018	0.024	0.062
26	P/O	0.020	P/O	0.021	0.016	0.022	0.060
27	P/O	0.023	P/O	P/O	0.029	0.020	0.053
28	P/O	P/O	0.029	0.018	0.029	0.020	0.055

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	<input checked="" type="radio"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED	SIGNATURE: <i>Jonathan Woody</i>		DATE: 3-9-25
	PHONE #: (541) 643-6137		CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#: **4100326** Month/Year: **Feb-2025**
 Disinfection: **Giardia Log Inactive: 1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
2/1/2025 20:18	1.4	150	215	6	8.2	84	Yes	175
2/2/2025 11:58	1.4	150	207	7	8.2	75	Yes	175
2/3/2025 23:49	1.3	150	194	6	8.4	87	Yes	175
2/4/2025 8:22	1.1	150	170	5	8.5	92	Yes	175
2/5/2025 11:52	1.2	150	174	5	8.5	93	Yes	175
2/6/2025 22:29	1.1	150	170	6	8.4	88	Yes	175
2/7/2025 0:32	1.1	150	171	6	8.5	90	Yes	175
2/8/2025 1:33	1.3	150	194	6	8.5	90	Yes	175
2/9/2025 20:59	1.3	150	200	6	8.5	90	Yes	175
2/10/2025 22:31	1.0	150	152	5	8.4	89	Yes	175
2/11/2025 4:20	1.1	150	167	5	8.3	88	Yes	175
2/12/2025 7:21	1.1	150	170	4	8.3	92	Yes	175
2/13/2025 5:57	1.2	150	173	4	8.1	86	Yes	175
2/14/2025 23:34	1.3	150	197	6	9.1	116	Yes	175
2/15/2025 5:32	1.3	150	192	6	8.2	79	Yes	175
2/16/2025 8:42	1.3	150	197	7	8.2	77	Yes	175
2/17/2025 23:13	1.2	150	179	7	8.3	74	Yes	175
2/18/2025 3:15	1.2	150	177	8	8.2	69	Yes	175
2/19/2025 9:16	1.2	150	173	8	8.1	67	Yes	175
2/20/2025 23:45	1.2	150	173	8	8.4	72	Yes	175
2/21/2025 6:01	1.1	150	165	8	8.4	77	Yes	175
2/22/2025 6:32	1.2	150	174	8	8.1	66	Yes	175
2/23/2025 23:11	1.2	150	177	9	8.1	64	Yes	175
2/24/2025 10:09	1.2	150	174	9	8.1	62	Yes	175
2/25/2025 22:43	1.2	150	179	8	8.2	68	Yes	175
2/26/2025 23:00	1.1	150	170	8	8.3	73	Yes	175
2/27/2025 5:29	1.1	150	167	8	8.3	71	Yes	175
2/28/2025 8:52	1.1	150	161	8	8.2	68	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours. Revised July 2018
 Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us 971-673-0694; or Drinking Water Services PO Box 14350 Portland, OR 97293-0350