

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: May-25

System Name Glide Water Association

ID#: 4100326

WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.042	P/O	0.037	0.018	P/O	P/O	0.042
2	P/O	P/O	0.024	0.018	0.018	0.016	0.031
3	P/O	P/O	P/O	0.018	P/O	P/O	0.037
4	P/O	P/O	0.018	0.016	0.016	0.016	0.027
5	P/O	P/O	0.020	0.016	0.016	P/O	0.029
6	P/O	P/O	P/O	0.018	0.016	0.018	0.061
7	0.018	P/O	0.018	0.020	0.018	P/O	0.042
8	0.020	P/O	0.020	0.027	0.018	P/O	0.031
9	0.020	P/O	0.020	0.018	0.018	0.018	0.026
10	0.018	P/O	0.025	P/O	0.018	P/O	0.031
11	0.020	P/O	P/O	0.020	0.029	0.020	0.029
12	P/O	P/O	0.020	0.026	P/O	P/O	0.031
13	P/O	P/O	0.024	P/O	P/O	0.020	0.033
14	0.022	0.024	0.022	0.022	P/O	P/O	0.033
15	0.024	P/O	0.018	P/O	P/O	0.018	0.055
16	P/O	P/O	P/O	P/O	0.018	P/O	0.031
17	P/O	P/O	P/O	P/O	0.016	0.016	0.037
18	P/O	P/O	0.022	0.018	0.018	0.018	0.029
19	0.018	P/O	0.018	0.018	0.020	P/O	0.035
20	P/O	P/O	P/O	P/O	0.024	0.020	0.061
21	0.022	0.033	P/O	0.022	0.020	0.022	0.040
22	0.024	P/O	0.024	0.022	0.022	P/O	0.035
23	0.027	P/O	0.031	0.027	0.022	0.024	0.044
24	0.025	P/O	P/O	0.029	0.027	P/O	0.042
25	0.029	P/O	0.029	0.029	0.035	0.031	0.038
26	P/O	P/O	P/O	0.035	0.033	0.038	0.048
27	0.037	P/O	0.037	0.037	0.037	0.037	0.044
28	P/O	P/O	0.044	0.042	0.042	0.044	0.050
29	0.046	P/O	0.048	P/O	0.018	0.015	0.055
30	0.016	P/O	0.018	P/O	0.015	0.016	0.024
31	P/O	P/O	0.016	0.020	0.016	0.015	0.026

Conventional or Direct Filtration 95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ² <u>Yes</u> / No All 4-hour turbidity readings $\leq$ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE ² triggers <u>Yes</u> / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <u>Yes</u> / No All Cl ₂ residual at entry point $\geq$ 0.2 mg/l? <u>Yes</u> / No	
Notes: P/O = PLANT OFF DV = DIVERTED		PRINTED NAME: Jonathan Woody SIGNATURE: <u>Jonathan Woody</u> PHONE #: (541) 643-6137 DATE: 6-9-25 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

Disinfection

Giardia Log

Inactive:

1.0

System Name: Glide Water Association

ID#:4100326

Month/Year: May 2025

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
5/1/2025 7:17	0.8	150	121	11	7.8	45	Yes	175
5/2/2025 9:02	0.8	150	122	12	7.7	43	Yes	175
5/3/2025 10:12	0.8	150	116	12	7.7	42	Yes	175
5/4/2025 6:24	0.8	150	113	11	7.7	46	Yes	175
5/5/2025 3:19	0.8	150	115	11	7.8	47	Yes	175
5/6/2025 7:21	0.8	150	118	12	7.7	43	Yes	175
5/7/2025 8:52	0.8	150	116	12	8.6	57	Yes	175
5/8/2025 9:32	0.8	150	116	13	7.9	43	Yes	175
5/9/2025 9:23	0.8	150	116	13	8.0	43	Yes	175
5/10/2025 6:50	0.8	150	125	13	7.9	43	Yes	175
5/11/2025 10:26	0.8	150	125	13	7.9	43	Yes	175
5/12/2025 23:42	0.8	150	115	12	7.9	46	Yes	175
5/13/2025 6:09	0.8	150	113	11	8.0	51	Yes	175
5/14/2025 9:20	0.8	150	115	11	8.1	51	Yes	175
5/15/2025 7:35	0.8	150	119	11	8.0	49	Yes	175
5/16/2025 6:16	0.8	150	119	12	8.1	50	Yes	175
5/17/2025 11:39	0.8	150	122	13	8.0	46	Yes	175
5/18/2025 2:55	0.8	150	122	12	8.1	48	Yes	175
5/19/2025 9:26	0.8	150	122	11	8.0	49	Yes	175
5/20/2025 23:44	0.8	150	115	12	7.9	45	Yes	175
5/21/2025 4:19	0.7	150	110	12	7.9	44	Yes	175
5/22/2025 8:55	0.6	150	88	13	7.8	42	Yes	175
5/23/2025 7:24	0.7	150	101	13	8.0	45	Yes	175
5/24/2025 6:17	0.8	150	119	13	8.0	43	Yes	175
5/25/2025 10:17	0.8	150	119	14	7.9	41	Yes	175
5/26/2025 6:15	0.8	150	122	14	8.0	43	Yes	175
5/27/2025 21:49	0.8	150	118	14	8.1	41	Yes	175
5/28/2025 6:25	0.7	150	110	15	8.1	40	Yes	175
5/29/2025 6:20	0.7	150	109	15	7.9	37	Yes	175
5/30/2025 7:55	0.7	150	110	15	7.9	37	Yes	175
5/31/2025 9:00	0.7	150	109	15	7.9	36	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350