

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Douglas

Month/Year: Jul-25

System Name Glide Water Association

ID#: 4100326

WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.022	P/O	0.028	0.022	P/O	0.028	0.035
2	0.028	P/O	0.027	0.029	0.031	0.035	0.040
3	0.037	P/O	0.020	P/O	0.022	0.022	0.042
4	P/O	P/O	P/O	0.022	0.022	P/O	0.029
5	P/O	P/O	P/O	0.024	P/O	0.026	0.033
6	0.026	P/O	P/O	0.042	0.042	0.042	0.042
7	0.042	P/O	P/O	P/O	0.018	0.018	0.072
8	P/O	0.062	0.079	0.026	0.026	0.026	0.088
9	P/O	0.026	0.029	0.026	P/O	0.026	0.042
10	0.029	P/O	0.052	P/O	0.031	0.031	0.083
11	0.031	P/O	0.055	0.035	0.035	0.039	0.059
12	0.039	P/O	0.050	0.044	0.046	0.050	0.064
13	0.055	P/O	0.072	0.070	0.070	0.070	0.079
14	0.070	P/O	0.038	0.020	0.020	P/O	0.070
15	0.022	P/O	0.029	0.020	P/O	0.022	0.031
16	P/O	0.024	P/O	0.018	0.022	0.022	0.039
17	0.020	P/O	0.042	0.020	P/O	0.026	0.046
18	0.024	P/O	P/O	0.018	0.020	0.022	0.045
19	0.022	P/O	0.027	0.022	0.020	P/O	0.031
20	0.024	0.028	0.033	0.024	0.026	0.026	0.035
21	0.026	P/O	0.038	P/O	0.018	0.020	0.046
22	P/O	P/O	0.040	P/O	0.020	0.020	0.042
23	P/O	0.020	0.044	P/O	P/O	0.022	0.050
24	0.020	P/O	P/O	0.020	0.020	0.024	0.052
25	0.024	P/O	0.042	0.016	P/O	0.020	0.048
26	0.018	P/O	0.037	0.018	0.018	0.020	0.039
27	0.020	P/O	0.044	0.020	0.020	0.024	0.046
28	0.024	P/O	0.040	0.018	P/O	0.018	0.044
29	0.018	0.016	0.027	0.016	0.018	0.018	0.029
30	0.024	0.020	0.029	0.020	P/O	0.020	0.029
31	0.018	0.020	0.028	0.020	0.020	0.022	0.057

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ²

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Notes: P/O = PLANT OFF

DV = DIVERTED

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes / No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?

Yes / No

PRINTED NAME: Jonathan Woody

SIGNATURE:

John Woody

DATE: 8-8-2025

PHONE #: (541) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

Disinfection
Giardia Log
Inactive

1.0

System Name: **Glide Water Association**

ID#: **4100326**

Month/Year: **July 2025**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
7/1/2025 5:57	0.7	150	108	20	8.3	31	Yes	175
7/2/2025 9:25	0.7	150	106	20	8.3	31	Yes	175
7/3/2025 6:33	0.7	150	107	19	8.3	34	Yes	175
7/4/2025 5:57	0.7	150	104	18	8.4	36	Yes	175
7/5/2025 3:22	0.7	150	106	18	8.3	36	Yes	175
7/6/2025 7:29	0.7	150	107	18	8.3	36	Yes	175
7/7/2025 7:29	0.7	150	109	18	8.3	34	Yes	175
7/8/2025 9:47	0.7	150	106	19	8.4	34	Yes	175
7/9/2025 9:49	0.7	150	109	19	8.4	33	Yes	175
7/10/2025 8:14	0.7	150	109	19	8.5	35	Yes	175
7/11/2025 7:34	0.7	150	107	19	8.4	33	Yes	175
7/12/2025 8:55	0.7	150	108	20	8.4	33	Yes	175
7/13/2025 9:28	0.7	150	109	20	8.5	33	Yes	175
7/14/2025 7:40	0.7	150	105	20	8.5	32	Yes	175
7/15/2025 8:27	0.7	150	109	20	8.5	32	Yes	175
7/16/2025 5:40	0.7	150	111	20	8.5	33	Yes	175
7/17/2025 6:54	0.7	150	111	20	8.5	33	Yes	175
7/18/2025 6:57	0.7	150	112	20	8.5	34	Yes	175
7/19/2025 8:26	0.7	150	111	19	8.6	35	Yes	175
7/20/2025 9:16	0.8	150	114	19	8.5	34	Yes	175
7/21/2025 7:41	0.8	150	113	19	8.5	36	Yes	175
7/22/2025 6:57	0.7	150	109	18	8.6	37	Yes	175
7/23/2025 5:21	0.7	150	110	19	8.5	35	Yes	175
7/24/2025 7:28	0.8	150	113	19	8.5	35	Yes	175
7/25/2025 7:15	0.8	150	113	19	8.5	35	Yes	175
7/26/2025 6:50	0.8	150	113	19	8.5	35	Yes	175
7/27/2025 6:55	0.8	150	113	19	8.5	35	Yes	175
7/28/2025 10:53	0.7	150	112	19	8.5	36	Yes	175
7/29/2025 5:05	0.7	150	112	19	8.4	34	Yes	175
7/30/2025 10:32	0.8	150	115	19	8.5	34	Yes	175
7/31/2025 7:22	0.7	150	112	19	8.5	34	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us, 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350