

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Douglas

Month/Year: Sep-25

System Name Glide Water Association

ID#: 4100326

WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.016	0.016	0.024	P/O	0.018	0.020	0.166
2	0.018	0.016	0.018	0.018	0.016	0.020	0.024
3	P/O	0.020	P/O	P/O	0.018	0.020	0.040
4	0.018	0.016	0.018	0.018	0.018	0.020	0.024
5	P/O	0.020	0.018	P/O	0.018	0.020	0.033
6	0.018	0.018	P/O	0.018	P/O	P/O	0.026
7	P/O	0.018	0.020	P/O	0.016	0.020	0.029
8	P/O	P/O	0.018	0.016	P/O	0.018	0.026
9	0.020	0.018	P/O	0.022	P/O	0.026	0.052
10	P/O	P/O	P/O	0.029	P/O	0.033	0.039
11	P/O	P/O	0.026	P/O	0.020	0.022	0.053
12	P/O	0.022	0.020	0.020	P/O	P/O	0.055
13	0.020	P/O	0.020	0.018	0.018	P/O	0.035
14	P/O	0.020	P/O	P/O	P/O	0.020	0.035
15	P/O	0.020	0.020	P/O	P/O	P/O	0.035
16	P/O	P/O	0.020	P/O	P/O	P/O	0.035
17	0.020	P/O	0.020	0.018	0.020	P/O	0.027
18	P/O	0.020	0.020	0.020	P/O	P/O	0.042
19	P/O	P/O	0.022	0.018	P/O	0.020	0.029
20	P/O	0.018	P/O	P/O	0.020	P/O	0.033
21	P/O	0.018	P/O	0.020	P/O	0.020	0.033
22	0.018	P/O	0.024	P/O	P/O	P/O	0.033
23	P/O	P/O	0.022	0.020	0.018	0.018	0.033
24	0.020	P/O	P/O	0.018	P/O	P/O	0.026
25	P/O	0.020	0.022	0.037	0.018	0.018	0.037
26	P/O	0.020	0.025	0.020	0.018	0.018	0.042
27	P/O	P/O	P/O	0.020	0.020	0.018	0.031
28	0.018	P/O	0.037	0.018	P/O	0.018	0.046
29	0.020	P/O	0.024	0.020	0.020	P/O	0.029
30	P/O	0.020	0.020	P/O	0.018	0.020	0.025

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ²

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Notes: P/O = PLANT OFF

DV = DIVERTED

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes / No

All Cl2 residual at entry point $\geq$ 0.2 mg/l?

Yes / No

PRINTED NAME: Jonathan Woody

SIGNATURE: *John Woody*

DATE: 10-9-25

PHONE #: (41) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indivd Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: Glide Water Association

ID#:4100326

Month/Year:

Disinfection

Giardia Log

Inactive

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (m)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
9/1/2025 8:06	0.8	150	119	17	8.6	41	Yes	175
9/2/2025 7:34	0.8	150	113	18	8.5	40	Yes	175
9/3/2025 4:49	0.8	150	113	18	8.4	37	Yes	175
9/4/2025 7:07	0.8	150	114	18	8.5	38	Yes	175
9/5/2025 4:30	0.8	150	115	18	8.5	38	Yes	175
9/6/2025 7:06	0.8	150	113	18	8.5	38	Yes	175
9/7/2025 8:32	0.7	150	110	18	8.6	39	Yes	175
9/8/2025 6:28	0.8	150	114	17	8.5	39	Yes	175
9/9/2025 9:11	0.8	150	113	17	8.5	40	Yes	175
9/10/2025 5:38	0.8	150	113	16	8.5	42	Yes	175
9/11/2025 15:44	0.7	150	107	16	8.5	43	Yes	175
9/12/2025 23:44	0.8	150	113	16	8.5	42	Yes	175
9/13/2025 6:04	0.7	150	109	16	8.5	43	Yes	175
9/14/2025 11:04	0.7	150	110	16	8.4	41	Yes	175
9/15/2025 3:34	0.7	150	110	16	8.4	42	Yes	175
9/16/2025 9:39	0.7	150	107	15	8.4	45	Yes	175
9/17/2025 9:13	0.7	150	112	15	8.4	45	Yes	175
9/18/2025 4:30	0.8	150	113	15	8.6	46	Yes	175
9/19/2025 8:54	0.7	150	112	15	8.4	44	Yes	175
9/20/2025 10:21	0.7	150	110	16	8.5	44	Yes	175
9/21/2025 10:01	0.7	150	110	16	8.4	43	Yes	175
9/22/2025 10:09	0.7	150	109	14	8.4	47	Yes	175
9/23/2025 5:31	0.7	150	110	14	8.3	45	Yes	175
9/24/2025 6:55	0.7	150	112	14	8.4	47	Yes	175
9/25/2025 10:18	0.8	150	125	14	8.3	45	Yes	175
9/26/2025 23:22	0.8	150	121	14	8.3	47	Yes	175
9/27/2025 6:25	0.8	150	116	13	8.4	49	Yes	175
9/28/2025 6:56	0.8	150	121	13	8.4	49	Yes	175
9/29/2025 21:50	0.7	150	112	14	8.2	45	Yes	175
9/30/2025 9:02	0.8	150	113	13	8.3	48	Yes	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us 971-673-0694, or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350