

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Douglas**  
Month/Year: **Feb-21**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	P/O	P/O	0.022	0.028	0.033	0.022	0.072
2	0.033	0.023	P/O	0.019	0.025	0.022	0.068
3	0.020	P/O	P/O	0.022	0.031	0.027	0.076
4	0.023	0.035	0.027	0.024	0.022	0.034	0.089
5	0.026	0.024	P/O	0.025	0.033	0.025	0.085
6	0.024	P/O	0.032	0.031	0.026	0.024	0.081
7	0.033	0.031	P/O	0.027	0.026	0.035	0.076
8	0.030	P/O	0.027	0.025	0.027	0.022	0.068
9	0.020	P/O	0.019	0.032	0.024	0.021	0.070
10	0.020	P/O	0.030	0.023	0.020	0.019	0.078
11	0.019	0.018	0.019	0.028	0.021	0.020	0.072
12	0.020	0.018	0.019	0.018	0.020	0.027	0.078
13	0.023	0.021	0.029	P/O	P/O	P/O	0.610
14	0.069	P/O	P/O	P/O	0.050	0.043	0.126
15	0.046	0.045	0.055	0.034	P/O	P/O	0.131
16	P/O	P/O	P/O	0.034	0.047	0.059	0.141
17	0.038	0.048	0.042	0.044	0.132	0.039	0.470
18	0.029	0.031	P/O	0.041	0.029	0.026	0.118
19	P/O	P/O	P/O	0.068	0.053	0.038	0.181
20	0.075	0.033	0.027	0.026	0.043	0.030	0.135
21	0.026	P/O	0.025	0.028	0.038	0.030	0.128
22	P/O	P/O	P/O	0.025	0.023	0.022	0.044
23	0.024	0.039	0.036	0.061	0.041	0.111	0.174
24	P/O	P/O	P/O	0.074	0.033	0.027	0.152
25	0.024	0.031	0.029	0.026	0.024	0.032	0.113
26	0.030	P/O	0.027	P/O	0.028	0.033	0.079
27	0.034	0.027	P/O	P/O	P/O	P/O	0.081
28	0.035	0.034	0.028	0.028	0.035	0.028	0.074
29	No Data	No Data	No Data	No Data	No Data	No Data	0.000
30	No Data	No Data	No Data	No Data	No Data	No Data	0.000
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

WTP: TP - A

<b>Conventional or Direct Filtration</b> 95% of 4-hour turbidity readings $\leq$ 0.3 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / <input type="radio"/> No All 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point $\geq$ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes: P/O = PLANT OFF DV = DIVERTED		PRINTED NAME: Jonathan Woody SIGNATURE: <i>[Signature]</i> DATE: 3-9-21 PHONE #: (541) 643-6137 CERT# 7232	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individual Filter Eff. (333-061-0040(T)(D)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: Glide Water Association

ID#: 4100326

Month/Year: Feb-21

Dialfection  
Glendale Log  
Inactive:

1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>a</sup> [ppm or mg/L]	Contact Time (m) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
2/1/2021 22:49	0.7	150	104	7	7.3	49	Yes	175
2/2/2021 10:37	0.7	150	103	7	7.3	49	Yes	175
2/3/2021 8:48	0.7	150	110	7	7.3	50	Yes	175
2/4/2021 1:15	0.8	150	125	6	7.2	52	Yes	175
2/5/2021 1:33	0.9	150	134	6	7.4	55	Yes	175
2/6/2021 7:12	0.9	150	135	7	7.4	56	Yes	175
2/7/2021 8:29	0.9	150	136	7	7.4	55	Yes	175
2/8/2021 22:30	0.8	150	116	7	7.5	54	Yes	175
2/9/2021 6:56	0.8	150	113	7	7.5	55	Yes	175
2/10/2021 8:25	0.8	150	125	6	7.5	57	Yes	175
2/11/2021 7:31	0.9	150	133	6	7.5	57	Yes	175
2/12/2021 7:37	0.9	150	140	7	7.4	56	Yes	175
2/13/2021 22:27	0.9	150	138	8	7.3	50	Yes	175
2/14/2021 15:56	0.8	150	116	8	7.2	45	Yes	175
2/15/2021 1:45	0.8	150	124	8	7.1	44	Yes	175
2/16/2021 10:16	0.8	150	115	8	7.1	43	Yes	175
2/17/2021 2:25	0.8	150	117	8	7.2	46	Yes	175
2/18/2021 18:50	1.2	150	173	8	7.2	49	Yes	175
2/19/2021 22:58	0.9	150	132	8	7.1	46	Yes	175
2/20/2021 10:11	0.8	150	120	8	7.2	46	Yes	175
2/21/2021 7:39	0.8	150	119	8	7.2	46	Yes	175
2/22/2021 9:48	0.8	150	119	8	7.3	46	Yes	175
2/23/2021 5:40	0.8	150	122	7	7.3	49	Yes	175
2/24/2021 9:59	0.9	150	141	7	7.2	49	Yes	175
2/25/2021 22:29	0.9	150	133	7	7.3	51	Yes	175
2/26/2021 22:02	0.8	150	124	7	7.6	55	Yes	175
2/27/2021 22:06	0.8	150	119	7	7.5	54	Yes	175
2/28/2021 3:11	0.8	150	116	7	7.7	60	Yes	175
29	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175
30	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

<sup>a</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwp@dnr.or.gov; 971-673-0894; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350