

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
Month/Year: **Mar-21**

System Name **Glide Water Association** ID#: **4100326** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.027	0.046	0.035	0.025	0.022	0.027	0.070
2	0.026	0.024	0.022	0.021	0.029	0.024	0.072
3	0.023	P/O	0.022	0.029	0.025	0.022	0.070
4	0.022	0.020	P/O	0.030	0.023	0.022	0.072
5	0.026	0.028	P/O	0.024	0.022	0.027	0.068
6	P/O	P/O	P/O	P/O	P/O	P/O	P/O
7	P/O	P/O	P/O	0.030	0.025	0.032	0.079
8	0.028	0.025	0.031	0.029	0.035	0.040	0.170
9	0.030	P/O	P/O	P/O	P/O	P/O	0.030
10	0.030	0.027	P/O	P/O	P/O	0.058	0.058
11	0.036	0.083	0.032	0.030	0.025	0.023	0.124
12	0.022	0.025	0.022	0.021	0.025	0.029	0.105
13	P/O	P/O	P/O	P/O	P/O	P/O	P/O
14	P/O	P/O	0.063	0.023	0.029	0.027	0.105
15	0.024	0.035	0.027	0.032	0.027	0.025	0.150
16	0.024	P/O	0.025	0.034	0.027	0.022	0.113
17	0.020	P/O	P/O	P/O	P/O	P/O	0.100
18	P/O	P/O	0.044	0.028	0.025	0.022	0.065
19	0.020	0.020	0.030	0.027	0.069	0.038	0.078
20	P/O	P/O	0.035	0.045	0.036	0.033	0.040
21	P/O	P/O	P/O	0.089	0.035	0.039	0.040
22	0.037	0.035	P/O	0.035	0.048	0.041	0.100
23	P/O	P/O	0.044	0.047	0.062	P/O	0.142
24	P/O	P/O	0.061	0.043	0.069	0.120	0.131
25	P/O	P/O	0.070	0.045	0.036	0.045	0.153
26	0.115	P/O	0.052	0.039	0.032	0.030	0.163
27	P/O	P/O	P/O	P/O	P/O	P/O	0.172
28	0.049	0.033	0.030	0.031	0.035	0.030	0.093
29	0.028	0.038	0.031	0.029	0.028	0.031	0.093
30	0.032	0.030	P/O	P/O	0.030	0.033	0.081
31	0.029	0.028	P/O	0.027	0.026	0.026	0.033

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	<input checked="" type="radio"/> Yes No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes No	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED	SIGNATURE: PHONE #: (541) 643-6137		DATE: 4 / 6 / 2021
	<i>Jonathan Woody</i>		CERT #: 7232

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A
 Disinfection
 Giardia Log
 Inactive: 1.0

System Name: Glide Water Association ID#:4100328 Month/Year: Mar-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
3/1/2021 23:05	0.8	150	120	7	7.7	59	Yes	175
3/2/2021 7:04	0.7	150	110	7	8.5	77	Yes	175
3/3/2021 7:11	0.7	150	109	7	7.8	58	Yes	175
3/4/2021 7:59	0.7	150	112	7	7.8	59	Yes	175
3/5/2021 21:14	0.8	150	116	8	7.6	55	Yes	175
3/6/2021 0:30	POL	150	#VALUE!	POL	POL	#VALUE!	#VALUE!	175
3/7/2021 9:37	0.7	150	112	8	7.8	58	Yes	175
8	0.9	150	129	10	7.5	44	Yes	175
9	0.7	150	111	8	7.5	52	Yes	175
3/10/2021 0:33	0.7	150	112	7	7.6	56	Yes	175
3/11/2021 0:31	0.8	150	116	7	7.7	59	Yes	175
3/12/2021 5:47	0.8	150	113	8	7.8	59	Yes	175
3/13/2021 0:30	POL	150	#VALUE!	POL	POL	#VALUE!	#VALUE!	175
3/14/2021 7:58	0.7	150	109	7	7.7	56	Yes	175
3/15/2021 22:52	0.7	150	109	7	7.8	61	Yes	175
3/16/2021 6:32	0.7	150	104	7	7.8	61	Yes	175
3/17/2021 5:51	0.7	150	111	7	7.7	58	Yes	175
3/18/2021 7:26	0.7	150	106	8	7.9	59	Yes	175
3/19/2021 8:18	0.8	150	115	8	7.8	56	Yes	175
3/20/2021 6:19	0.7	150	110	8	7.8	57	Yes	175
3/21/2021 8:46	0.8	150	127	8	8.0	61	Yes	175
3/22/2021 18:16	0.9	150	133	7	7.8	59	Yes	175
3/23/2021 6:20	0.8	150	124	8	7.8	59	Yes	175
3/24/2021 7:36	0.8	150	125	8	7.8	59	Yes	175
3/25/2021 9:20	0.9	150	129	8	7.9	61	Yes	175
3/26/2021 7:23	0.9	150	136	8	7.9	61	Yes	175
3/27/2021 23:28	0.9	150	131	9	7.7	51	Yes	175
3/28/2021 0:31	0.9	150	136	9	8.0	59	Yes	175
3/29/2021 23:15	0.9	150	130	9	8.0	58	Yes	175
3/30/2021 11:56	0.8	150	127	8	8.1	64	Yes	175
3/31/2021 7:54	0.8	150	127	8	8.0	63	Yes	175

² If Cl₂ at entry point < 0.2 mg/L or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to: