

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
Month/Year: **Apr-21**

System Name **Glide Water Association** ID#: **4100326** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.026	P/O	0.027	0.033	0.028	P/O	0.074
2	P/O	P/O	0.036	0.050	0.062	0.034	0.640
3	0.029	0.027	P/O	P/O	P/O	P/O	0.030
4	P/O	P/O	P/O	0.026	0.026	0.030	0.052
5	0.026	0.026	0.035	0.028	0.028	P/O	0.083
6	P/O	P/O	0.036	0.029	0.028	0.028	0.090
7	P/O	P/O	0.035	0.029	0.028	0.031	0.089
8	0.030	0.029	0.030	0.028	0.028	0.031	0.031
9	0.029	0.029	0.029	0.029	0.033	0.031	0.033
10	0.029	0.029	0.041	0.031	0.031	0.031	0.041
11	0.031	0.035	0.037	0.030	0.033	0.033	0.037
12	0.033	0.033	0.041	0.035	0.033	0.033	0.041
13	0.037	0.038	0.037	0.027	0.046	0.029	0.046
14	0.029	0.027	0.025	0.029	0.029	0.027	0.029
15	0.027	0.098	0.031	0.028	0.027	0.037	0.210
16	0.037	0.037	0.037	0.029	0.029	0.039	0.040
17	0.033	0.031	0.031	0.037	0.030	0.035	0.037
18	0.037	0.033	0.035	0.035	0.035	0.042	0.037
19	0.041	0.041	0.037	0.042	0.035	0.033	0.042
20	0.042	0.043	0.033	0.033	0.035	0.029	0.043
21	0.028	0.027	0.031	0.026	0.027	0.031	0.031
22	0.026	0.026	0.026	0.028	0.026	0.037	0.037
23	0.037	0.037	0.027	0.026	0.033	0.029	0.037
24	0.031	0.029	0.026	0.029	0.028	0.035	0.035
25	0.035	0.035	0.035	0.028	0.033	0.029	0.035
26	0.061	0.061	0.037	0.026	0.031	0.037	0.061
27	0.037	0.037	0.048	0.022	0.031	0.026	0.048
28	0.026	P/O	0.024	0.082	0.021	0.026	0.160
29	0.024	P/O	0.022	0.020	0.028	0.022	0.118
30	P/O	P/O	0.027	0.023	0.021	0.028	0.137
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>John Woody</i>	DATE: 5/9/21
		PHONE #: (541) 496-3614	CERT #: D-069208/T-09207

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Glide Water Association** ID#:4100326 Month/Year: **Apr-21** Disinfection
Giardia Log Inactive: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
4/1/2021 8:00	0.9	150	133	9	8.1	61	Yes	175
4/2/2021 7:10	0.9	150	133	9	8.0	56	Yes	175
4/3/2021 1:04	0.9	150	140	10	7.7	49	Yes	175
4/4/2021 8:42	0.9	150	133	10	7.9	53	Yes	175
4/5/2021 9:04	0.9	150	130	9	7.8	52	Yes	175
4/6/2021 7:37	0.8	150	116	9	7.8	54	Yes	175
4/7/2021 6:17	0.8	150	119	9	7.8	53	Yes	175
4/8/2021 8:46	0.9	150	140	9	7.9	55	Yes	175
4/9/2021 5:27	0.9	150	134	9	7.9	55	Yes	175
4/10/2021 7:51	1.0	150	143	9	7.8	53	Yes	175
4/11/2021 8:25	0.9	150	142	9	7.8	56	Yes	175
4/12/2021 23:01	0.7	150	106	9	7.9	54	Yes	175
4/13/2021 7:17	0.6	150	97	10	7.9	53	Yes	175
4/14/2021 3:46	0.9	150	131	9	7.9	54	Yes	175
4/15/2021 6:20	0.9	150	140	10	7.9	53	Yes	175
4/16/2021 7:51	1.0	150	143	10	7.9	51	Yes	175
4/17/2021 1:40	1.0	150	149	11	7.8	47	Yes	175
4/18/2021 7:03	1.0	150	152	12	7.9	47	Yes	175
4/19/2021 21:12	0.9	150	134	12	7.8	44	Yes	175
4/20/2021 20:42	0.7	150	109	12	7.9	45	Yes	175
4/21/2021 3:19	0.6	150	95	11	7.8	45	Yes	175
4/22/2021 5:29	0.7	150	102	11	7.8	46	Yes	175
4/23/2021 6:13	0.7	150	103	11	7.8	46	Yes	175
4/24/2021 3:26	0.7	150	106	11	7.7	45	Yes	175
4/25/2021 6:18	0.7	150	109	11	7.7	46	Yes	175
4/26/2021 17:42	0.7	150	112	10	7.8	49	Yes	175
4/27/2021 7:01	0.6	150	91	10	7.8	49	Yes	175
4/28/2021 5:40	0.7	150	103	11	7.8	46	Yes	175
4/29/2021 5:29	0.9	150	133	12	7.9	45	Yes	175
4/30/2021 5:48	0.9	150	136	13	7.8	42	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350