

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jun-21**

System Name **Glide Water Association** ID#: **4100326** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.024	0.024	0.024	0.024	0.024	0.025	0.168
2	0.029	0.026	0.026	0.030	0.028	0.033	0.176
3	0.031	0.030	0.030	0.027	0.029	0.030	0.156
4	0.029	0.026	0.026	0.033	0.030	0.031	0.490
5	0.030	0.028	0.031	0.029	0.034	0.033	0.089
6	0.033	0.032	0.032	0.031	0.032	0.036	0.084
7	0.035	0.033	0.032	0.024	0.026	0.026	0.072
8	0.029	0.028	0.026	0.026	0.026	0.026	0.030
9	0.026	P/O	0.031	0.028	0.028	0.028	0.071
10	0.028	P/O	0.028	0.026	0.029	0.029	0.083
11	0.028	0.028	0.029	0.028	0.028	0.029	0.067
12	0.034	0.031	0.030	0.030	0.031	0.032	0.033
13	0.032	0.032	0.030	0.032	0.034	0.035	0.083
14	0.035	0.035	0.035	0.036	0.040	0.040	0.046
15	0.070	pol	pol	pol	pol	pol	0.070
16	0.030	0.030	0.030	0.030	0.040	0.030	0.040
17	0.029	0.026	0.028	0.026	0.028	0.031	0.117
18	0.034	0.029	0.028	0.026	0.028	0.031	0.032
19	0.030	0.027	0.045	0.028	0.029	0.033	0.107
20	0.031	0.027	0.026	0.030	0.030	0.037	0.170
21	0.034	0.030	0.028	0.032	0.032	0.037	0.091
22	0.035	0.032	0.030	0.036	0.037	0.043	0.100
23	0.042	0.038	0.037	0.035	0.033	0.038	0.115
24	0.035	0.030	0.029	0.033	0.033	0.037	0.109
25	0.035	0.031	0.030	0.035	0.057	0.037	0.109
26	0.035	0.031	0.030	0.031	0.038	0.040	0.098
27	0.038	0.034	0.033	0.034	0.041	0.045	0.116
28	0.042	0.038	0.038	0.051	0.039	0.044	0.265
29	0.040	0.034	0.036	0.035	0.041	0.046	0.197
30	0.045	0.042	0.036	0.033	0.032	0.037	0.167
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 7-9-21
		PHONE #: (541) 643-8137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : **A**

System Name: **Glide Water Association** ID#: **4100326**

Month/Year:

Disinfection
Gardle Log
Inactive: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (m)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
6/1/2021 0:43	0.9	150	130	17	7.9	34	Yes	175
6/2/2021 22:16	0.8	150	120	18	7.9	31	Yes	175
6/3/2021 22:46	0.8	150	123	19	8.0	30	Yes	175
6/4/2021 10:22	0.8	150	122	19	8.0	30	Yes	175
6/5/2021 8:06	0.8	150	116	18	7.9	30	Yes	175
6/6/2021 8:29	0.8	150	122	16	7.9	34	Yes	175
6/7/2021 21:20	0.7	150	105	15	8.0	37	Yes	175
6/8/2021 6:46	0.6	150	97	15	7.9	37	Yes	175
6/9/2021 5:12	0.7	150	106	14	7.9	38	Yes	175
6/10/2021 5:46	0.7	150	110	14	7.9	38	Yes	175
6/11/2021 9:04	0.7	150	112	14	7.7	35	Yes	175
6/12/2021 8:25	0.7	150	109	14	7.8	39	Yes	175
6/13/2021 18:35	0.7	150	105	16	7.9	35	Yes	175
6/14/2021 21:13	0.6	150	97	16	7.7	32	Yes	175
15	0.6	150	92	17	8.5	40	Yes	175
16	0.7	150	101	18	8.5	37	Yes	175
6/17/2021 6:32	0.7	150	109	16	8.1	36	Yes	175
6/18/2021 7:27	0.7	150	109	17	8.1	34	Yes	175
6/19/2021 8:05	0.7	150	108	19	8.1	31	Yes	175
6/20/2021 10:00	0.8	150	115	20	8.1	29	Yes	175
6/21/2021 3:10	0.8	150	118	20	8.2	29	Yes	175
6/22/2021 0:47	0.8	150	127	20	8.2	29	Yes	175
6/23/2021 10:02	0.8	150	127	20	8.2	29	Yes	175
6/24/2021 10:03	0.8	150	127	20	8.2	29	Yes	175
6/25/2021 10:33	0.9	150	130	20	8.1	28	Yes	175
6/26/2021 23:34	0.9	150	133	21	8.1	27	Yes	175
6/27/2021 23:11	0.9	150	130	22	8.1	26	Yes	175
6/28/2021 20:02	0.8	150	120	23	8.1	24	Yes	175
6/29/2021 22:29	0.8	150	118	22	8.2	26	Yes	175
6/30/2021 0:58	0.8	150	119	22	8.2	27	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

³ If CT at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dws.dmsca@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360