

Conventional or Direct Filtration

County: Douglas
 Month/Year: Sep-21
 WTP: TP - A

System Name: Glide Water Association

ID#: 4100326

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.024	0.023	P/O	0.023	0.025	0.030	0.103
2	0.026	P/O	0.026	0.026	0.032	0.031	0.141
3	0.031	0.032	P/O	0.028	0.020	0.022	0.088
4	0.023	P/O	0.020	0.019	0.020	0.019	0.082
5	0.022	0.020	P/O	0.019	0.019	0.020	0.077
6	0.021	0.020	0.020	0.020	0.020	0.023	0.082
7	0.020	P/O	0.021	0.020	0.025	0.021	0.121
8	0.020	P/O	0.020	0.023	0.021	0.022	0.079
9	0.021	P/O	0.036	0.021	0.021	0.022	0.105
10	0.023	0.022	P/O	0.021	0.021	P/O	0.038
11	0.022	0.021	P/O	0.021	0.023	0.024	0.088
12	0.024	P/O	0.025	0.021	0.022	0.030	0.082
13	0.025	P/O	0.024	0.022	0.027	0.026	0.171
14	0.029	0.028	0.025	0.024	0.023	0.025	0.055
15	0.023	P/O	0.028	0.024	0.023	0.025	0.103
16	0.025	0.030	0.027	0.025	0.026	0.026	0.095
17	0.026	P/O	0.037	0.027	0.027	0.030	0.112
18	0.030	P/O	0.031	0.032	0.038	0.044	0.073
19	P/O	0.053	P/O	0.087	P/O	P/O	0.641
20	P/O	P/O	0.018	0.039	0.049	0.053	0.144
21	0.041	0.035	P/O	0.027	0.024	0.028	0.073
22	0.024	P/O	0.021	0.021	0.020	0.018	0.064
23	0.020	0.019	P/O	0.017	0.018	0.018	0.040
24	0.018	P/O	0.023	0.018	0.018	0.020	0.053
25	0.018	P/O	P/O	0.022	0.018	0.021	0.049
26	0.020	P/O	0.025	0.021	0.022	0.020	0.049
27	P/O	0.023	0.024	0.023	0.025	0.025	0.049
28	0.025	P/O	0.027	0.053	0.030	0.029	0.134
29	P/O	P/O	0.025	0.026	0.026	0.021	0.044
30	P/O	P/O	0.023	0.021	0.022	P/O	0.065
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

Conventional or Direct Filtration 95% of 4-hour turbidity readings ≤ 0.3 NTU? ² <input checked="" type="checkbox"/> Yes / No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No All turbidity readings < IFE ³ triggers <input checked="" type="checkbox"/> Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
Notes: P/O = PLANT OFF DV = DIVERTED		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> PHONE #: (641) 643-8137 DATE: 10-2-21 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-081-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP : A

System Name: **Gilde Water Association** ID#: **4100328**

Month/Year:

Disinfection
Garde Log
Inactive: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (m)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
9/1/2021 7:58	0.8	150	115	16	7.8	33	Yes	175
9/2/2021 6:28	0.8	150	119	15	7.9	36	Yes	175
9/3/2021 7:59	0.8	150	121	15	7.8	35	Yes	175
9/4/2021 7:03	0.8	150	116	15	7.8	35	Yes	175
9/5/2021 8:57	0.8	150	127	15	7.7	35	Yes	175
9/6/2021 20:47	0.8	150	121	15	7.8	35	Yes	175
9/7/2021 17:00	0.8	150	122	16	7.8	34	Yes	175
9/8/2021 12:25	0.8	150	121	16	7.9	35	Yes	175
9/9/2021 10:01	0.8	150	127	16	7.7	32	Yes	175
9/10/2021 9:02	0.8	150	122	16	7.5	30	Yes	175
9/11/2021 22:30	0.9	150	134	15	7.7	34	Yes	175
9/12/2021 7:38	0.9	150	133	16	7.6	33	Yes	175
9/13/2021 17:35	0.8	150	122	16	7.2	27	Yes	175
9/14/2021 6:53	0.8	150	116	16	7.2	27	Yes	175
9/15/2021 9:05	0.8	150	124	15	7.1	27	Yes	175
9/16/2021 8:01	0.8	150	121	15	7.1	27	Yes	175
9/17/2021 9:16	0.9	150	128	14	7.1	29	Yes	175
9/18/2021 8:08	0.9	150	128	15	7.1	28	Yes	175
9/19/2021 9:05	0.8	150	118	14	7.6	35	Yes	175
9/20/2021 8:03	0.6	150	85	14	7.7	35	Yes	175
9/21/2021 9:50	0.5	150	79	14	7.7	35	Yes	175
9/22/2021 7:33	0.7	150	100	14	7.6	35	Yes	175
9/23/2021 8:46	0.8	150	121	15	7.7	35	Yes	175
9/24/2021 7:40	0.9	150	128	15	7.7	35	Yes	175
9/25/2021 11:11	0.8	150	124	15	7.7	35	Yes	175
9/26/2021 8:20	0.9	150	130	15	7.8	36	Yes	175
9/27/2021 18:54	0.8	150	113	15	7.6	33	Yes	175
9/28/2021 7:23	0.7	150	112	14	7.3	32	Yes	175
9/29/2021 7:09	0.7	150	107	13	7.5	35	Yes	175
9/30/2021 7:42	0.6	150	83	13	7.5	35	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dince@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350