

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: **Douglas**  
 Month/Year: **Oct-21**

System Name **Glide Water Association** ID# **4100328** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.019	P/O	0.017	0.021	0.020	0.019	0.034
2	P/O	P/O	0.019	0.020	0.019	0.018	0.053
3	0.018	P/O	P/O	0.018	0.020	0.020	0.042
4	0.021	P/O	P/O	0.020	0.020	0.023	0.040
5	P/O	P/O	0.023	0.021	0.023	0.023	0.055
6	0.023	P/O	0.027	0.024	0.025	0.025	0.055
7	0.026	P/O	0.031	0.024	0.023	0.026	0.064
8	P/O	P/O	0.023	0.024	0.025	0.025	0.053
9	0.025	P/O	P/O	0.023	0.023	0.026	0.058
10	0.023	P/O	P/O	0.028	0.027	0.025	0.191
11	P/O	P/O	0.029	0.028	0.027	P/O	0.058
12	0.029	P/O	0.027	0.030	0.029	0.029	0.060
13	0.031	P/O	0.030	0.030	P/O	0.034	0.106
14	0.034	0.034	P/O	0.035	0.034	0.048	0.105
15	0.038	P/O	0.033	0.030	-0.009	P/O	0.120
16	P/O	P/O	P/O	0.026	0.019	0.019	0.069
17	0.019	P/O	P/O	0.024	0.019	0.019	0.056
18	P/O	P/O	P/O	0.021	0.019	0.019	0.068
19	P/O	P/O	0.026	0.020	0.019	0.019	0.055
20	0.019	P/O	0.025	0.020	P/O	0.019	0.058
21	P/O	P/O	0.026	0.021	P/O	0.021	0.058
22	P/O	0.049	0.122	0.114	P/O	P/O	0.280
23	0.075	0.128	P/O	0.066	0.070	P/O	0.554
24	P/O	P/O	P/O	0.054	P/O	P/O	0.165
25	0.038	0.036	0.029	0.032	0.028	P/O	0.103
26	0.026	0.024	P/O	0.038	0.026	P/O	0.062
27	0.023	P/O	0.032	0.025	P/O	0.025	0.069
28	P/O	P/O	0.027	0.031	0.046	0.031	0.093
29	P/O	0.027	P/O	0.027	0.025	0.034	0.071
30	P/O	P/O	0.032	0.030	0.036	0.032	0.071
31	0.032	P/O	P/O	0.031	0.035	0.036	0.073

Conventional or Direct Filtration 95% of 4-hour turbidity readings $\leq$ 0.3 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / <input type="radio"/> No All 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point $\geq$ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes: P/O = PLANT OFF DV = DIVERTED		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> DATE: 11-7-21 PHONE #: (641) 643-6137 CERT #: 7232	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

WTP: **A**

System Name: **Glide Water Association**

ID#: **4100328**

Month/Year:

Distribution  
Glide Log  
Instr: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (c) <sup>2</sup>	Contact Time (m)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
10/1/2021 4:22	0.8	150	119	14	7.6	37	Yes	175
10/2/2021 6:11	1.0	150	146	14	7.6	37	Yes	175
10/3/2021 9:14	1.0	150	153	14	7.8	40	Yes	175
10/4/2021 19:30	0.9	150	137	14	7.8	40	Yes	175
10/5/2021 8:15	0.8	150	117	13	7.6	37	Yes	175
10/6/2021 8:11	0.7	150	110	13	7.6	39	Yes	175
10/7/2021 6:57	0.7	150	104	12	7.8	42	Yes	175
10/8/2021 21:46	0.9	150	140	11	7.7	45	Yes	175
10/9/2021 8:21	0.8	150	127	11	7.6	43	Yes	175
10/10/2021 10:24	0.9	150	133	11	7.7	44	Yes	175
10/11/2021 21:44	0.8	150	116	11	7.6	43	Yes	175
10/12/2021 8:19	0.7	150	108	10	7.5	45	Yes	175
10/13/2021 17:10	0.7	150	111	11	7.7	45	Yes	175
10/14/2021 9:06	0.9	150	130	11	7.6	45	Yes	175
10/15/2021 9:52	0.8	150	119	10	7.6	45	Yes	175
10/16/2021 9:28	0.7	150	110	10	7.7	47	Yes	175
10/17/2021 9:38	0.9	150	130	10	7.8	48	Yes	175
10/18/2021 18:17	0.7	150	109	11	7.7	46	Yes	175
10/19/2021 6:46	0.6	150	97	11	7.6	45	Yes	175
10/20/2021 8:25	0.9	150	128	11	7.6	45	Yes	175
10/21/2021 6:29	0.8	150	124	12	7.8	42	Yes	175
10/22/2021 21:34	0.7	150	109	12	7.5	40	Yes	175
10/23/2021 8:17	0.6	150	91	12	7.2	36	Yes	175
10/24/2021 20:08	0.4	150	67	12	7.3	36	Yes	175
10/25/2021 23:37	0.8	150	122	11	7.2	38	Yes	175
10/26/2021 11:46	0.7	150	103	11	7.2	37	Yes	175
10/27/2021 5:48	0.7	150	98	11	7.2	37	Yes	175
10/28/2021 5:36	0.7	150	104	12	7.3	37	Yes	175
10/29/2021 2:37	0.8	150	119	12	7.3	36	Yes	175
10/30/2021 9:20	0.9	150	134	12	7.4	38	Yes	175
10/31/2021 9:24	0.9	150	134	12	7.4	39	Yes	175

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 15th of following month by email, fax, or mail to:  
 dno.dnrc@state.or.us; 571-673-0804; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360