

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
Month/Year: **Nov-21**

System Name **Gilde Water Association** ID#: **4100326** WTP: TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	P/O	P/O	0.034	0.023	0.032	0.021	0.289
2	0.021	P/O	0.027	0.025	0.026	P/O	0.075
3	0.021	P/O	0.024	0.025	0.020	0.019	0.089
4	0.019	P/O	0.024	0.025	0.021	P/O	0.098
5	P/O	P/O	0.027	0.076	0.075	0.064	0.221
6	0.081	P/O	0.044	0.125	0.152	0.103	0.284
7	0.038	P/O	P/O	0.029	0.034	0.094	0.127
8	P/O	P/O	0.083	0.028	0.022	0.031	0.156
9	0.025	P/O	0.022	0.021	0.021	0.028	0.036
10	0.025	P/O	0.023	0.023	0.027	0.026	0.078
11	P/O	P/O	0.038	P/O	P/O	0.080	0.147
12	0.045	0.034	0.027	0.023	0.024	0.025	0.108
13	P/O	P/O	0.020	0.023	0.021	P/O	0.056
14	P/O	P/O	P/O	0.022	0.021	0.022	0.053
15	0.022	P/O	0.021	0.021	0.025	P/O	0.047
16	P/O	P/O	0.023	0.021	0.019	0.028	0.123
17	P/O	0.019	0.019	0.027	0.022	0.024	0.082
18	0.023	P/O	0.020	0.019	0.025	0.021	0.049
19	P/O	0.019	0.031	0.024	0.020	P/O	0.034
20	0.019	P/O	P/O	0.025	0.020	0.019	0.049
21	0.025	P/O	P/O	0.023	0.021	0.021	0.043
22	0.026	P/O	0.027	0.019	0.024	0.018	0.030
23	0.019	P/O	0.018	0.024	P/O	0.019	0.034
24	P/O	P/O	P/O	0.025	0.023	0.025	0.062
25	P/O	P/O	0.020	0.028	0.022	0.019	0.055
26	0.032	P/O	0.023	0.021	P/O	0.025	0.047
27	P/O	0.022	P/O	0.020	0.019	0.026	0.040
28	P/O	P/O	P/O	0.021	0.024	0.021	0.043
29	P/O	P/O	0.022	0.025	0.022	P/O	0.067
30	0.021	P/O	0.035	0.024	0.021	P/O	0.051
31	No Data	No Data	No Data	No Data	No Data	No Data	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jonathan Woody	
Notes: P/O = PLANT OFF DV = DIVERTED		SIGNATURE: <i>Jonathan Woody</i>	DATE: 12-6-21
		PHONE #: (641) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Glide Water Association ID#:4100326 Month/Year:

Disinfection
Giardia Log
Inactive: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
11/1/2021 8:13	0.9	150	138	12	7.5	41	Yes	175
11/2/2021 6:56	0.9	150	128	11	7.4	40	Yes	175
11/3/2021 21:41	0.8	150	127	11	7.5	41	Yes	175
11/4/2021 6:56	0.8	150	115	12	7.4	38	Yes	175
11/5/2021 16:07	0.6	150	88	11	7.3	38	Yes	175
11/6/2021 6:47	0.7	150	101	11	7.1	38	Yes	175
11/7/2021 12:42	0.8	150	115	10	7.2	40	Yes	175
11/8/2021 18:05	0.7	150	101	9	7.4	45	Yes	175
11/9/2021 6:31	0.6	150	95	9	7.3	42	Yes	175
11/10/2021 6:37	0.7	150	110	9	7.2	43	Yes	175
11/11/2021 22:54	0.8	150	122	10	7.3	41	Yes	175
11/12/2021 10:51	0.8	150	113	11	7.1	36	Yes	175
11/13/2021 8:35	0.8	150	119	12	7.2	36	Yes	175
11/14/2021 9:00	0.8	150	127	11	7.2	38	Yes	175
11/15/2021 7:33	0.7	150	104	11	7.2	38	Yes	175
11/16/2021 6:29	0.6	150	97	10	7.2	40	Yes	175
11/17/2021 3:19	0.9	150	137	8	7.2	46	Yes	175
11/18/2021 6:20	0.9	150	131	8	7.3	48	Yes	175
11/19/2021 21:37	0.9	150	137	9	7.3	46	Yes	175
11/20/2021 8:26	0.9	150	128	8	7.3	48	Yes	175
11/21/2021 8:14	0.9	150	129	7	7.3	51	Yes	175
11/22/2021 6:08	0.9	150	131	7	7.3	52	Yes	175
11/23/2021 6:41	0.8	150	125	7	7.2	49	Yes	175
11/24/2021 7:46	0.9	150	128	7	7.3	50	Yes	175
11/25/2021 7:30	0.9	150	135	7	7.4	53	Yes	175
11/26/2021 7:11	0.9	150	138	7	7.3	51	Yes	175
11/27/2021 2:12	1.0	150	147	8	7.3	49	Yes	175
11/28/2021 9:09	0.9	150	137	9	7.3	46	Yes	175
11/29/2021 20:59	0.8	150	113	9	7.3	45	Yes	175
11/30/2021 6:52	0.7	150	106	8	7.3	46	Yes	175
31	#N/A	150	#N/A	#N/A	#N/A	#N/A	#N/A	175

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dms@state.or.us; 971-673-0894; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350